



1112 Manatee Ave. West
Bradenton, FL 34205
purchasing@mymanatee.org

Solicitation Addendum

Addendum No.:	2
Solicitation No.:	20-R074487GE
Solicitation Title:	Portable Diesel Generators
Addendum Date:	July 14, 2020
Procurement Contact:	George Earnest, CPPB

IFB No. 20-R074487GE for Portable Diesel Generators is amended as set forth herein. Responses to questions posed by prospective bidders are provided below. This addendum is hereby incorporated in and made a part of IFB No. 20-R074487GE.

CHANGE TO:

EXHIBIT 1, SCOPE OF WORK/SPECIFICATIONS, SECTION 1.07, ENCLOSURE

The generator enclosure shall meet or exceed these minimum requirements:

- A. Generator set shall be enclosed in a weather-protective housing constructed of heavy-gauge, reinforced aluminum. Alternative materials for the enclosure are acceptable as long as the Supplier provides an unlimited ten (10) year warranty against rust and corrosion as per Section 1.03 WARRANTY. The housing shall be attached to the generator set standard mounting base and radiator cooling. Unit and enclosure shall be designed to operate fully during wind-driven rainstorms.

NOTE: Items that are ~~struck through~~ are deleted. Items that are underlined have been added or changed. All other terms and conditions remain as stated in the IFB.

END OF ADDENDUM

INSTRUCTIONS:

Receipt of this addendum must be acknowledged as instructed in the solicitation document. Failure to acknowledge receipt of this Addendum may result in the response being deemed non-responsive.

AUTHORIZED FOR RELEASE