



1112 Manatee Ave. West
Bradenton, FL 34205
purchasing@mymanatee.org

Solicitation Addendum

Addendum No.:	1
Solicitation No.:	20-R074554AJ
Solicitation Title:	Perico – Robinson Connector Boardwalk Construction
Addendum Date:	August 18, 2020
Procurement Contact:	Abby Jenkins

ITQ No. 20-R074554AJ is amended as set forth herein. Responses to questions posed by prospective bidders are provided below. This addendum is hereby incorporated in and made a part of ITQ No. 20-R074554AJ.

ADD:

EXHIBIT 6, ROOKERY AT PERICO SEAGRASS ADVANCE MITIGATION DRAWINGS

Exhibit 6, Rookery at Perico Seagrass Advance Mitigation Drawings is hereby incorporated into the ITQ as a separate attachment.

CHANGE TO:

EXHIBIT 2, MINIMUM QUALIFICATIONS, 2.03

Bidder must possess one of the following licenses: a current, Certified General Contractor's license, Certified Building Contractor license or Marine Specialty license issued by the Florida Department of Business and Professional Regulation for a period of at least four (4) consecutive years since July 1, 2016. License must be current and valid through the Due Date for submission of bids for this ITQ.

Provide a copy of either the Bidder's General Contractor's license, Certified Building Contractor license or Marine Specialty license, issued by the Florida Department of Business and Professional Regulation and documentation confirming Bidder has been licensed and/or certified for the period of July 1, 2016 through the date of submission of the ITQ.

QUESTIONS AND RESPONSES:

Q1. Could you please provide the Budget /engineering cost estimate for the Perico - Robinson Connector Boardwalk Construction?

R1. Due to the size and scope of this project an engineer estimate of cost was not warranted. However, the budget exceeds all reasonable costs for the assigned work and will not be a limiting factor for awarding a contract; in addition, constraints on cost are provided through a highly competitive bidding process.

Q2. Do you anticipate extending the bid due date?

R2. No

Q3. Is there a spec for the desired live load?

R3. Structural load (live load and dead load) should be based on (1) 1600-LB Vehicle and (2) 200-LB Persons with a structural load safety factor of 1.5.

Q4. Will this be intended for pedestrian traffic only or will vehicle traffic need to be considered?

R4. Structures are intended for pedestrian and staff UTV use. Structural load (live load and dead load) should be based on (1) 1600-LB Vehicle and (2) 200-LB Persons with a structural load safety factor of 1.5.

Q5. Are there any soil borings or geotechnical data available for the project area?

R5. There is no soil boring or geotechnical data available for the project area. However, soil profile data associated with boardwalks constructed in 2015 at Perico Preserve is provided for reference only (see attached Exhibit 6 "Rookery at Perico Seagrass Advance Mitigation" by Watermark Engineering Group, Inc.). Contractor is responsible for collection of all applicable soils/geotechnical data as stated in the bid specifications.

Q6. What wind speed load is the full wood curtain to withstand?

R6. The wooden privacy screen is expected to withstand windspeeds up to 75 mph or as required by County and/or City building codes as applicable, whichever value is greater.

Q7. Will the county accept a CBC or a Marine Specialty License for this project?

R7. Manatee County will accept a Certified Building Contractor or Marine Specialty License for this project under the same requirements as noted in the bid specification for General Contractor.

Q8. What additional details are you willing to provide, if any, beyond what is stated in the bid documents concerning how you will identify the winning bid ?

R8. All the requirements are detailed in the bid documents.

Q9. Was this bid posted to the nationwide free bid notification website at www.mygovwatch.com/free?

R9. No.

Q10. Other than your own website, where was this bid posted?

R10. The bid was posted to Bid Sync at: <https://prod.bidsync.com/> and on Manatee County Web site at: https://public.mymanatee.org/rfp_post/controller

NOTE: Items that are ~~struck through~~ are deleted. Items that are underlined have been added or changed. All other terms and conditions remain as stated in the ITQ.

END OF ADDENDUM

INSTRUCTIONS:

Receipt of this addendum must be acknowledged as instructed in the solicitation document. Failure to acknowledge receipt of this Addendum may result in the response being deemed non-responsive.

AUTHORIZED FOR RELEASE