

MANATEE COUNTY GOVERNMENT NOTICE OF CANCELLATION AND INTENT TO RE-SOLICIT

SUBJECT	Replace Motor Control Panels for Effluent Storage Lake Pumpback Stations, at the Southwest Water Reclamation Facility	DATE POSTED	MC AT 9/27 DS	cc NA BCC NA
SOLICITATION NO.	RFO No. 18-R068599OV	PROCUREMENT REPRESENTATIVE	Olga Valcich, Ext. 3055	
AUTHORIZED BY	Chris Daley, Procurement Manager	SIGNATURE / DATE	CESA 9/20/18	

NOTICE OF CANCELLATION

Notice is hereby given that Manatee County Government has rejected the offer submitted and cancels RFO 18-R068599OV. Notice is also given that the County intends to re-solicit for these services.

ENABLING/REGULATING AUTHORITY

Federal/State law(s), administrative ruling(s), Manatee County Comp Plan/Land Development Code, ordinances, resolutions, policy.

Pursuant to the RFO 18-R068599OV, Section A.13, Reserved Rights, the County is publishing notice of its decision to reject all offers received in response to the above-referenced Request for Offer (RFO) and cancel the RFO. Pursuant to F.S. 119.071(1)(b)3, if an agency rejects all replies submitted in response to a competitive solicitation and the agency concurrently provides notice of its intent to reissue the competitive solicitation, the rejected replies remain exempt from s. 119.07(1) and s. 24(a), Art. I of the State Constitution until such time as the agency provides notice of an intended decision concerning the reissued competitive solicitation or until the agency withdraws the reissued competitive solicitation.

BACKGROUND/DISCUSSION

SOLICITATION DETAILS:

This Request for Offer was advertised on June 18, 2018 on the Manatee County website, in addition to the solicitation being emailed to various firms. One (1) offer was received from CEC Controls Company, Inc., Bradenton, FL.

SCOPE OF WORK DESCRIPTION:

The project consisted of the contractor to provide a turn-key operation for the design, shop drawings, working drawings, equiment, labor, materials, supplies, licensing, transportation, and other components necessary to provide replacement of two (2) Motor Control Panels for the Effluent Storage Lake Pumpback Stations at the Southwest Water Reclamation facility, including new UL listed VFD (Vertical Frequency Drive) Pump Control Panels.