



1112 Manatee Avenue West  
Bradenton, FL 34205  
[purchasing@mymanatee.org](mailto:purchasing@mymanatee.org)

## Solicitation Addendum

---

Addendum No.:	2
Solicitation No.:	IFBC No. 23-R081656JH
Solicitation Title:	Manatee County Juvenile Detention Facility Roof Replacement
Addendum Date:	May 11, 2023
Procurement Contact:	Jeb Hayter

**IFBC No. 23-R081656JH is amended as set forth herein. Responses to questions posed by prospective bidders are provided below. This Addendum is hereby incorporated in and made a part of IFBC No. 23-R081656JH.**

**The deadline to submit all inquiries concerning interpretation, clarification or additional information pertaining to this IFBC was May 04, 2023.**

### QUESTIONS AND RESPONSES:

- Q1. There are 4 mechanical split units that are not code complaint. Is required mechanical work to be included in all bidders' base bids?**
- R1. No. Code compliance of mechanical units will be addressed by others.
- Q2. There is lightning protection existing on this roof. Are bidders to include removal and reinstalment in the base bid?**
- R2. Yes, any existing lightning protection equipment that requires removal to allow for roof replacement shall be removed and re-installed by the contractor to match existing conditions.
- Q3. Fencing with barbed wire extends over on to the shingle roofs in some areas. How is this going to be addressed? Fencing will need to be removed and reinstalled by others or we must be allowed access to the internal portion of the fenced in area in order to install roofing properly?**
- R3. If said areas cannot be worked due to existing barbed wire, County staff will have the fencing temporarily removed to allow work.

**Q4. What type of security measures will need to be adhered to by crew members? daily inventory, check in and check out, etc.?**

R4. Initial background clearance will be required for all personnel for facility entry, but no daily inventory will be required. Sheriff's office staff will perform daily grounds inspections for contraband, so daily cleanup will be imperative.

**Q5. Will direct purchase order be used for this project?**

R5. A two (2) party Construction Agreement will be executed and accompanied by a purchase order.

**Q6. Is the use of minority or disadvantaged business enterprises required?**

R6. This is not a requirement for this solicitation.

**NOTE:**

Deleted items will be ~~struck through~~, added or modified items will be underlined. All other terms and conditions remain as stated in the IFBC.

**INSTRUCTIONS:**

Receipt of this Addendum must be acknowledged as instructed in the solicitation document. Failure to acknowledge receipt of this Addendum may result in the response being deemed non-responsive.

**END OF ADDENDUM**

AUTHORIZED FOR RELEASE