



1112 Manatee Avenue West  
Bradenton, FL 34205  
[purchasing@mymanatee.org](mailto:purchasing@mymanatee.org)

## Solicitation Addendum

---

Addendum No.: 3  
Solicitation No.: 25-TA005763JH  
Project No.: 6093170  
Solicitation Title: SR64 (Manatee Avenue) Water Main Intracoastal Crossing  
Addendum Date: March 21, 2025  
Procurement Contact: Jeb Hayter, Procurement Agent III

**IFBC No. 25-TA005763JH is amended as set forth herein. Responses to questions posed by prospective bidders are provided below. This Addendum is hereby incorporated in and made a part of IFBC No. 25-TA005763JH.**

**The deadline to submit all inquiries concerning interpretation, clarification or additional information pertaining to this IFBC was February 20, 2025.**

### **REPLACE:**

#### **SECTION B, BID FORMS, APPENDIX M, BID PRICING FORM (REVISED FILLABLE)**

Replace Appendix M, Bid Pricing Form (Revised Fillable) with Appendix M, Bid Pricing Form (Revision 2 Fillable) hereby incorporated into this IFBC and available for download as a separate attachment.

### **REPLACE:**

#### **SECTION B, BID FORMS, APPENDIX M, BID PRICING FORM (REVISED)**

Replace Appendix M, Bid Pricing Form (Revised) with Appendix M, Bid Pricing Form (Revision 2) issued with and attached to Addendum 3, hereby incorporated into this IFBC.

## **QUESTIONS AND RESPONSES:**

**Q1. I have a question regarding Addendum 2. I sent the information you provided for the Pressure Transmitter to Kobold, and they came back saying they can't supply anything for use on Potable water. How would the County like to proceed?**

R1. Item 25, pressure monitor has been removed from Appendix M, Bid Pricing Form. A Revised Appendix M, Bid Pricing form will be issued with this Addendum 3 and available for download as a separate attachment.

### **NOTE:**

Deleted items will be ~~struck through~~, added or modified items will be underlined. All other terms and conditions remain as stated in the IFBC.

### **INSTRUCTIONS:**

Receipt of this Addendum must be acknowledged as instructed in the solicitation document. Failure to acknowledge receipt of this Addendum may result in the response being deemed non-responsive.

### **END OF ADDENDUM**

AUTHORIZED FOR RELEASE

APPENDIX M, BID PRICING FORM (REVISION 2)

IFBC NO. 25-TA005763JH SR64 (MANATEE AVENUE) WATER MAIN INTRACOASTAL CROSSING

Bidders must provide prices for each available line item on each tab for their bid to be considered responsive

\*To be considered responsive, it is the sole responsibility of the bidder to correctly calculate and manually enter all sub-total, contingency, and total bid price fields\*

| ITEM                             | DESCRIPTION   | QUANTITY |               | BID A 410 CALENDAR DAYS |                   | BID B 470 CALENDAR DAYS |                   |
|----------------------------------|---|----------|---------------|-------------------------|-------------------|-------------------------|-------------------|
|                                  |   |          |               | UNIT PRICE              | TOTAL PRICE       | UNIT PRICE              | TOTAL PRICE       |
| <b>I. MISCELLANEOUS</b>          |   |          |               |                         |                   |                         |                   |
| 1                                | Mobilization (10%)  | 1        | LS            |                         | \$0.00            |                         | \$0.00            |
| 2                                | Maintenance of Traffic  | 1        | LS            |                         | \$0.00            |                         | \$0.00            |
| 3                                | Maintenance of Drill & Temporary Culverts for Laydown Pipe        | 1        | LS            |                         | \$0.00            |                         | \$0.00            |
| 4                                | Erosion and Sediment Control                                      | 1        | LS            |                         | \$0.00            |                         | \$0.00            |
| 5                                | Clearing and Grubbing   | 1        | LS            |                         | \$0.00            |                         | \$0.00            |
| 6                                | Preconstruction Video   | 1        | LS            |                         | \$0.00            |                         | \$0.00            |
| 7                                | Project Signs   | 1        | LS            |                         | \$0.00            |                         | \$0.00            |
| 8                                | Record Drawings   | 1        | LS            |                         | \$0.00            |                         | \$0.00            |
| 9                                | Pipeline Testing and Chlorine Injection                           | 1        | LS            |                         | \$0.00            |                         | \$0.00            |
| <b>MISCELLANEOUS SUBTOTAL</b>    |   |          |               |                         |                   |                         |                   |
| <b>II. PROPOSED IMPROVEMENTS</b> |   |          |               |                         |                   |                         |                   |
| 10                               | 20" HDPE DR 9 Water Main (HDD)                                    | 3840     | LF            |                         | \$0.00            |                         | \$0.00            |
| 11                               | 30" Steel Casing and 16" DIP Class 350 Water Main (Jack and Bore) | 50       | LF            |                         | \$0.00            |                         | \$0.00            |
| 12                               | 30" Steel Casing and 16" DIP Class 350 Water Main (Open Cut)      | 40       | LF            |                         | \$0.00            |                         | \$0.00            |
| 13                               | 16" DIP Class 350 Water Main (Open Cut)                           | 2600     | LF            |                         | \$0.00            |                         | \$0.00            |
| 14                               | 16" DI Fitting - 90 Deg. Bend, MJ                                 | 2        | EA            |                         | \$0.00            |                         | \$0.00            |
| 15                               | 16" DI Fitting - 45 Deg. Bend, MJ                                 | 18       | EA            |                         | \$0.00            |                         | \$0.00            |
| 16                               | 16" DI Fitting - Tee, MJ  | 2        | EA            |                         | \$0.00            |                         | \$0.00            |
| 17                               | 20" DI Fitting - 11.25 Deg. Bend, MJ                              | 2        | EA            |                         | \$0.00            |                         | \$0.00            |
| 18                               | 20" X 16" DI Fitting - Reducer, MJ                                | 2        | EA            |                         | \$0.00            |                         | \$0.00            |
| 19                               | 16" DI FLG Adapter  | 1        | EA            |                         | \$0.00            |                         | \$0.00            |
| 20                               | 16" MJ Sleeve   | 2        | EA            |                         | \$0.00            |                         | \$0.00            |
| 21                               | Cut and Connect to 16" Water Main                                 | 2        | EA            |                         | \$0.00            |                         | \$0.00            |
| 22                               | Water Monitoring Valve Vault                                      | 1        | EA            |                         | \$0.00            |                         | \$0.00            |
| 23                               | 16" Endress+Hauser Electromagnetic Flow Meter                     | 1        | EA            |                         | \$0.00            |                         | \$0.00            |
| 24                               | 16" Mechanical Electric Actuated Gate Valve & Actuator            | 1        | EA            |                         | \$0.00            |                         | \$0.00            |
| 25                               | <del>Pressure Monitor</del>                                       | 4        | <del>EA</del> |                         | <del>\$0.00</del> |                         | <del>\$0.00</del> |

Removed

|   |   |      |    |  |        |  |        |
|---|---|------|----|--|--------|--|--------|
| 26  | 16" DI Gate Valve, MJ                                 | 5    | EA |  | \$0.00 |  | \$0.00 |
| 27  | Above Ground Air Release Valve Assembly               | 2    | EA |  | \$0.00 |  | \$0.00 |
| 28  | 6" Fire Hydrant Assembly                              | 5    | EA |  | \$0.00 |  | \$0.00 |
| 29  | Water Service and Meter Removal and Replacement       | 1    | LS |  | \$0.00 |  | \$0.00 |
| 30  | Remove Existing 4" Inactive Force Main (Excavation)   | 20   | LF |  | \$0.00 |  | \$0.00 |
| 31  | Remove Existing 8" Inactive Water Main (Excavation)   | 10   | LF |  | \$0.00 |  | \$0.00 |
| 32  | Remove Existing 16" Water Main (Excavation)           | 3030 | LF |  | \$0.00 |  | \$0.00 |
| 33  | Remove Existing 16" Water Main (On Bridge Deck)       | 1550 | LF |  | \$0.00 |  | \$0.00 |
| 34  | Grout-fill and Abandon Existing 16" Water Main        | 5    | CY |  | \$0.00 |  | \$0.00 |
| 35  | Grout-fill and Abandon Existing Water Service Line    | 1    | CY |  | \$0.00 |  | \$0.00 |
| 36  | Full Road Restoration                                 | 94   | SY |  | \$0.00 |  | \$0.00 |
| 37  | Mill and Resurface                                    | 230  | SY |  | \$0.00 |  | \$0.00 |
| 38  | Sidewalk Restoration                                  | 85   | SY |  | \$0.00 |  | \$0.00 |
| 39  | FDOT Bank Run Shell Restoration                       | 1670 | SY |  | \$0.00 |  | \$0.00 |
| 40  | Sodding   | 3840 | SY |  | \$0.00 |  | \$0.00 |
| 41  | Tree and Shrub Removal                                | 1    | LS |  | \$0.00 |  | \$0.00 |
| 42  | Wetland Restoration                                   | 1    | LS |  | \$0.00 |  | \$0.00 |
| 43  | Bollards  | 20   | EA |  | \$0.00 |  | \$0.00 |
| 44  | Wooden Bollards                                       | 13   | EA |  | \$0.00 |  | \$0.00 |
| 45  | 20" DIP Class 250 Water Main (Open Cut)               | 6    | LF |  | \$0.00 |  | \$0.00 |
| <b>PROPOSED IMPROVEMENTS SUBTOTAL</b>                       |   |      |    |  |        |  |        |
| <b>BASE BID CONSTRUCTION TOTAL WITHOUT CONTINGENCY</b>      |   |      |    |  |        |  |        |
| 46  | Contract Contingency (Used only with County approval) | 10%  |    |  |        |  |        |
| <b>TOTAL BASE BID (SUBTOTAL PRICE PLUS THE CONTINGENCY)</b> |   |      |    |  |        |  |        |
| Bidders name _____  |   |      |    |  |        |  |        |
| Bidders Signature _____                                     |   |      |    |  |        |  |        |