



1112 Manatee Ave. West
Bradenton, FL 34205
purchasing@mymanatee.org

Solicitation Addendum

Addendum No.:	2
Solicitation No.:	20-R074345SAM
Solicitation Title:	Lena Road Landfill Stormwater System Revisions
Addendum Date:	June 12, 2020
Procurement Contact:	Sherri Meier

IFB No. 20-R074345SAM is amended as set forth herein. Responses to questions posed by prospective bidders are provided below. This addendum is hereby incorporated in and made a part of IFB No. 20-R074345SAM.

QUESTIONS AND RESPONSES:

Q1. We have been informed AASHTO No. 3 stone is not available. Would a No. 4 or No. 57 stone be acceptable for use on this project?

R1. AASHTO #3 is a gradation of gravel ranging from ½" (less than 5%) to 2.5". Provided that less than 5% of the gravel is smaller than ½" and nothing larger than 2.5", and the gravel meets the other specifications, it will be deemed to meet project specifications. #4 and #57 stone would be too small.

Q2. We have been informed 902-4 Underdrain Sand Type V is no longer available or being processed. Only 902-4 Type I-IV Underdrain Sand is available. Will this sand be acceptable for use on this project?

R2. Type I-IV underdrain sand will be acceptable.

NOTE: Items that are ~~struck through~~ are deleted. Items that are underlined have been added or changed. All other terms and conditions remain as stated in the IFB.

END OF ADDENDUM

INSTRUCTIONS:

Receipt of this addendum must be acknowledged as instructed in the solicitation document. Failure to acknowledge receipt of this Addendum may result in the response being deemed non-responsive.

AUTHORIZED FOR RELEASE