



1112 Manatee Ave. West
Bradenton, FL 34205
purchasing@mymanatee.org

Solicitation Addendum

| | |
|----------------------|--|
| Addendum No.: | 2 |
| Solicitation No.: | 19-TA003135BB |
| Solicitation Title: | Gravity Sewer Replacement – Port Manatee |
| Addendum Date: | October 11, 2019 |
| Procurement Contact: | Brooke Baker |

IFBC No. 19-TA003135BB is amended as set forth herein. Responses to questions posed by prospective bidders are provided below. This addendum is hereby incorporated in and made a part of IFBC No. 19-TA003135BB.

ADD:

ADVERTISEMENT, SOLICITATION INFORMATION CONFERENCE

An additional non-mandatory Site Visit will be held at 9:30 A.M. on October 16, 2019 at Port Manatee, 1705 Piney Point Road, Palmetto, FL 34221. All attendees must meet at the Port Manatee Main Gate Customer Service Window to be escorted into the project site. A state-issued driver's license or identity card is required to obtain temporary access into the Port.

ADD:

SECTION A, INFORMATION FOR BIDDERS, A.02, SOLICITATION INFORMATION CONFERENCE

An additional non-mandatory Site Visit will be held at 9:30 A.M. on October 16, 2019 at Port Manatee, 1705 Piney Point Road, Palmetto, FL 34221. All attendees must meet at the Port Manatee Main Gate Customer Service Window to be escorted into the project site. A state-issued driver's license or identity card is required to obtain temporary access into the Port.

CHANGE TO:

ADVERTISEMENT DATE, TIME AND PLACE DUE

The Due Date and Time for submission of Bids in response to this IFBC is October 29, 2019 at 3:00 P.M. ET. Bids must be delivered to the following location: Manatee County Administration Building, 1112 Manatee Ave. W., Suite 803, Bradenton, FL 34205 prior to the Due Date and Time.

CHANGE TO:

ADVERTISEMENT, DEADLINE FOR QUESTIONS AND CLARIFICATION REQUESTS

The deadline to submit all questions, inquiries, or requests concerning interpretation, clarification or additional information pertaining to this Invitation for Bid Construction to the Manatee County Procurement Division is October 20, 2019. Questions and inquiries should be submitted via email to the Designated Procurement Contact shown below.

CHANGE TO:**SECTION A, INFORMATION FOR BIDDERS, A.01, BID DUE DATE, FIRST PARAGRAPH**

The Due Date and Time for submission of Bids in response to this Invitation for Bid (IFBC) is October 29, 2019 at 3:00 P.M. ET. Bids must be delivered to the following location: Manatee County Administration Building, 1112 Manatee Ave. W., Suite 803, Bradenton, FL 34205 and time stamped by a Procurement representative prior to the Due Date and Time.

CHANGE TO:**SECTION A, INFORMATION FOR BIDDERS, A.51, SOLICITATION SCHEDULE**

| Scheduled Item | Scheduled Date |
|---|--------------------------------------|
| Non-Mandatory Information Conference and Non-Mandatory Site Visit | September 26, 2019 |
| <u>Additional Non-Mandatory Site Visit</u> | <u>October 16, 2019</u> |
| Question and Clarification Deadline | <u>October 20, 2019</u> |
| Final Addendum Posted | <u>October 22, 2019</u> |
| Bid Response Due Date and Time | <u>October 29, 2019, 3:00 PM, ET</u> |
| Due Diligence Review Completed | <u>November 5, 2019</u> |
| Projected Award | November 2019 |

QUESTIONS AND RESPONSES:**Q1. What is the engineer's estimated opinion of cost?**

R1. The engineer's estimated opinion of cost is \$179,780.70.

Q2. Is there any geotechnical data available for the area? If not, should we assume that the excavated soil will be suitable for backfill, or should we plan to haul excavated material off-site and backfill with clean soil?

R2. There is not any geotechnical data available; however, it can be assumed that excavated soil can be used as backfill.

Q3. What is the schedule of work hours?

R3. The schedule of work hours is Monday through Friday from 7:00 A.M. to 7:00 P.M.

Q4. Are weekend work hours an option if necessary?

R4. Yes, but would need to be coordinated with the Port.

Q5. What peak flow should be used when sizing the bypass pump?

R5. The estimated peak flow is 50 gpm.

Q6. Is it required that both the primary and secondary bypass pumps be sound attenuated, or can the secondary bypass pump be an open type?

R6. Yes, Section 02720, 2.01(A)(2) requires both pumps to be sound attenuated.

Q7. Where is the water generated during dewatering anticipated to be discharged to? Is there a nearby stormwater inlet that it can be discharged to?

R7. The Port is a known contaminated area. Bid Item #5 includes Environmental Coordination, as such the County will provide an environmental subcontractor to test and handle all contaminated water. It shall be the Contractors responsibility to coordinate said activities with the environmental subcontractor. If the environmental subcontractor determines there are no contaminates in the groundwater, the Contractor can either dewater into the County's sanitary sewer system or an onsite stormwater system.

Q8. The plans call for rehabilitation of manholes with Raven liner. During the site visit the upstream manhole appeared to have been lined and the lining appeared to be in good condition. If this is the case, would lining still be required?

R8. Yes, manhole rehabilitation will still be required.

Q9. Has the downstream manhole been lined similarly to the upstream manhole?

R9. See response to Question 8.

Q10. Will the Contractor be required to obtain testing results for compaction, or will this be completed by others?

R10. The County will provide a testing company; however, it shall be the Contractor's responsibility to coordinate and schedule all test with the testing company.

Q11. What are the elevations for the two manholes to be lined?

R11. The elevations of the manhole are shown in the profile of Sheet C-1.

NOTE: Items that are ~~struck through~~ are deleted. Items that are underlined have been added or changed. All other terms and conditions remain as stated in the IFBC.

End of Addendum

INSTRUCTIONS:

Receipt of this addendum must be acknowledged as instructed in the solicitation document. Failure to acknowledge receipt of this Addendum may result in the response being deemed non-responsive.

AUTHORIZED FOR RELEASE Chris Daley