



1112 Manatee Avenue West  
Bradenton, FL 34205  
[purchasing@mymanatee.org](mailto:purchasing@mymanatee.org)

## Solicitation Addendum

---

Addendum No.: 3  
Solicitation No.: 23-R081797LP  
Solicitation Title: Blackstone Park Chainlink Fence Backstops  
Addendum Date: June 21, 2023  
Procurement Contact: Leslie Peer

**IFBC 23-R081797LP is amended as set forth herein. Responses to questions posed by prospective bidders are provided below. This Addendum is hereby incorporated in and made a part of IFBC 23-R081797LP.**

**The deadline to submit all inquiries concerning interpretation, clarification or additional information pertaining to this IFBC is June 23, 2023.**

### QUESTIONS AND RESPONSES:

**Q1. After reviewing the addendum 2 responses with my supplier we noticed your response to question #9 in regards to the 6-5/8" posts being (XX strong schedule 120), per our supplier / manufacture the sch120 posts can ONLY be galvanized, due to the thickness of the pipe the ovens will not heat the product up enough to adhere the powder coating. The thickest post gauge our supplier can run in black vinyl is the 6-5/8" posts in (X strong sch80) .Please confirm if the 6-5/8" posts can be (Xstrong sch 80) in lieu of (XX strong sch 120) to allow proper black vinyl coating adhering process. >**

**R1. The post sizes are based on the spacing of the posts. For the spacing currently shown, the thickness indicated on our drawings is required. We will allow for alternative coating options that meet or exceed the specifications of powder coating on these posts.**

### NOTE:

Deleted items will be ~~struck through~~, added or modified items will be underlined. All other terms and conditions remain as stated in the IFBC.

### INSTRUCTIONS:

Receipt of this Addendum must be acknowledged as instructed in the solicitation document. Failure to acknowledge receipt of this Addendum may result in the response being deemed non-responsive.

**END OF ADDENDUM**

AUTHORIZED FOR RELEASE