



# MANATEE COUNTY FLORIDA

August 18, 2011

TO: All Interested Bidders

SUBJECT: Invitation for Bid # 11-2127-DS  
2011 Lift Station Rehab Group 3

## ADDENDUM # 1

Bidders are hereby notified that this Addendum shall be acknowledged on pages 00300-1 of the Bid Form and made a part of the above named bidding and contract documents. Bids submitted without acknowledgement of the Addendum will be considered incomplete.

The following items are issued to add to, modify, and clarify the bid and contract documents. These items shall have the same force and effect as the original bidding and contract documents, and cost involved shall be included in the bid prices. Bids to be submitted on the specified bid date, shall conform to the additions and revisions listed herein.

The deadline for clarification of questions is August 19, 2011 at 2:00 pm. This deadline has been established to maintain fair treatment of all potential bidders, while maintaining the expedited nature of the Economic Stimulus that the contracting of this work may achieve. Questions received after this date and time shall not be considered.

Attachment: Letter of clarification from Mr. Shea Shoun, Project Engineer, Manatee County Government dated August 9, 2011 (2 pages)

Bidders: By way of this Addendum # 1 please replace all bid forms for Bids "A" and Bid "B" for this solicitation with the supplied Addendum # 1 version attached. (28 pages)

A change has been initiated on the following pages of the IFB plans. By way of this Addendum # 1 all interested bidders will need to remove the following pages, Sheet 7 of 12, Sheet 8 of 12 and replace with the revised sheet 7 of 12 and Sheet 8 of 12 dated 7/22/2011 provided in the Addendum # 1.  
(2 pages)

Finance Management Department  
Mailing Address: Purchasing Division: 1112 Manatee Avenue West, Suite 803, Bradenton, FL 34205  
PHONE: 941-749-3045 \* FAX: 941-749-3034  
[www.mymanatee.org](http://www.mymanatee.org)

Page 2

August 18, 2011

All Interested Bidders

**Invitation for Bid # 11-2127-DS**

**2011 Lift Station Rehab Group 3**

**Question posed regarding the requirement of the Installation Floater required—**  
Contractors can locate the information on page 0030-6 section C.14 (f) header Installation Floater which states:

**If this contract does not include** construction of or additions to above ground building or structures, **but does involve** the installation of machinery or equipment, contractor shall provide an "Installation Floater" with the minimum amount of insurance to be 100% of the value of such addition(s), building(s), or structure(s).

**Performance and Payment Bonds.** See C.15 page 00030-7.

**Warranty and Guarantee Provisions:** See C.07 page 00030-3 for the full scope of warranty for this IFB.


A public records request was made for the engineers estimate for this project.

**Attached is a copy of the engineer's estimate letter (1) page dated July 22, 2011. It is important to note that Manatee County Government is currently receiving competitive bids which are up to 50% lower than engineer's estimate. (1 page)**

If you have submitted a bid prior to receiving this addendum, you may request in writing that your original, sealed bid be returned to your firm. All sealed bids received will be opened on the date stated.

**The deadline for submitting sealed Bids at the Manatee County Purchasing Division, 1112 Manatee Avenue West, Suite 803, Bradenton, Florida 34205 is until 2:00 pm on September 7, 2011.**

Sincerely,



R. C. "Rob" Cuthbert, CPM, CPPO  
Purchasing Official

/ds

Attachment (33 pages)

Finance Management Department  
Mailing Address: Purchasing Division: 1112 Manatee Avenue West, Suite 803, Bradenton, FL 34205  
PHONE: 941-749-3045 \* FAX: 941-749-3034  
[www.mymanatee.org](http://www.mymanatee.org)



MANATEE COUNTY  
FLORIDA

Date: July 22, 2011  
To: All Bidders  
Subject: FY 2011 Lift Station Rehabilitation - Group 3  
Project No.: 402.0019707

The total "construction cost estimate" for the seven (7) aforementioned FY 2011 Lift Station Rehabilitation - Group 3 project is \$525,513, five hundred twenty-five thousand five hundred and thirteen dollars.

This construction cost estimate was determined on July 22, 2011. The construction cost estimate is based on the original specifications and drawings issued. Changes to the specifications subsequent to the original documents by addenda to this bid may not be accounted in this construction cost estimate.

Sincerely,

J. Shea Shoun, P.E.  
Project Engineer

Public Works Department/Engineering Services  
Mailing Address: P. O. Box 1000, Bradenton, FL 34206-1000  
Street Address: 1022 26<sup>th</sup> Ave. E., Bradenton, FL 34208  
WEB: [www.mymanatee.org](http://www.mymanatee.org) \* PHONE: 941.708-7450 \* FAX: 941.708-7431

# MEMORANDUM



Public Works Department  
1022 26<sup>th</sup> Avenue East  
Bradenton, FL 34208

MANATEE COUNTY  
FLORIDA

Phone: 941.708-7450  
Fax: 941.708-7431  
[www.mymanatee.org](http://www.mymanatee.org)

To: Walter Sowa, Project Manager

From: J. Shea Shoun, PE

Date: August 9, 2011

Subject: IFB# 11-2127-DS---2011 Lift Station Rehab Group 3 - Response to Bidders' Questions

A handwritten signature in black ink, appearing to read "J. Shea Shoun".

Responses to bidder questions regarding this project are as follows:

## Questions received from TLC Diversified, Inc - July 21, 2011

1. **Question:** The bid form for Country Palms (RTU337) calls for items that I do not see on the plans.

Bid item #14 Quick Coupler Adapter & Bid Item #16 Plug Valve are not shown on the drawings. Sheet 4 does not call for a new plug valve and there is a note that says, "Quick Connect to Remain."

**Response:** Correct. The Bid form has been revised.

2. **Question:** The bid form for Palm Aire 5 (RTU459) calls for an item that I do not see on the plans.

Bid Item #17 "PVC Pipe Cross/Tee to Plug Valve" - this work is not shown on the drawings. Shouldn't this item not exist?

**Response:** Correct. The Bid form has been revised.

3. **Question:** The bid form for Legacy 10 (RTU660) Part A is followed by Legacy 13 (RTU662) Part B. I believe the wording is incorrect for the title of the Legacy 13 bid form that comes after Legacy 10.

**Response:** The Bid forms have been revised.

## Questions received from Pro-Rehab Contracting, Inc. - Aug 2, 2011

1. **Question:** Can you tell me if there will be Cementitious and/or epoxy coating on any or all of the lift stations mentioned in this project?

**Response:** Non-shrink cementitious grout shall be used for setting wall castings, sleeves, leveling pump bases, doweling anchors into existing concrete and elsewhere as shown on the construction drawings. Exterior coatings for ductile iron pipe and fittings used in wastewater systems shall be either an asphaltic coating per AWWA C151 or a factory-applied epoxy coating per AWWA C550. All valves shall have a factory applied, holiday free, fusion bonded epoxy coating on the interior and exterior.

Questions received from CEC Motor & Utility Services, LLC - Aug 8, 2011

1. **Question:** We are bidding this project and had a question. Palm Aire 5 has a triplex shown on the drawings but you have quantity 2 on your bid form. Can you advise if we are bidding three or two pump packages?

**Response:** The lift station is a triplex, so bid accordingly for three pump packages. Addendum #1 includes revised plans and bid forms to address the discrepancies between them.

---

**BID FORM**  
(Submit in Triplicate)

**BID "A"**

**IFB# 11-2127-DS ----- 2011 Lift Station Rehab Group 3**

PROJECT SITE: Country Palms, (RTU337)  
 PROJECT NUMBER: 402.0019707-5001332  
 SECTION / TOWNSHIP / RANGE: S32/T35S/R18E  
 PROJECT DESCRIPTION: Rehab wetwell & valve vault piping for lift station  
 PROJECT SITE DIMENSIONS: All work within LS site

**BID "A" BASED ON COMPLETION OF 300 Calendar Days**  
**ADDENDUM # 1**

ITEM NO.	DESCRIPTION	UNITS	QTY.	UNIT PRICE (\$)	EXTENDED PRICE (\$)
1	Wetwell Cleaning	SF	311	\$	\$
2	DR-11 HDPE Piping	LF	35	\$	\$
3	HDPE Flange Adapters	EA	4	\$	\$
4	HDPE Fittings	LB	8	\$	\$
5	BPIU 4" Base Ells	EA	2	\$	\$
6	Base Ell Mounting Plate	EA	2	\$	\$
7	S.S. Pipe Bracing	EA	2	\$	\$
8	<i>Item removed (Addendum # 1)</i>				
9	Resilient (Link) Seals w/Carrier Pipe & Liner Repair	EA	4	\$	\$
10	<i>Item removed (Addendum # 1)</i>				
11	Flanged Gate Valve	EA	2	\$	\$
12	Flanged Swing Check Valve	EA	2	\$	\$
13	<i>Intentionally Left Blank</i>				
14	<i>Item removed (Addendum # 1)</i>				
15	S.S. Valve Supports	EA	3	\$	\$
16	<i>Intentionally Left Blank (Addendum # 1)</i>				
17	<i>Intentionally Left Blank (Addendum # 1)</i>				

BIDDER (FIRM NAME) \_\_\_\_\_

BID "A"

AUTHORIZED SIGNATURE: \_\_\_\_\_

**BID FORM**  
(Submit in Triplicate)

**BID "A"**

**IFB# 11-2127-DS ----- 2011 Lift Station Rehab Group 3**

PROJECT SITE: Country Palms, (RTU337)  
 PROJECT NUMBER: 402.0019707-5001332  
 SECTION / TOWNSHIP / RANGE: S32/T35S/R18E  
 PROJECT DESCRIPTION: Rehab wetwell & valve vault piping for lift station  
 PROJECT SITE DIMENSIONS: All work within LS site

**BID "A" BASED ON COMPLETION OF 300 Calendar Days  
ADDENDUM # 1**

ITEM NO.	DESCRIPTION	UNITS	QTY.	UNIT PRICE (\$)	EXTENDED PRICE (\$)
18	Influent Line Plug	EA	1	\$	\$
19	By-Pass Pumping	DAY	10	\$	\$
20	Repair Ex. Liner (excl. Bid Items 9 & 10) (Addendum # 1)	SF	4	\$	\$
21	<i>Intentionally Left Blank</i>				
22	<i>Intentionally Left Blank</i>				
23	<i>Intentionally Left Blank</i>				
24	<i>Intentionally Left Blank</i>				
25	<i>Intentionally Left Blank</i>				
26	<i>Intentionally Left Blank</i>				
	<b>SubTotal Construction Cost</b>				\$
27	Mobilization				\$
28	Miscellaneous Work , Clean Up & Record Drawings				\$
29	<b>Discretionary Work (Addendum # 1)</b>				<b>\$3,000.00</b>
	<b>TOTAL BID PRICE "A"</b> Based on Completion Time of 300 Calendar Days (ADDENDUM # 1)				\$

BIDDER (FIRM NAME) \_\_\_\_\_

BID "A"

AUTHORIZED SIGNATURE: \_\_\_\_\_

**BID FORM**  
(Submit in Triplicate)

**BID "B"**

**IFB# 11-2127-DS ----- 2011 Lift Station Rehab Group 3**

**PROJECT SITE:** Country Palms, (RTU337)  
**PROJECT NUMBER:** 402.0019707-5001332  
**SECTION / TOWNSHIP / RANGE:** S32/T35S/R18E  
**PROJECT DESCRIPTION:** Rehab wetwell & valve vault piping for lift station  
**PROJECT SITE DIMENSIONS:** All work within LS site

**BID "B" BASED ON COMPLETION OF 345 Calendar Days**

**ADDENDUM # 1**

ITEM NO.	DESCRIPTION	UNITS	QTY.	UNIT PRICE (\$)	EXTENDED PRICE (\$)
1	Wetwell Cleaning	SF	311	\$	\$
2	DR-11 HDPE Piping	LF	35	\$	\$
3	HDPE Flange Adapters	EA	4	\$	\$
4	HDPE Fittings	LB	8	\$	\$
5	BPIU 4" Base Ells	EA	2	\$	\$
6	Base Ell Mounting Plate	EA	2	\$	\$
7	S.S. Pipe Bracing	EA	2	\$	\$
8	<i>Item removed (Addendum # 1)</i>				
9	Resilient (Link) Seals w/Carrier Pipe & Liner Repair	EA	4	\$	\$
10	<i>Item removed (Addendum # 1)</i>				
11	Flanged Gate Valve	EA	2	\$	\$
12	Flanged Swing Check Valve	EA	2	\$	\$
13	<i>Intentionally Left Blank</i>				
14	<i>Item removed (Addendum # 1)</i>				
15	S.S. Valve Supports	EA	3	\$	\$
16	<i>Item removed (Addendum # 1)</i>				
17	<i>Item removed (Addendum # 1)</i>				
18	Influent Line Plug	EA	1	\$	\$

BIDDER (FIRM NAME) \_\_\_\_\_

BID "B"

AUTHORIZED SIGNATURE: \_\_\_\_\_



**BID FORM**  
(Submit in Triplicate)

**BID "B"**

**IFB# 11-2127-DS ----- 2011 Lift Station Rehab Group 3**

PROJECT SITE: Country Palms, (RTU337)  
 PROJECT NUMBER: 402.0019707-5001332  
 SECTION / TOWNSHIP / RANGE: S32/T35S/R18E  
 PROJECT DESCRIPTION: Rehab wetwell & valve vault piping for lift station  
 PROJECT SITE DIMENSIONS: All work within LS site

**BID "B" BASED ON COMPLETION OF 345 Calendar Days**

**ADDENDUM # 1**

19	By-Pass Pumping	DAY	10	\$	\$
20	Repair Ex. Liner (excl. Bid Items 9 & 10) (Addendum # 1)	SF	4	\$	\$
21	<i>Intentionally Left Blank</i>				
22	<i>Intentionally Left Blank</i>				
23	<i>Intentionally Left Blank</i>				
24	<i>Intentionally Left Blank</i>				
25	<i>Intentionally Left Blank</i>				
26	<i>Intentionally Left Blank</i>				
	<b>SubTotal Construction Cost</b>				\$
27	Mobilization				\$
28	Miscellaneous Work , Clean Up & Record Drawings				\$
29	<b>Discretionary Work (Addendum # 1)</b>				\$3,000.00
	<b>TOTAL BID PRICE "B"</b> Based on Completion Time of 345 Calendar Days (ADDENDUM # 1)				\$

BIDDER (FIRM NAME) \_\_\_\_\_

AUTHORIZED SIGNATURE: \_\_\_\_\_

BID "B"

**BID FORM**  
(Submit in Triplicate)

**BID "A"**

IFB# 11-2127-DS ----- 2011 Lift Station Rehab Group 3

PROJECT SITE: PALM AIRE 5, (RTU 459)  
 PROJECT NUMBER: 402.0019707-5001333  
 SECTION / TWSHP / RANGE: S34/T35S/R18E  
 PROJECT DESCRIPTION: Rehab wetwell & valve vault piping for lift station  
 PROJECT SITE DIMENSIONS: All work within LS site

**BID "A" BASED ON COMPLETION OF 300 Calendar Days**  
**ADDENDUM # 1**

ITEM NO.	DESCRIPTION	UNITS	QTY.	UNIT PRICE (\$)	EXTENDED PRICE (\$)
1	Wetwell Cleaning	SF	1079	\$	\$
2	DR-11 HDPE Piping	LF	71	\$	\$
3	HDPE Flange Adapters (ADDENDUM # 1)	EA	6	\$	\$
4	HDPE Fittings (ADDENDUM #1)	LB	117	\$	\$
5	6" BPIU BASE EII's (ADDENDUM # 1)	EA	3	\$	\$
6	Base EII Mounting Plate ( ADDENDUM # 1)	EA	3	\$	\$
7	S.S. Pipe Bracing	EA	4	\$	\$
8	2 Inch S.S. Pump Guide Rail System (ADDENDUM #1)	LF	89	\$	\$
9	Resilient (Link) Seals w/Carrier Pipe & Liner Repair (ADDENDUM # 1)	EA	6	\$	\$
10	<i>Item removed (Addendum # 1)</i>				
11	Flanged Gate Valve	EA	4	\$	\$
12	Flanged Swing Check Valve (ADDENDUM #1)	EA	3	\$	\$
13	<i>Intentionally Left Blank</i>				
14	Quick Coupler Adapter	EA	1	\$	\$
15	S.S. Valve Supports (ADDENDUM # 1)	EA	7	\$	\$
16	<i>Intentionally Left Blank</i>				
17	<i>Item removed (Addendum # 1)</i>				

BIDDER (FIRM NAME) \_\_\_\_\_

AUTHORIZED SIGNATURE: \_\_\_\_\_

BID "A"

**BID FORM**  
(Submit in Triplicate)

**BID "A"**

IFB# 11-2127-DS ----- 2011 Lift Station Rehab Group 3

PROJECT SITE: PALM AIRE 5, (RTU 459)  
 PROJECT NUMBER: 402.0019707-5001333  
 SECTION / TWSHP / RANGE: S34/T35S/R18E  
 PROJECT DESCRIPTION: Rehab wetwell & valve vault piping for lift station  
 PROJECT SITE DIMENSIONS: All work within LS site

**BID "A" BASED ON COMPLETION OF 300 Calendar Days**

**ADDENDUM # 1**

ITEM NO.	DESCRIPTION	UNITS	QTY.	UNIT PRICE (\$)	EXTENDED PRICE (\$)
18	Influent Line Plug	EA	1	\$	\$
19	By-Pass Pumping	DAY	10	\$	\$
20	Repair Ex. Liner , (excl. Bid Items 9 & 10) (ADDENDUM # 1)	SF	74	\$	\$
21	<i>Intentionally Left Blank</i>				
22	Fill & Sod, Bahia	CF	18	\$	\$
23	<i>Intentionally Left Blank</i>				
24	<i>Intentionally Left Blank</i>				
25	6" PVC Stilling Well	LF	30	\$	\$
26	<i>Intentionally Left Blank</i>				
	<b>SubTotal Construction Cost</b>				\$
27	Mobilization				\$
28	Miscellaneous Work , Clean Up & Record Drawings				\$
29	<b>Discretionary Work (ADDENDUM # 1)</b>				<b>\$10,000.00</b>
	<b>TOTAL BID PRICE "A" Based on Completion Time of 300 Calendar Days (ADDENDUM # 1)</b>				<b>\$</b>

BIDDER (FIRM NAME) \_\_\_\_\_

AUTHORIZED SIGNATURE: \_\_\_\_\_

BID "A"

**BID FORM**  
(Submit in Triplicate)

**BID "B"**

**IFB# 11-2127-DS ----- 2011 Lift Station Rehab Group 3**

PROJECT SITE: PALM AIRE 5, (RTU 459)  
 PROJECT NUMBER: 402.0019707-5001333  
 SECTION / TOWNSHIP / RANGE: S34/T35S/R18E  
 PROJECT DESCRIPTION: Rehab wetwell & valve vault piping for lift station  
 PROJECT SITE DIMENSIONS: All work within LS site

**BID "B" BASED ON COMPLETION OF 345 Calendar Days**  
**ADDENDUM # 1**

ITEM NO.	DESCRIPTION	UNITS	QTY.	UNIT PRICE (\$)	EXTENDED PRICE (\$)
1	Wetwell Cleaning	SF	1079	\$	\$
2	DR-11 HDPE Piping	LF	71	\$	\$
3	HDPE Flange Adapters ( ADDENDUM # 1)	EA	6	\$	\$
4	HDPE Fittings (ADDENDUM # 1)	LB	117	\$	\$
5	6" BPIU Base Ells (ADDENDUM # 1)	EA	3	\$	\$
6	Base Ell Mounting Plate (ADDENDUM # 1)	EA	3	\$	\$
7	S.S. Pipe Bracing	EA	4	\$	\$
8	2 Inch S.S. Pump Guide Rail System (ADDENDUM # 1)	LF	89	\$	\$
9	Resilient (Link) Seals w/Carrier Pipe & Liner Repair (ADDENDUM # 1)	EA	6	\$	\$
10	<i>Item removed (Addendum # 1)</i>				
11	Flanged Gate Valve	EA	4	\$	\$
12	Flanged Swing Check Valve (ADDENDUM # 1)	EA	3	\$	\$
13	<i>Intentionally Left Blank</i>				
14	Quick Coupler Adapter	EA	1	\$	\$
15	S.S. Valve Supports (ADDENDUM # 1)	EA	7	\$	\$
16	<i>Intentionally Left Blank</i>				
17	<i>Item removed (Addendum # 1)</i>				

BIDDER (FIRM NAME) \_\_\_\_\_

AUTHORIZED SIGNATURE: \_\_\_\_\_

BID "B"

**BID FORM**  
(Submit in Triplicate)

**BID "B"**

**IFB# 11-2127-DS ----- 2011 Lift Station Rehab Group 3**

PROJECT SITE: PALM AIRE 5, (RTU 459)  
 PROJECT NUMBER: 402.0019707-5001333  
 SECTION / TWNSHP / RANGE: S34/T35S/R18E  
 PROJECT DESCRIPTION: Rehab wetwell & valve vault piping for lift station  
 PROJECT SITE DIMENSIONS: All work within LS site

**BID "B" BASED ON COMPLETION OF 345 Calendar Days**  
**ADDENDUM # 1**

ITEM NO.	DESCRIPTION	UNITS	QTY.	UNIT PRICE (\$)	EXTENDED PRICE (\$)
18	Influent Line Plug	EA	1	\$	\$
19	By-Pass Pumping	DAY	10	\$	\$
20	Repair Ex. Liner, (excl. Bid Items 9 & 10) (ADDENDUM # 1)	SF	74	\$	\$
21	<i>Intentionally Left Blank</i>				
22	Fill & Sod, Bahia	CF	18	\$	\$
23	<i>Intentionally Left Blank</i>				
24	<i>Intentionally Left Blank</i>				
25	6" PVC Stilling Well	LF	30	\$	\$
26	<i>Intentionally Left Blank</i>				
	<b>SubTotal Construction Cost</b>				\$
27	Mobilization				\$
28	Miscellaneous Work , Clean Up & Record Drawings				\$
29	<b>Discretionary Work (ADDENDUM # 1)</b>				<b>\$10,000.00</b>
	<b>TOTAL BID PRICE "B"</b> Based on Completion Time of 345 Calendar Days (ADDENDUM # 1)				\$

BIDDER (FIRM NAME) \_\_\_\_\_

AUTHORIZED SIGNATURE: \_\_\_\_\_

BID "B"

**BID FORM**  
(Submit in Triplicate)

**BID "A"**

**IFB# 11-2127-DS ----- 2011 Lift Station Rehab Group 3**

**PROJECT SITE:** Rosedale 2, (RTU 360)  
**PROJECT NUMBER:** 402.0019707-5001334  
**SECTION / TOWNSHIP / RANGE:** S12/T35S/R18E  
**PROJECT DESCRIPTION:** Rehab wetwell & valve vault piping for lift station  
**PROJECT SITE DIMENSIONS:** All work within LS site

**BID "A" BASED ON COMPLETION OF 300 Calendar Days**  
**ADDENDUM # 1**

ITEM NO.	DESCRIPTION	UNITS	QTY.	UNIT PRICE (\$)	EXTENDED PRICE (\$)
1	Wetwell Cleaning	SF	431	\$	\$
2	DR-11 HDPE Piping	LF	48	\$	\$
3	HDPE Flange Adapters	EA	4	\$	\$
4	HDPE Fittings	LB	8	\$	\$
5	BPIU 4" Base Ells	EA	2	\$	\$
6	Base Ell Mounting Plate	EA	2	\$	\$
7	S.S. Pipe Bracing	EA	2	\$	\$
8	2 Inch S.S. Pump Guide Rail System	LF	40	\$	\$
9	Resilient (Link) Seals w/Carrier Pipe & Liner Repair	EA	4	\$	\$
10	<i>Item removed (Addendum # 1)</i>				
11	Flanged Gate Valve	EA	3	\$	\$
12	Flanged Swing Check Valve	EA	2	\$	\$
13	<i>Intentionally Left Blank</i>				
14	<i>Item removed (Addendum # 1)</i>				
15	S.S. Valve Supports	EA	3	\$	\$
16	<i>Intentionally Left Blank</i>				

BIDDER (FIRM NAME) \_\_\_\_\_

AUTHORIZED SIGNATURE: \_\_\_\_\_

BID "A"

**BID FORM**  
(Submit in Triplicate)

**BID "A"**

**IFB# 11-2127-DS ----- 2011 Lift Station Rehab Group 3**

PROJECT SITE: Rosedale 2, (RTU 360)  
 PROJECT NUMBER: 402.0019707-5001334  
 SECTION / TWNSHP / RANGE: S12/T35S/R18E  
 PROJECT DESCRIPTION: Rehab wetwell & valve vault piping for lift station  
 PROJECT SITE DIMENSIONS: All work within LS site

**BID "A" BASED ON COMPLETION OF 300 Calendar Days**  
**ADDENDUM # 1**

ITEM NO.	DESCRIPTION	UNITS	QTY.	UNIT PRICE (\$)	EXTENDED PRICE (\$)
17	<i>Item removed (Addendum # 1)</i>				
18	Influent Line Plug	EA	1	\$	\$
19	By-Pass Pumping	DAY	10	\$	\$
20	<i>Item removed (Addendum # 1)</i>				
21	<i>Intentionally Left Blank</i>				
22	<i>Intentionally Left Blank</i>				
23	<i>Intentionally Left Blank</i>				
24	<i>Intentionally Left Blank</i>				
25	<i>Intentionally Left Blank</i>				
26	<i>Intentionally Left Blank</i>				
					\$
27	Mobilization				\$
28	Miscellaneous Work , Clean Up & Record Drawings				\$
29	<b>Discretionary Work</b>				<b>\$3,500.00</b>
	<b>TOTAL BID PRICE "A"</b> Based on Completion Time of 300 Calendar Days (ADDENDUM # 1)				\$

BIDDER (FIRM NAME) \_\_\_\_\_

AUTHORIZED SIGNATURE: \_\_\_\_\_

BID "A"

## BID FORM

(Submit in Triplicate)

BID "B"

## IFB# 11-2127-DS ----- 2011 Lift Station Rehab Group 3

PROJECT SITE: Rosedale 2, (RTU 360)  
 PROJECT NUMBER: 402.0019707-5001334  
 SECTION / TWSHP / RANGE: S12/T35S/R18E  
 PROJECT DESCRIPTION: Rehab wetwell & valve vault piping for lift station  
 PROJECT SITE DIMENSIONS: All work within LS site

BID "B" BASED ON COMPLETION OF 345 Calendar Days

## ADDENDUM # 1

ITEM NO.	DESCRIPTION	UNITS	QTY.	UNIT PRICE (\$)	EXTENDED PRICE (\$)
1	Wetwell Cleaning	SF	431	\$	\$
2	DR-11 HDPE Piping	LF	48	\$	\$
3	HDPE Flange Adapters	EA	4	\$	\$
4	HDPE Fittings	LB	8	\$	\$
5	BPIU 4" Base Ells	EA	2	\$	\$
6	Base Ell Mounting Plate	EA	2	\$	\$
7	S.S. Pipe Bracing	EA	2	\$	\$
8	2 Inch S.S. Pump Guide Rail System	LF	40	\$	\$
9	Resilient (Link) Seals w/Carrier Pipe & Liner Repair	EA	4	\$	\$
10	<i>Item removed (Addendum # 1)</i>				
11	Flanged Gate Valve	EA	3	\$	\$
12	Flanged Swing Check Valve	EA	2	\$	\$
13	<i>Intentionally Left Blank</i>				
14	<i>Item removed (Addendum # 1)</i>				
15	S.S. Valve Supports	EA	3	\$	\$
16	<i>Intentionally Left Blank</i>				

BIDDER (FIRM NAME) \_\_\_\_\_

AUTHORIZED SIGNATURE: \_\_\_\_\_

BID "B"



BID "B"

## IFB# 11-2127-DS ----- 2011 Lift Station Rehab Group 3

PROJECT SITE: Rosedale 2, (RTU 360)  
 PROJECT NUMBER: 402.0019707-5001334  
 SECTION / TWSHP / RANGE: S12/T35S/R18E  
 PROJECT DESCRIPTION: Rehab wetwell & valve vault piping for lift station  
 PROJECT SITE DIMENSIONS: All work within LS site

BID "B" BASED ON COMPLETION OF 345 Calendar Days

## ADDENDUM # 1

ITEM NO.	DESCRIPTION	UNITS	QTY.	UNIT PRICE (\$)	EXTENDED PRICE (\$)
17	<i>Item removed (Addendum # 1)</i>				
18	Influent Line Plug	EA	1	\$	\$
19	By-Pass Pumping	DAY	10	\$	\$
20	<i>Item removed (Addendum # 1)</i>				
21	<i>Intentionally Left Blank</i>				
22	<i>Intentionally Left Blank</i>				
23	<i>Intentionally Left Blank</i>				
24	<i>Intentionally Left Blank</i>				
25	<i>Intentionally Left Blank</i>				
26	<i>Intentionally Left Blank</i>				
	<b>SubTotal Construction Cost</b>				\$
27	Mobilization				\$
28	Miscellaneous Work , Clean Up & Record Drawings				\$
29	<b>Discretionary Work</b>				\$3,500.00
	<b>TOTAL BID PRICE "B"</b> Based on Completion Time of 345 Calendar Days (ADDENDUM # 1)				\$

BIDDER (FIRM NAME) \_\_\_\_\_

AUTHORIZED SIGNATURE: \_\_\_\_\_

BID "B"

**BID FORM**  
(Submit in Triplicate)

**BID "A"**

**IFB# 11-2127-DS ----- 2011 Lift Station Rehab Group 3**

**PROJECT SITE:** Summerfield Village (RTU390)  
**PROJECT NUMBER:** 402.0019707-5001335  
**SECTION / TOWNSHIP / RANGE:** S20/T35S/R19E  
**PROJECT DESCRIPTION:** Rehab wetwell & valve vault piping for lift station  
**PROJECT SITE DIMENSIONS:** All work within LS site

**BID "A" BASED ON COMPLETION OF 300 Calendar Days**

**ADDENDUM # 1**

ITEM NO.	DESCRIPTION	UNITS	QTY.	UNIT PRICE (\$)	EXTENDED PRICE (\$)
1	Wetwell Cleaning	SF	519	\$	\$
2	DR-11 HDPE Piping	LF	57	\$	\$
3	HDPE Flange Adapters	EA	4	\$	\$
4	HDPE Fittings	LB	8	\$	\$
5	BPIU 4" Base Ells	EA	2	\$	\$
6	Base Ell Mounting Plate	EA	2	\$	\$
7	S.S. Pipe Bracing	EA	3	\$	\$
8	2 Inch S.S. Pump Guide Rail System	LF	49	\$	\$
9	Resilient (Link) Seals w/Carrier Pipe & Liner Repair	EA	4	\$	\$
10	<i>Item Removed (ADDENDUM # 1)</i>				
11	Flanged Gate Valve	EA	3	\$	\$
12	Flanged Swing Check Valve	EA	2	\$	\$
13	<b>Ductile Iron Fittings (ADDENDUM # 1)</b>	LB	45	\$	\$
14	Quick Coupler Adapter	EA	1	\$	\$
15	<b>S.S. Valve Supports (ADDENDUM # 1)</b>	EA	2	\$	\$
16	<i>Intentionally Left Blank</i>				
17	<i>Item Removed (ADDENDUM # 1)</i>				

BIDDER (FIRM NAME) \_\_\_\_\_

AUTHORIZED SIGNATURE: \_\_\_\_\_

BID "A"

**BID FORM**  
(Submit in Triplicate)

**BID "A"**

**IFB# 11-2127-DS ----- 2011 Lift Station Rehab Group 3**

PROJECT SITE: Summerfield Village (RTU390)  
 PROJECT NUMBER: 402.0019707-5001335  
 SECTION / TOWNSHIP / RANGE: S20/T35S/R19E  
 PROJECT DESCRIPTION: Rehab wetwell & valve vault piping for lift station  
 PROJECT SITE DIMENSIONS: All work within LS site

**BID "A" BASED ON COMPLETION OF 300 Calendar Days**

**ADDENDUM # 1**

ITEM NO.	DESCRIPTION	UNITS	QTY.	UNIT PRICE (\$)	EXTENDED PRICE (\$)
18	Influent Line Plug	EA	1	\$	\$
19	By-Pass Pumping	DAY	10	\$	\$
20	<i>Intentionally Left Blank</i>				
21	<i>Intentionally Left Blank</i>				
22	<i>Intentionally Left Blank</i>				
23	<i>Intentionally Left Blank</i>				
24	<i>Intentionally Left Blank</i>				
25	<i>Intentionally Left Blank</i>				
26	<i>Intentionally Left Blank</i>				
	<b>SubTotal Construction Cost</b>				\$
27	Mobilization				\$
28	Miscellaneous Work , Clean Up & Record Drawings				\$
29	<b>Discretionary Work</b>				<b>\$4,000.00</b>
	<b>TOTAL BID PRICE "A"</b> Based on Completion Time of 300 Calendar Days (ADDENDUM # 1)				\$

BIDDER (FIRM NAME) \_\_\_\_\_

AUTHORIZED SIGNATURE: \_\_\_\_\_

BID "A"

**BID FORM**  
(Submit in Triplicate)

**BID "B"**

**IFB# 11-2127-DS ----- 2011 Lift Station Rehab Group 3**

**PROJECT SITE:** Summerfield Village (RTU390)  
**PROJECT NUMBER:** 402.0019707-5001335  
**SECTION / TOWNSHIP / RANGE:** S20/T35S/R19E  
**PROJECT DESCRIPTION:** Rehab wetwell & valve vault piping for lift station  
**PROJECT SITE DIMENSIONS:** All work within LS site

**BID "B" BASED ON COMPLETION OF 345 Calendar Days**

**ADDENDUM # 1**

ITEM NO.	DESCRIPTION	UNITS	QTY.	UNIT PRICE (\$)	EXTENDED PRICE (\$)
1	Wetwell Cleaning	SF	519	\$	\$
2	DR-11 HDPE Piping	LF	57	\$	\$
3	HDPE Flange Adapters	EA	4	\$	\$
4	HDPE Fittings	LB	8	\$	\$
5	BPIU 4" Base Ells	EA	2	\$	\$
6	Base Ell Mounting Plate	EA	2	\$	\$
7	S.S. Pipe Bracing	EA	3	\$	\$
8	2 Inch S.S. Pump Guide Rail System	LF	49	\$	\$
9	Resilient (Link) Seals w/Carrier Pipe & Liner Repair	EA	4	\$	\$
10	<i>Item Removed (ADDENDUM # 1)</i>				
11	Flanged Gate Valve	EA	3	\$	\$
12	Flanged Swing Check Valve	EA	2	\$	\$
13	Ductile Iron Fittings (ADDENDUM # 1)	LB	45	\$	\$
14	Quick Coupler Adapter	EA	1	\$	\$
15	S.S. Valve Supports (ADDENDUM # 1)	EA	2	\$	\$
16	<i>Intentionally Left Blank</i>				
17	<i>Item Removed (ADDENDUM # 1)</i>				

BIDDER (FIRM NAME) \_\_\_\_\_

AUTHORIZED SIGNATURE: \_\_\_\_\_

BID "B"

**BID FORM**  
(Submit in Triplicate)

**BID "B"**

**IFB# 11-2127-DS ----- 2011 Lift Station Rehab Group 3**

**PROJECT SITE:** Summerfield Village (RTU390)  
**PROJECT NUMBER:** 402.0019707-5001335  
**SECTION / TOWNSHIP / RANGE:** S20/T35S/R19E  
**PROJECT DESCRIPTION:** Rehab wetwell & valve vault piping for lift station  
**PROJECT SITE DIMENSIONS:** All work within LS site

**BID "B" BASED ON COMPLETION OF 345 Calendar Days**

**ADDENDUM # 1**

ITEM NO.	DESCRIPTION	UNITS	QTY.	UNIT PRICE (\$)	EXTENDED PRICE (\$)
18	Influent Line Plug	EA	1	\$	\$
19	By-Pass Pumping	DAY	10	\$	\$
20	<i>Intentionally Left Blank</i>				
21	<i>Intentionally Left Blank</i>				
22	<i>Intentionally Left Blank</i>				
23	<i>Intentionally Left Blank</i>				
24	<i>Intentionally Left Blank</i>				
25	<i>Intentionally Left Blank</i>				
26	<i>Intentionally Left Blank</i>				
	<b>SubTotal Construction Cost</b>				\$
27	Mobilization				\$
28	Miscellaneous Work , Clean Up & Record Drawings				\$
29	<b>Discretionary Work</b>				<b>\$4,000.00</b>
	<b>TOTAL BID PRICE "B"</b> Based on Completion Time of 345 Calendar Days (ADDENDUM # 1)				\$

BIDDER (FIRM NAME) \_\_\_\_\_

AUTHORIZED SIGNATURE: \_\_\_\_\_

BID "B"

**BID FORM**  
(Submit in Triplicate)

**BID "A"**

**IFB# 11-2127-DS ----- 2011 Lift Station Rehab Group 3**

**PROJECT SITE:** Legacy 13, (RTU662)  
**PROJECT NUMBER:** 402.0019707-5001336  
**SECTION / TOWNSHIP / RANGE:** S33/T35S/R19E  
**PROJECT DESCRIPTION:** Rehab wetwell & valve vault piping for lift station  
**PROJECT SITE DIMENSIONS:** All work within LS site

**BID "A" BASED ON COMPLETION OF 300 Calendar Days**  
**ADDENDUM # 1**

ITEM NO.	DESCRIPTION	UNITS	QTY.	UNIT PRICE (\$)	EXTENDED PRICE (\$)
1	Wetwell Cleaning	SF	505	\$	\$
2	DR-11 HDPE Piping	LF	58	\$	\$
3	HDPE Flange Adapters	EA	4	\$	\$
4	HDPE Fittings	LB	22	\$	\$
5	BPIU 4" Base Ells	EA	2	\$	\$
6	Base Ell Mounting Plate	EA	2	\$	\$
7	S.S. Pipe Bracing	EA	3	\$	\$
8	<i>Item Removed (ADDENDUM # 1)</i>				
9	<b>Resilient (Link) Seals w/Carrier Pipe &amp; Liner Repair (ADDENDUM # 1)</b>	EA	5	\$	\$
10	Remove & Replace 2" PVC Drain P-trap (regROUT) & Liner Repair	EA	1	\$	\$
11	Flanged Gate Valve	EA	3	\$	\$
12	Flanged Swing Check Valve	EA	2	\$	\$
13	<b>Ductile Iron Fittings (ADDENDUM # 1)</b>	LB	570	\$	\$
14	Quick Coupler Adapter	EA	1	\$	\$
15	S.S. Valve Supports	EA	3	\$	\$
16	Plug Valve	EA	1	\$	\$
17	PVC Pipe (C900) (cross/tee to plug valve)	LF	4	\$	\$

BIDDER (FIRM NAME) \_\_\_\_\_

AUTHORIZED SIGNATURE: \_\_\_\_\_

BID "A"

**BID FORM**  
(Submit in Triplicate)

**BID "A"**

**IFB# 11-2127-DS ----- 2011 Lift Station Rehab Group 3**

PROJECT SITE: Legacy 13, (RTU662)  
 PROJECT NUMBER: 402.0019707-5001336  
 SECTION / TOWNSHIP / RANGE: S33/T35S/R19E  
 PROJECT DESCRIPTION: Rehab wetwell & valve vault piping for lift station  
 PROJECT SITE DIMENSIONS: All work within LS site

**BID "A" BASED ON COMPLETION OF 300 Calendar Days**  
**ADDENDUM # 1**

ITEM NO.	DESCRIPTION	UNITS	QTY.	UNIT PRICE (\$)	EXTENDED PRICE (\$)
18	Influent Line Plug	EA	1	\$	\$
19	By-Pass Pumping	DAY	10	\$	\$
20	Repair Ex. Liner, (excl. Bid Items 9 & 10) (ADDENDUM # 1)	SF	24	\$	\$
21	<i>Intentionally Left Blank</i>				
22	<i>Intentionally Left Blank</i>				
23	Concrete, new valve vault floor	CY	7	\$	\$
24	Core Bore Holes & Patch Ex. Holes for Piping	EA	5	\$	\$
25	<i>Intentionally Left Blank</i>				
26	<i>Intentionally Left Blank</i>				
	<b>SubTotal Construction Cost</b>				\$
27	Mobilization				\$
28	Miscellaneous Work , Clean Up & Record Drawings				\$
29	<b>Discretionary Work (ADDENDUM # 1)</b>				<b>\$6,500.00</b>
	<b>TOTAL BID PRICE "A"</b> Based on Completion Time of 300 Calendar Days (ADDENDUM # 1)				\$

BIDDER (FIRM NAME) \_\_\_\_\_

AUTHORIZED SIGNATURE: \_\_\_\_\_

BID "A"

**BID FORM**  
(Submit in Triplicate)

**BID "B"**

**IFB# 11-2127-DS ----- 2011 Lift Station Rehab Group 3**

PROJECT SITE: Legacy 13, (RTU662)  
 PROJECT NUMBER: 402.0019707-5001336  
 SECTION / TOWNSHIP / RANGE: S33/T35S/R19E  
 PROJECT DESCRIPTION: Rehab wetwell & valve vault piping for lift station  
 PROJECT SITE DIMENSIONS: All work within LS site

**BID "B" BASED ON COMPLETION OF 345 Calendar Days**

**ADDENDUM # 1**

ITEM NO.	DESCRIPTION	UNITS	QTY.	UNIT PRICE (\$)	EXTENDED PRICE (\$)
1	Wetwell Cleaning	SF	505	\$	\$
2	DR-11 HDPE Piping	LF	58	\$	\$
3	HDPE Flange Adapters	EA	4	\$	\$
4	HDPE Fittings	LB	22	\$	\$
5	BPIU 4" Base Ells	EA	2	\$	\$
6	Base Ell Mounting Plate	EA	2	\$	\$
7	S.S. Pipe Bracing	EA	3	\$	\$
8	<i>Item Removed (ADDENDUM # 1)</i>				
9	<b>Resilient (Link) Seals w/Carrier Pipe &amp; Liner Repair (ADDENDUM # 1)</b>	EA	5	\$	\$
10	Remove & Replace 2" PVC Drain P-trap (regROUT) & Liner Repair	EA	1	\$	\$
11	Flanged Gate Valve	EA	3	\$	\$
12	Flanged Swing Check Valve	EA	2	\$	\$
13	<b>Ductile Iron Fittings (ADDENDUM # 1)</b>	LB	570	\$	\$
14	Quick Coupler Adapter	EA	1	\$	\$
15	S.S. Valve Supports	EA	3	\$	\$
16	Plug Valve	EA	1	\$	\$
17	PVC Pipe (C900) (cross/tee to plug valve)	LF	4	\$	\$

BIDDER (FIRM NAME) \_\_\_\_\_

AUTHORIZED SIGNATURE: \_\_\_\_\_

BID "B"



**BID FORM**  
(Submit in Triplicate)

**BID "B"**

**IFB# 11-2127-DS ----- 2011 Lift Station Rehab Group 3**

PROJECT SITE: Legacy 13, (RTU662)  
 PROJECT NUMBER: 402.0019707-5001336  
 SECTION / TWNShP / RANGE: S33/T35S/R19E  
 PROJECT DESCRIPTION: Rehab wetwell & valve vault piping for lift station  
 PROJECT SITE DIMENSIONS: All work within LS site

**BID "B" BASED ON COMPLETION OF 345 Calendar Days**

**ADDENDUM # 1**

ITEM NO.	DESCRIPTION	UNITS	QTY.	UNIT PRICE (\$)	EXTENDED PRICE (\$)
18	Influent Line Plug	EA	1	\$	\$
19	By-Pass Pumping	DAY	10	\$	\$
20	Repair Ex. Liner, (excl. Bid Items 9 & 10) (ADDENDUM # 1)	SF	24	\$	\$
21	<i>Intentionally Left Blank</i>				
22	<i>Intentionally Left Blank</i>				
23	Concrete, new valve vault floor	CY	7	\$	\$
24	Core Bore Holes & Patch Ex. Holes for Piping	EA	5	\$	\$
25	<i>Intentionally Left Blank</i>				
26	<i>Intentionally Left Blank</i>				
	<b>SubTotal Construction Cost</b>				\$
27	Mobilization				\$
28	Miscellaneous Work , Clean Up & Record Drawings				\$
29	<b>Discretionary Work (ADDENDUM # 1)</b>				<b>\$6,500.00</b>
	<b>TOTAL BID PRICE "B" Based on Completion Time of 345 Calendar Days (ADDENDUM # 1)</b>				\$

BIDDER (FIRM NAME) \_\_\_\_\_

AUTHORIZED SIGNATURE: \_\_\_\_\_

BID "B"

**BID FORM**  
(Submit in Triplicate)

**BID "A"**

**IFB# 11-2127-DS ----- 2011 Lift Station Rehab Group 3**

**PROJECT SITE:** Sabal Cove (RTU470)  
**PROJECT NUMBER:** 402.0019707-5001337  
**SECTION / TWSHP / RANGE:** S17/T35S/R18E  
**PROJECT DESCRIPTION:** Rehab wetwell & valve vault piping for lift station  
**PROJECT SITE DIMENSIONS:** All work within LS site

**BID "A" BASED ON COMPLETION OF 300 Calendar Days**  
**ADDENDUM # 1**

ITEM NO.	DESCRIPTION	UNITS	QTY.	UNIT PRICE (\$)	EXTENDED PRICE (\$)
1	Wetwell Cleaning	SF	729	\$	\$
2	DR-11 HDPE Piping	LF	62	\$	\$
3	HDPE Flange Adapters	EA	4	\$	\$
4	HDPE Fittings	LB	40	\$	\$
5	BPIU 6" Base Ells	EA	2	\$	\$
6	Base Ell Mounting Plate	EA	2	\$	\$
7	S.S. Pipe Bracing	EA	3	\$	\$
8	2 Inch S.S. Pump Guide Rail System	LF	50	\$	\$
9	<b>Resilient (Link) Seals w/Carrier Pipe &amp; Liner Repair (ADDENDUM # 1)</b>	EA	5	\$	\$
10	Remove & Replace 2" PVC Drain P-trap (regROUT) & Liner Repair	EA	1	\$	\$
11	Flanged Gate Valve	EA	3	\$	\$
12	Flanged Swing Check Valve	EA	2	\$	\$
13	Ductile Iron Fittings	LB	650	\$	\$
14	Quick Coupler Adapter	EA	1	\$	\$
15	<b>S.S. Valve Supports (ADDENDUM # 1)</b>	EA	4	\$	\$
16	<i>Intentionally Left Blank</i>				
17	<b>PVC Pipe (C900) (cross/tee to plug valve) (ADDENDUM # 1)</b>	LF	10	\$	\$

BIDDER (FIRM NAME) \_\_\_\_\_

AUTHORIZED SIGNATURE: \_\_\_\_\_

BID "A"

**BID FORM**  
(Submit in Triplicate)

**BID "A"**

**IFB# 11-2127-DS ----- 2011 Lift Station Rehab Group 3**

**PROJECT SITE:** Sabal Cove (RTU470)  
**PROJECT NUMBER:** 402.0019707-5001337  
**SECTION / TWSHP / RANGE:** S17/T35S/R18E  
**PROJECT DESCRIPTION:** Rehab wetwell & valve vault piping for lift station  
**PROJECT SITE DIMENSIONS:** All work within LS site

**BID "A" BASED ON COMPLETION OF 300 Calendar Days**  
**ADDENDUM # 1**

ITEM NO.	DESCRIPTION	UNITS	QTY.	UNIT PRICE (\$)	EXTENDED PRICE (\$)
18	Influent Line Plug	EA	1	\$	\$
19	By-Pass Pumping	DAY	10	\$	\$
20	Repair Ex. Liner, (excl. Bid Items 9 & 10) (ADDENDUM # 1)	SF	10	\$	\$
21	Mag. Flow Meter	EA	1	\$	\$
22	<i>Intentionally Left Blank</i>				
23	<i>Intentionally Left Blank</i>				
24	Core Bore Holes & Patch Ex. Holes for Piping	EA	0.5	\$	\$
25	6" PVC Stilling Well	LF	25	\$	\$
26	1" Conduit from Control Panel to Wet Well	LF	25	\$	\$
	<b>SubTotal Construction Cost</b>				\$
27	Mobilization				\$
28	Miscellaneous Work , Clean Up & Record Drawings				\$
29	<b>Discretionary Work</b>				<b>\$8,000.00</b>
	<b>TOTAL BID PRICE "A"</b> Based on Completion Time of 300 Calendar Days (Addendum # 1)				\$

BIDDER (FIRM NAME) \_\_\_\_\_

AUTHORIZED SIGNATURE: \_\_\_\_\_

BID "A"

**BID FORM**  
(Submit in Triplicate)

**BID "B"**

**IFB# 11-2127-DS ----- 2011 Lift Station Rehab Group 3**

PROJECT SITE: Sabal Cove (RTU470)  
 PROJECT NUMBER: 402.0019707-5001337  
 SECTION / TOWNSHIP / RANGE: S17/T35S/R18E  
 PROJECT DESCRIPTION: Rehab wetwell & valve vault piping for lift station  
 PROJECT SITE DIMENSIONS: All work within LS site

**BID "B" BASED ON COMPLETION OF 345 Calendar Days**

**ADDENDUM # 1**

ITEM NO.	DESCRIPTION	UNITS	QTY.	UNIT PRICE (\$)	EXTENDED PRICE (\$)
1	Wetwell Cleaning	SF	729	\$	\$
2	DR-11 HDPE Piping	LF	62	\$	\$
3	HDPE Flange Adapters	EA	4	\$	\$
4	HDPE Fittings	LB	40	\$	\$
5	BPIU 6" Base Ells	EA	2	\$	\$
6	Base Ell Mounting Plate	EA	2	\$	\$
7	S.S. Pipe Bracing	EA	3	\$	\$
8	2 Inch S.S. Pump Guide Rail System	LF	50	\$	\$
9	<b>Resilient (Link) Seals w/Carrier Pipe &amp; Liner Repair (ADDENDUM # 1)</b>	<b>EA</b>	<b>5</b>	<b>\$</b>	<b>\$</b>
10	Remove & Replace 2" PVC Drain P-trap (regROUT) & Liner Repair	EA	1	\$	\$
11	Flanged Gate Valve	EA	3	\$	\$
12	Flanged Swing Check Valve	EA	2	\$	\$
13	Ductile Iron Fittings	LB	650	\$	\$
14	Quick Coupler Adapter	EA	1	\$	\$
15	<b>S.S. Valve Supports (ADDENDUM # 1)</b>	<b>EA</b>	<b>4</b>	<b>\$</b>	<b>\$</b>
16	<i>Intentionally Left Blank</i>				
17	<b>PVC Pipe (C900) (cross/tee to plug valve) (ADDENDUM # 1)</b>	<b>LF</b>	<b>10</b>	<b>\$</b>	<b>\$</b>
18	Influent Line Plug	EA	1	\$	\$

BIDDER (FIRM NAME) \_\_\_\_\_

AUTHORIZED SIGNATURE: \_\_\_\_\_

BID "B"

**BID FORM**  
(Submit in Triplicate)

**BID "B"**

**IFB# 11-2127-DS ----- 2011 Lift Station Rehab Group 3**

PROJECT SITE: Sabal Cove (RTU470)  
 PROJECT NUMBER: 402.0019707-5001337  
 SECTION / TOWNSHIP / RANGE: S17/T35S/R18E  
 PROJECT DESCRIPTION: Rehab wetwell & valve vault piping for lift station  
 PROJECT SITE DIMENSIONS: All work within LS site

**BID "B" BASED ON COMPLETION OF 345 Calendar Days**

**ADDENDUM # 1**

ITEM NO.	DESCRIPTION	UNITS	QTY.	UNIT PRICE (\$)	EXTENDED PRICE (\$)
19	By-Pass Pumping	DAY	10	\$	\$
20	Repair Ex. Liner, (excl. Bid Items 9 & 10) (ADDENDUM # 1)	SF	10	\$	\$
21	Mag. Flow Meter	EA	1	\$	\$
22	<i>Intentionally Left Blank</i>				
23	<i>Intentionally Left Blank</i>				
24	Core Bore Holes & Patch Ex. Holes for Piping	EA	0.5	\$	\$
25	6" PVC Stilling Well	LF	25	\$	\$
26	1" Conduit from Control Panel to Wet Well	LF	25	\$	\$
	<b>SubTotal Construction Cost</b>				\$
27	Mobilization				\$
28	Miscellaneous Work , Clean Up & Record Drawings				\$
29	<b>Discretionary Work</b>				<b>\$8,000.00</b>
	<b>TOTAL BID PRICE "A"</b> Based on Completion Time of 300 Calendar Days (ADDENDUM # 1)				\$

BIDDER (FIRM NAME) \_\_\_\_\_

AUTHORIZED SIGNATURE: \_\_\_\_\_

BID "B"

**BID FORM**  
(Submit in Triplicate)

**BID "A"**

**IFB# 11-2127-DS ----- 2011 Lift Station Rehab Group 3**

**PROJECT SITE:** Legacy 10, (RTU660)  
**PROJECT NUMBER:** 402.0019707-5001338  
**SECTION / TOWNSHIP / RANGE:** S33/T35S/R19E  
**PROJECT DESCRIPTION:** Rehab wetwell & valve vault piping for lift station  
**PROJECT SITE DIMENSIONS:** All work within LS site

**BID "A" BASED ON COMPLETION OF 300 Calendar Days**

**ADDENDUM # 1**

ITEM NO.	DESCRIPTION	UNITS	QTY.	UNIT PRICE (\$)	EXTENDED PRICE (\$)
1	Wetwell Cleaning	SF	905	\$	\$
2	DR-11 HDPE Piping	LF	62	\$	\$
3	HDPE Flange Adapters	EA	4	\$	\$
4	HDPE Fittings	LB	40	\$	\$
5	<b>4" BPIU Base Ells &amp; 4" Tubing (ADDENDUM # 1)</b>	<b>EA</b>	<b>2</b>	<b>\$</b>	<b>\$</b>
6	Base Ell Mounting Plate	EA	2	\$	\$
7	S.S. Pipe Bracing	EA	3	\$	\$
8	2 Inch S.S. Pump Guide Rail System	LF	48	\$	\$
9	<b>Resilient (Link) Seals w/Carrier Pipe &amp; Liner Repair (ADDENDUM # 1)</b>	<b>EA</b>	<b>5</b>	<b>\$</b>	<b>\$</b>
10	Remove & Replace 2" PVC Drain P-trap (regROUT) & Liner Repair	EA	1	\$	\$
11	Flanged Gate Valve	EA	3	\$	\$
12	Flanged Swing Check Valve	EA	2	\$	\$
13	<b>Ductile Iron Fittings (ADDENDUM # 1)</b>	<b>LB</b>	<b>770</b>	<b>\$</b>	<b>\$</b>
14	Quick Coupler Adapter	EA	1	\$	\$
15	S.S. Valve Supports	EA	5	\$	\$
16	Plug Valve	EA	1	\$	\$

BIDDER (FIRM NAME) \_\_\_\_\_

AUTHORIZED SIGNATURE: \_\_\_\_\_

BID "A"

**BID FORM**  
(Submit in Triplicate)

**BID "A"**

**IFB# 11-2127-DS ----- 2011 Lift Station Rehab Group 3**

PROJECT SITE: Legacy 10, (RTU660)  
 PROJECT NUMBER: 402.0019707-5001338  
 SECTION / TWNSHP / RANGE: S33/T35S/R19E  
 PROJECT DESCRIPTION: Rehab wetwell & valve vault piping for lift station  
 PROJECT SITE DIMENSIONS: All work within LS site

**BID "A" BASED ON COMPLETION OF 300 Calendar Days**

**ADDENDUM # 1**

ITEM NO.	DESCRIPTION	UNITS	QTY.	UNIT PRICE (\$)	EXTENDED PRICE (\$)
17	PVC Pipe (C900) (cross/tee to plug valve) (ADDENDUM # 1)	LF	6	\$	\$
18	Influent Line Plug	EA	1	\$	\$
19	By-Pass Pumping	DAY	10	\$	\$
20	Repair Ex. Liner, (excl. Bid Items 9 & 10) (ADDENDUM # 1)	SF	24	\$	\$
21	Intentionally Left Blank				
22	Intentionally Left Blank				
23	Intentionally Left Blank				
24	Core Bore Holes & Patch Ex. Holes for Piping	EA	5	\$	\$
25	6" PVC Stilling Well	LF	24	\$	\$
26	1" Conduit from Control Panel to Wet Well	LF	25	\$	\$
	<b>SubTotal Construction Cost</b>				\$
27	Mobilization				\$
28	Miscellaneous Work , Clean Up & Record Drawings				\$
29	<b>Discretionary Work (ADDENDUM # 1)</b>				<b>\$8,500.00</b>
	<b>TOTAL BID PRICE "A" Based on Completion Time of 300 Calandar Days (ADDENDUM # 1)</b>				<b>\$</b>

BIDDER (FIRM NAME) \_\_\_\_\_

AUTHORIZED SIGNATURE: \_\_\_\_\_

BID "A"

**BID FORM**  
(Submit in Triplicate)

**BID "B"**

**IFB# 11-2127-DS ----- 2011 Lift Station Rehab Group 3**

PROJECT SITE: Legacy 10, (RTU660)  
 PROJECT NUMBER: 402.0019707-5001338  
 SECTION / TWSHP / RANGE: S33/T35S/R19E  
 PROJECT DESCRIPTION: Rehab wetwell & valve vault piping for lift station  
 PROJECT SITE DIMENSIONS: All work within LS site

**BID "B" BASED ON COMPLETION OF 345 Calendar Days**  
**ADDENDUM # 1**

ITEM NO.	DESCRIPTION	UNITS	QTY.	UNIT PRICE (\$)	EXTENDED PRICE (\$)
1	Wetwell Cleaning	SF	905	\$	\$
2	DR-11 HDPE Piping	LF	62	\$	\$
3	HDPE Flange Adapters	EA	4	\$	\$
4	HDPE Fittings	LB	40	\$	\$
5	<b>4" BPIU Base Ells &amp; 4" Tubing (ADDENDUM # 1)</b>	<b>EA</b>	<b>2</b>	<b>\$</b>	<b>\$</b>
6	Base Ell Mounting Plate	EA	2	\$	\$
7	S.S. Pipe Bracing	EA	3	\$	\$
8	2 Inch S.S. Pump Guide Rail System	LF	48	\$	\$
9	<b>Resilient (Link) Seals w/Carrier Pipe &amp; Liner Repair (ADDENDUM # 1)</b>	<b>EA</b>	<b>5</b>	<b>\$</b>	<b>\$</b>
10	Remove & Replace 2" PVC Drain P-trap (regROUT) & Liner Repair	EA	1	\$	\$
11	Flanged Gate Valve	EA	3	\$	\$
12	Flanged Swing Check Valve	EA	2	\$	\$
13	<b>Ductile Iron Fittings (ADDENDUM # 1)</b>	<b>LB</b>	<b>770</b>	<b>\$</b>	<b>\$</b>
14	Quick Coupler Adapter	EA	1	\$	\$
15	S.S. Valve Supports	EA	5	\$	\$
16	Plug Valve	EA	1	\$	\$
17	<b>PVC Pipe (C900) (cross/tee to plug valve) (ADDENDUM # 1)</b>	<b>LF</b>	<b>6</b>	<b>\$</b>	<b>\$</b>

BIDDER (FIRM NAME) \_\_\_\_\_

AUTHORIZED SIGNATURE: \_\_\_\_\_

BID "B"



**BID FORM**  
(Submit in Triplicate)

**BID "B"**

**IFB# 11-2127-DS ----- 2011 Lift Station Rehab Group 3**

PROJECT SITE: Legacy 10, (RTU660)  
 PROJECT NUMBER: 402.0019707-5001338  
 SECTION / TWSHP / RANGE: S33/T35S/R19E  
 PROJECT DESCRIPTION: Rehab wetwell & valve vault piping for lift station  
 PROJECT SITE DIMENSIONS: All work within LS site

**BID "B" BASED ON COMPLETION OF 345 Calendar Days  
ADDENDUM # 1**

ITEM NO.	DESCRIPTION	UNITS	QTY.	UNIT PRICE (\$)	EXTENDED PRICE (\$)
18	Influent Line Plug	EA	1	\$	\$
19	By-Pass Pumping	DAY	10	\$	\$
20	<b>Repair Ex. Liner, (excl. Bid Items 9 &amp; 10) (ADDENDUM # 1)</b>	SF	24	\$	\$
21	<i>Intentionally Left Blank</i>				
22	<i>Intentionally Left Blank</i>				
23	<i>Intentionally Left Blank</i>				
24	Core Bore Holes & Patch Ex. Holes for Piping	EA	5	\$	\$
25	6" PVC Stilling Well	LF	24	\$	\$
26	1" Conduit from Control Panel to Wet Well	LF	25	\$	\$
	<b>SubTotal Construction Cost</b>				\$
27	Mobilization				\$
28	Miscellaneous Work , Clean Up & Record Drawings				\$
29	<b>Discretionary Work (ADDENDUM # 1)</b>				<b>\$8,500.00</b>
	<b>TOTAL BID PRICE "B" Based on Completion Time of 345 Calendar Days (ADDENDUM # 1)</b>				\$

BIDDER (FIRM NAME) \_\_\_\_\_

AUTHORIZED SIGNATURE: \_\_\_\_\_

BID "B"