



1112 Manatee Avenue West
Bradenton, FL 34205
purchasing@mymanatee.org

Solicitation Addendum

Addendum No.: 5
Solicitation No.: 25-TA006192LP
Project No.: 6102460
Solicitation Title: 9th Avenue NW Roadway Improvements
Addendum Date: November 21, 2025
Procurement Contact: Leslie Peer

IFBC 25-TA006192LP is amended as set forth herein. Responses to questions posed by prospective bidders are provided below. This Addendum is hereby incorporated in and made a part of IFBC 25-TA006192LP.

The deadline to submit all inquiries concerning interpretation, clarification or additional information pertaining to this IFBC was November 19, 2025.

ADD:

SECTION C, BID ATTACHMENTS, BID ATTACHMENT 11 - 19, CAD FILES

Add Bid Attachment 11 – 19, CAD Files available for download as separate attachments, hereby incorporated into the IFBC

QUESTIONS AND RESPONSES:

Q1. Addendum No. 1 revised bid form for pay item 0530 3-4 has a quantity of 92.1 tons. Plan sheet 2, sheet #33 calls out 133.7 tons. Which one is correct?

R1. Please submit your bid based off the bid form pay item quantity of 92.1 tons for pay item 0530-3-4. Actual amount paid will be based on total materials placed.

Q2. Would it be possible to supply the CAD files for this project to assist us in preparing our bid?

R2. See Bid Attachment 11 – 19, CAD Files available for download as separate attachments.

Q3. On plan sheet #35, on the north side of the right of way at the approximate stationing of 43+30, there are four large banyan trees located in the drainage easement where the new sediment basin and removal replacement of larger elliptical pipes will take place. These trees are not called out to be removed, but the construction operations will most definitely impact the root systems and overhangs of these trees, most likely killing them. Please advise as to if these trees are to be removed as part of the clear & grub and if not, what actions are required by the County to attempt to save the trees during the drainage scope of work in this easement.

R3. The Engineer of Record and Manatee County Project Manager recently met with the residents of Hawthorn Park and made them aware the first four trees adjacent to the installation of the 38”X60” pipe and corresponding structures would most likely be impacted during constructions. Please include the removal of these four trees in your clearing and grubbing pay item.

NOTE:

Deleted items will be ~~struck through~~, added or modified items will be underlined. All other terms and conditions remain as stated in the IFBC.

INSTRUCTIONS:

Receipt of this Addendum must be acknowledged as instructed in the solicitation document. Failure to acknowledge receipt of this Addendum may result in the response being deemed non-responsive.

END OF ADDENDUM

AUTHORIZED FOR RELEASE