



MANATEE COUNTY FLORIDA

email

October 25, 2011

TO: All Interested Quoters

SUBJECT: Request for Quotation #11-3315DC Pipe Rehabilitation
On Morgan Johnson Road - ADDENDUM #1

The following items are issued to add to, modify, and clarify the quote documents. Quotes to be submitted by the specified due date, shall conform to the additions and revisions listed herein.

1. The requirement to form and pour a floor and toe wall shall be determined in the field; the width shall also be determined at this time.
2. The minimum thickness requirement on material application shall be 2.5" and shall be measured from the highest point of the inside surface of the pipe.
3. Test cubes of the lining material shall be taken randomly as directed by the inspector at owner's expense to verify strengths. Thickness can be verified with a wet gage at any random point of the new interior surface. Any areas found to be thinner than minimum shall immediately receive additional material. Visual inspection should verify a leak-free, uniform appearance.
4. Material compressive strength shall be tested at 28 days.

Quotes will be received until **November 1, 2011 at 1:00 P.M.** Email is acceptable.

Sincerely,

A handwritten signature in cursive script that reads "Deborah Carey-Reed".

Deborah Carey-Reed
Contract Specialist

/dcr

Financial Management Department * Purchasing Division
1112 Manatee Avenue West, Suite 803, Bradenton, FL 34205
deborah.carey-reed@mymanatee.org* PHONE: 941.749-3074 * FAX: 941.749-3034
WEB: www.mymanatee.org