



1112 Manatee Avenue West
Bradenton, FL 34205
purchasing@mymanatee.org

Solicitation Addendum

Addendum No.: 1
Solicitation No.: 26-R089936JH
Solicitation Title: Lakewood Ranch Park Rosedale Buffer
Addendum Date: April 30, 2026
Procurement Contact: Jeb Hayter, Procurement Agent III

IFB No. 26-R089936JH is amended as set forth herein. Responses to questions posed by prospective bidders are provided below. This Addendum is hereby incorporated into and made a part of IFB No. 26-R089936JH.

The deadline to submit all inquiries concerning interpretation, clarification or additional information pertaining to this IFB was April 28, 2026.

QUESTIONS AND RESPONSES:

Q1. For the irrigation contractor license, which one do we need to have? FNGLA Certified Landscape Irrigation Service Technician (FCLIST) , Florida Water Star Accredited Professional (FWS-AP). Would you accept any other credentials in lieu of these requirements, such as ISA Certified Arborist, GI BMP, etc.?

R1. Preferred license would be FNGLA Certified Landscape Irrigation Service Technician but would accept FWS-AP or another license that is related to Irrigation as long as it is issued by the Florida Nursery, Growers and Landscape Association or Florida Department of Business and Professional Regulation.

Q2. The plans call for sandy loam mix for soil, my supplier can provide regular fill dirt. In order to get the mix to provide more loam, sand can also be brought in and mixed. Would that suffice for the sandy loam mix?

R2. Regular fill dirt will be fine, as long as a sand mixture is used around the plantings.

Q3. Aside from silt fence and inlet protection, are there additional dust protection procedures the HOA or park would request?

R3. No, Irrigation heads in place will be able to be turned on to wet the area to keep dust down.

Q4. The plan pages specify the slash pines as 30 gallons, 8-10 feet in height with a 2.5 inch caliper. The current market shows them as 30 gallon, 8 foot high with a 2 inch caliper. Is the

2 inch caliper acceptable or should we price as a 45 gallon in order to meet the specified caliper?

R4. The largest 30 gallon available will be acceptable even if they are 8 ft with 2 inch caliper.

NOTE:

Deleted items will be ~~struck through~~, added or modified items will be underlined. All other terms and conditions remain as stated in the IFB.

INSTRUCTIONS:

Receipt of this Addendum must be acknowledged as instructed in the solicitation document. Failure to acknowledge receipt of this Addendum may result in the response being deemed non-responsive.

END OF ADDENDUM

AUTHORIZED FOR RELEASE