



## MANATEE COUNTY FLORIDA

### Email

November 3, 2011

TO: All Interested Quoters

SUBJECT: Request for Quotation #11-3315DC Pipe Rehabilitation  
On Morgan Johnson Road - ADDENDUM #3

The following items are issued to add to, modify, and clarify the quote documents. Quotes to be submitted by the specified due date, shall conform to the additions and revisions listed herein.

1. Additional work item for floor and toe walls is deleted from this Quote and will be addressed in the field if the need arise.
2. The specification has been reviewed by the County's engineering department and the minimum thickness requirement shall remain at 2.5" for the material application (as stated in Addendum 1).

Quotes will be received until **November 7, 2011 at 1:00 P.M.** Email is acceptable.

Sincerely,

A handwritten signature in cursive script that reads "Deborah Carey-Reed".

Deborah Carey-Reed  
Contract Specialist

/dcr

Financial Management Department \* Purchasing Division  
1112 Manatee Avenue West, Suite 803, Bradenton, FL 34205  
deborah.carey-reed@mymanatee.org \* PHONE: 941.749-3074 \* FAX: 941.749-3034  
WEB: [www.mymanatee.org](http://www.mymanatee.org)