



MANATEE COUNTY FLORIDA

REQUEST FOR QUOTATION #13-0037GE WATER FILTER HOUSING

DATE ISSUED: October 8, 2012

DUE DATE: October 12, 2012 at 3:00pm

Submit quote to George Earnest CPPB, Buyer either by email or fax.
P 941.749.3044 F 941.749.3034
george.earnest@mymanatee.org

Manatee County invites your participation in the following quotation. The specifications stated herein are of the minimum requirements:

The County Waste Water Processing Plant is seeking a filter housing unit for the purpose of filtering pond water back to the treatment plant. The unit is a bag filter which holds eight 7" x 30" filter bags. The unit is fitted with an 8" inlet and outlet. The unit should also have a 2" drain on the bottom. Approximate size of unit should be 40" wide by 73" high. The lid must be removable and be securely fitted with eye bolts and a hand crank lifting mechanism. Construction material for the filter housing should be carbon steel with stainless steel filter baskets. The unit housing shall have a Max. working pressure of 150 psi. Filter should be sized to process at least 1000 gallons a minute. The unit shall also have an inlet and outlet pressure gauge. The unit must be ASME coded. This filter uses polyester felt replaceable filter bags for high solids holding. The quoter shall also quote a price for 50 filter bags.

Vendors submitting a quote must provide a drawing of their unit and detailed specifications. The price quoted must include shipping cost as a separate quote item as FOB Destination to the Southwest Waster Water Maintenance Building, 5160 65th Street West, Bradenton FL 34210. Delivery lead time from receipt of the Purchase Order must be one week.

Financial Management Department, Purchasing
1112 Manatee Avenue West, Suite 803, Bradenton, FL 34205-1000
WEB: www.mymanatee.org, * george.earnest@mymanatee.org * PHONE: 941.749-3044
* FAX: 941.749-3034