



MANATEE COUNTY FLORIDA

December 9, 2013

TO: All Interested Bidders
SUBJECT: Invitation for Bids #13-2222CD
Fort Hamer Park Expansion- Phase II

ADDENDUM #4

Bidders are hereby notified that this Addendum shall be acknowledged on page 00300-1 of the Bid Form and made a part of the above named bidding and contract documents. Bids submitted without acknowledgment of the Addendum will be considered incomplete.

The following items are issued to add to, modify, and clarify the bid and contract documents. These items shall have the same force and effect as the original bidding and contract documents, and cost involved shall be included in the bid prices. Bids to be submitted on the specified bid date, shall conform to the additions and revisions listed herein.

1. **CHANGE RESPONSE #1** issued in Addendum #3 to read as follows:

Schedule 40 PVC pipe and fittings with bell end and gasket, manufactured by Harvel Plastics, are distributed by Ryan Herco Flow Solutions in Orlando, FL. Schedule 40 PVC pipe and fittings with bell end and gasket are also available from other suppliers but may require minimum orders from the manufacturer.

Equivalent sized solvent weld schedule 40 PVC pipe and fittings (white in color) may also be used as an alternate to the specified SDR-35 PVC storm pipe.

2. **CHANGE** the Due Date and Time to **Thursday, December 12, 2013 at 3:00 PM.**

END OF ADDENDUM #4

Bids will be received at Manatee County Purchasing, 1112 Manatee Avenue West, Bradenton, Florida 34205 until **Thursday, December 12, 2013 at 3:00 PM.**

Sincerely,


Melissa M. Wendel, CPPO
Purchasing Official

Financial Management Department - Purchasing Division
1112 Manatee Avenue West, Suite 803, Bradenton, FL 34205
PHONE: 941.749.3014 * FAX: 941.749.3034

www.myanatee.org