



MANATEE COUNTY
FLORIDA

March 11, 2014

TO: All Interested Quoters

SUBJECT: **Request for Quotation # 14-1064-DS**
Stormwater Discharge Maintenance Program Bay Drive

ADDENDUM # 1

Quoters are hereby notified that this Addendum shall be acknowledged on page 23 of the Quote Form and made a part of the above named quoting and contract documents. Quotes submitted without acknowledgement of the Addendum will be considered incomplete.

The following items are issued to add to, modify, and clarify the Quote and contract documents. These items shall have the same force and effect as the original Quoting and contract documents, and cost involved shall be included in the bid prices. Bids to be submitted on the specified bid date, shall conform to the additions and revisions listed herein.

The deadline for clarification of questions was **March 7, 2014 at 2:00pm**. This deadline had been established to maintain fair treatment of all potential Quoters. Questions received after this date and time shall not be considered.

Q1: A public records request was made for the Engineers Estimate for this project.

R1: The Construction budgeted amount is \$ 81,400.00

Q2: What is the predominant sediment type within the dredge limits?

R2: The predominant sediment type is organic material and sand.

Q3: Does all dewatering have to be done on a barge? Could we possibly use a small site near the shore to dewater the sediment and then haul it to the landfill?

R3: No all dewatering does not have to be on a barge. You could use some other location to dewater. However, you will need approval from the homeowner and possibly enter into an agreement with the homeowner. A dewatering plan will also need to be approved for dewatering on-site or off-site.

Q4: Is it imperative that the material is hauled to the Manatee County Landfill, and if so, are we responsible for the tipping fees?

R4: Yes. All dredged material must be disposed of at the Manatee County Class I Landfill (Lena Road). All disposal material placed in the landfill shall be in compliance with "Test Methods for Evaluating Solid Waste, Physical Chemical Method" Method 9095 (Paint Filter Liquids Test) (EPA Publication No. SW-846). All tipping fees will be waived.

Financial Management Department
Mailing Address: P. O. Box 1000 1112 Manatee Avenue West Suite 803, Bradenton, FL 34206-1000
WEB: www.mymanatee.org * PHONE: 941.749.3045 * FAX: 941.749.3014

March 11, 2014

Request for Quotation # 14-1064-DS

Stormwater Discharge Maintenance Program Bay Drive

Page 2

- Q5:** Can we pump the material into sealed trucks on the street for dewatering if it is kept clean, as opposed to having to dewater on a barge and transport over water to an off-load site? Given the location of the outfalls in reference to an offload site, this would be a more efficient approach, in my opinion
- R5:** A dewatering plan will need to be approved for dewatering on-site or off-site. It is our experience that the paint test cannot be met for disposal at the landfill without additional dewatering beyond what can occur or be achieved in sealed trucks.
- Q6:** I understand the forms necessary for submittal approval to be as described below, totaling 9 pages. If this is correct, how many copies would you like with the original? If this is not correct, what other additional information must we submit?

Quotation form 2 pages

Florida Trench Act 1 page

Contractor's questionnaire 4 pages

Public Contracting and Environmental Crimes Certification 2 pages

- R6:** The necessary forms to submit are noted above in addition to the affidavit if applicable. Submit one signed set via the method as defined on the front of the Request for Quotation.
- Q7:** Sheet 2, Note #7 requires dredged spoils to be taken to the Lena Road Landfill. Is it acceptable for the contractor to find and include in his bid an approved, permitted alternate disposal site?
- R7:** No. All dredged material must be disposed of at the Manatee County Class I Landfill (Lena Road). All disposal material placed in the landfill shall be in compliance with "Test Methods for Evaluating Solid Waste, Physical Chemical Method" Method 9095 (Paint Filter Liquids Test) (EPA Publication No. SW-846). All tipping fees will be waived.

Clarification of qualification of Quoters:

QUALIFICATIONS OF THE QUOTER

The Quoter must have a minimum **five (5) years experience** in dredging and also must have successfully constructed, as prime Contractor, at least three projects of similar size which is the subject of this Request for Quotation.

Each Quoter shall submit as a portion of their quote a completed Contractor's Questionnaire included as Section 00430.

Each Quoter must be prepared to submit with five (5) days of the County's request; written evidence such as previous experience, present commitments and other such data as may be requested. Quoter must be able to provide evidence of Quoters' qualification to do business in the State of Florida.

Financial Management Department

Mailing Address: P. O. Box 1000 1112 Manatee Avenue West Suite 803, Bradenton, FL 34206-1000

WEB: www.mymanatee.org * PHONE: 941.749.3045 * FAX: 941.749.3014

March 11, 2014

Request for Quotation # 14-1064-DS

Stormwater Discharge Maintenance Program Bay Drive

Page 2


QUALIFICATIONS OF THE QUOTER (continued)

A complete list of all subcontractors proposed for any portion of the Work may be requested of any Quoter deemed necessary by the County. Subcontracts shall be awarded only to those subcontractors considered satisfactory by the County.

The deadline for submitting quotes is unchanged at March 18, 2014 at 3:00 PM.

END OF ADDENDUM # 1

Sincerely,



Donna M. Stevens
Contract Specialist

Financial Management Department

Mailing Address: P. O. Box 1000 1112 Manatee Avenue West Suite 803, Bradenton, FL 34206-1000

WEB: www.mymanatee.org * PHONE: 941.749.3045 * FAX: 941.749.3014