



MANATEE COUNTY FLORIDA

September 12, 2014

TO: All Interested Quoters

SUBJECT: ADDENDUM #2 – RFQ #14-2538BS
Fire Suppression Maintenance
Revised RFQ Due Date: September 22, 2014

Quoters are hereby notified that this addendum shall be acknowledged within their quote and shall be made a part of the above issued Request for Quotation. This information is issued to add to, modify, and/or clarify the Request for Quotation documents. These items shall have the same force and effect as the original Request for Quotation. Quotes are to be submitted on the specified date and shall conform to the additions and revisions listed herein.

REVISED RFQ DUE DATE: September 22, 2014

- Q: Are previous inspection reports available at each site (for review)?
- A: Inspection reports should be at each control panel site.
- Q: Is the previous quotation tabulation available?
- A: Previously provided in addendum #1, dated September 4, 2014.
- Q: Are there any sites that require after hours inspections?
- A: All inspections shall be scheduled during normal business hours.
- Q: Are site visits allowed?
- A: Site visits may be scheduled with the site coordinator.
- Q: Jail – Stockade, Spray-paint Booth Suppression System – This type of system, traditionally a pre-engineering fire suppression system, falls under the Fire Equipment Dealer Class license rather than the Contractor I and III licenses. Is it Manatee County's intention to keep this system as part of this quotation?
- A: Yes, it is our intention to keep this system on this quotation.

Page Two
September 12, 2014
RFQ #14-2538BS, Fire Suppression Maintenance
Note: Revised RFQ Due Date, September 22, 2014


Q: Judicial Center IT Wing – Does Manatee County intent to include the newly installed fire suppression system, in the Hensley Wing, as part of this quotation?

A: This item has been added as A-13, please see revised quotation form. Note: The Hensley 4th floor Information Technology Data Room Suppressions system:

Fike, Encarro 375 with liquid level indicator
Including 2 nozzles, 6 smokes, 1 bell, 1 horn, 1 strobe, 1 pull, and 1 abort

Q: Are the current inspections performed in sync? Are all inspections performed during the same month?

A: The inspection schedule is flexible, however, our intent it have annual and semi-annual testing completed within three weeks of their current expiration date.

 9/12/2014
Bonnie Sietman Date
Purchasing, Senior Buyer

/bls

Attachment: Quotation Form

QUOTATION FORM (Revised 9/12/2014, added A-13)
REQUEST FOR QUOTATION #14-2538BS
FIRE SUPPRESSION MAINTENANCE

		Suppression System			
A	Locations	Annual PM cost	Semi-annual PM cost		Total Cost of both PM's
X	Administration Building, 7 th floor data room	Omitted - due to	Scheduled		Construction of Data room
1	Administration Building, 7 th Phone room	\$	\$	=	\$
2	Desoto Center MSO, 2 nd floor	\$	\$	=	\$
3	GTE Building, 2 nd Floor	\$	\$	=	\$
4	Health Department, Data room	\$	\$	=	\$
5	Historic Courthouse, Data Center, 1 st floor	\$	\$	=	\$
6a	Judicial Center, room 418	\$	\$	=	\$
6b	Judicial Center, room 413	\$	\$	=	\$
7a	Public Safety EOC, room 1330	\$	\$	=	\$
7b	Public Safety EOC, room 1412	\$	\$	=	\$
7c	Public Safety EOC, room 1100	\$	\$	=	\$
7d	Public Safety EOC, room 2001	\$	\$	=	\$
7e	Public Safety EOC, room 2606	\$	\$	=	\$
8	Central Jail, Data room	\$	\$	=	\$
9	Central Jail - Stockade Paint booth	\$	\$	=	\$
10	Cortez, Water Tower Site	\$	\$	=	\$
11	Northwest, Water tower Site	\$	\$	=	\$
12	Buffalo, Water tower Site	\$	\$	=	\$
13	Hensley, 4 th Fl, Data Room	\$	\$	=	\$
TOTAL AMOUNT (Section A)			→		\$

B	Labor Costs for Repairs				
1	Charge Per Hour for Labor as Directed (M-F, 8-5) (MCPM On site time only, no travel charges will be accepted)	\$ _____	X 40	=	\$
2	Overtime Charge Per Hour for Labor as Directed (Hours other than M-F, 8-5) (MCPM On site time only, no travel charges will be accepted)	\$ _____	X 10	=	\$

C	Repair Parts Allowance				
1	Annual Repair Parts Allowance (approved by PM)	\$4000.00 x _____ % off MSRP	=	\$	

D	TOTAL AMOUNT FOR SECTIONS A, B, AND C	=	\$
---	--	---	----

Company Name: _____