



Financial Management Department
Purchasing Division
1112 Manatee Ave W Suite 803
Bradenton, FL 34205
Phone: (941) 749-3074
www.mymanatee.org

email
October 8, 2014

TO: All Interested Bidders

SUBJECT: Invitation for Bid #14-2848DC
Force Main 1MA Replacement

ADDENDUM #2

Bidders are hereby notified that this Addendum shall be acknowledged on the Bid Form and made a part of the above named bidding and contract documents.

1. Engineer's response to questions received attached.

If you have submitted a bid prior to receiving this addendum you may request in writing that your original, sealed bid be returned to your firm. All sealed bids received will be opened on the date stated.

Bids will be received at Manatee County Purchasing, 1112 Manatee Avenue West, Suite 803, Bradenton, Florida 34205 until **October 15, 2014 at 3:00 P.M.**

Sincerely,

A handwritten signature in pink ink that reads "Deborah Carey-Reed".

Deborah Carey-Reed, CPPB
Contracts Specialist

/dcr
Attachment



Public Works Department
Utility Engineering Division
1022 26th Avenue East
Bradenton, FL 34208
Phone: (941) 708-7450
www.mymanatee.org

MEMORANDUM

To: Deborah Carey-Reed, CPPB, Contract Specialist
From: Michael L. Sturm, PE, Project Manager, Shea Shoun, PE, Senior Project Engineer
Date: October 9, 2014
Subject: Force Main 1MA Replacement - Responses to Bidder Questions
Project: #6085980

In discussion with Shea Shoun, P.E. in Jim Stockwell, P.E.'s absence and confirmed by Chris Mowbray, P.E., The following text answers questions received regarding this project and provides clarifications and revisions to this contract as follows:

Questions from Charlie Keister of DR Swanson Company October 8, 2014

1. Question: Can the lift station feeding the existing force main be shut down, and if so, for how long?

Answer: No, the contractor should be prepared to use a pump truck while performing the work.

2. Question: What is the maximum flow rate in the existing force main?

Answer: 275 GPM at 25 TDH.

3. Question: Can the Maritime Museum property, the lawn area just outside the ROW and adjacent parking lot entrance, be used for the directional drill machine working area? This would eliminate excessive damages to the existing landscaping.

Answer: This is private property. The contractor would have to negotiate the use of the property with the property owner.

4. Question: Can a portion of the Maritime Museum rear parking lot area be used for temporary storage of equipment and materials?

Answer: This is private property. The contractor would have to negotiate the use of the property with the property owner.

S:\PWD_PJM_Share\Projects\Wastewater\FM-1MA Rehab_6085980\PM\PM-MSturm\Addendum\BidderQresponse100914.docx