



Financial Management Department
Purchasing Division
1112 Manatee Ave W Suite 803
Bradenton, FL 34205
Phone: (941) 749-3014
www.mymanatee.org

October 15, 2014

TO: All Interested Bidders
SUBJECT: Invitation for Bids #14-2847CD
2014 Rehabilitation of Satellite Lift Stations- Group 2

ADDENDUM #2

Bidders are hereby notified that this Addendum shall be acknowledged on page Bid Form-1 of the Bid Form and made a part of the above named bidding and contract documents. Bids submitted without acknowledgment of the Addendum will be considered incomplete.

The following items are issued to add to, modify, and clarify the bid and contract documents. These items shall have the same force and effect as the original bidding and contract documents, and cost involved shall be included in the bid prices. Bids to be submitted on the specified bid date, shall conform to the additions and revisions listed herein.

1. **DELETE** Bid Form pages Bid Form-2 through Bid Form-26 and **INSERT** Revised Bid Form pages Bid Form-2 through Bid Form-26 that are attached to this Addendum #2.
2. **DELETE** the pages 42 thru 43 of the Technical Specifications dated July 2014 and **INSERT** the Revised pages 42 thru 43 of the Technical Specifications that are attached to this Addendum #2.
3. **DELETE** Plan Sheet number 6 and **INSERT** the Revised Plan Sheet number 6 dated 10/10/2014 that is attached to this Addendum #2.
4. **CLARIFICATIONS OF ENGINEER'S CHANGES:**
 - a. Technical Specifications:
 - i. Section 01150- Measurement and Payment; Changes to Article 1.07 on page 42 and 43 of 183 as follows:
 1. Added a new Bid Item #47: Driveway, and revised bid item numbering accordingly.
 - b. Bid Form:
 - i. Revised Bid Items for West Glenn RTU 146 as follows:
 1. Added Bid Items #32,42,43,44,45, and 47
 2. Removed Bid Items #38,39, and 41
 - c. Plan Set:
 - i. Revised Plan Sheet 6 as follows:
 1. Added note 3
 2. Added note 4.
 3. Plan revision: Existing palm tree by control panel to be removed; Control panel to remain at current location; furnish & install new electrical mounting structure; Install new meter, backflow preventer and hose bid south of existing wet well.

The following questions have been presented by potential bidders:

QUESTION #1: Are there Electrical Prints available for this bid? If so, we would request a copy. Our electrical contractor is requesting said prints to better evaluate the electrical work required of this bid.

RESPONSE #1: Please refer to the Standards for electrical requirements. The Manatee County Utility Standards may be downloaded for your use at the following web address:

<http://www.mymanatee.org/dms/departments/public-works/engineering-standards/Manatee-County-Utility-Standards-PDF/Manatee%20County%20Utility%20Standards%20PDF.pdf>

Please note: these stations differ from the standards, as the station will have above ground valve assemblies, except for Medor Subdivision.

QUESTION #2: For RTU 131: Will the Water service be terminated? If so, will it be cut at the corps or at the main?

RESPONSE #2: Yes. However, the water service shall already be abandoned by the County prior to construction.

QUESTION #3: For RTU 471: Can the guard rail and fence be removed for the rehab? Where is the closest manhole for bypassing?

RESPONSE #3: No to guardrail. Yes to fence. The fence shall be reinstalled as existing. The nearest manhole is about 15-20 feet to the east of station.

QUESTION #4: For RTU 435: How much of the planting must be replaced. A large tree is adjacent to the site that will interfere with the work along with bushes planted up against the panels and electrical components.

RESPONSE #4: Please see the notes on the Plan Sheet for this Lift Station on the lower left side of the "Proposed". Tree shall be removed. Bushes and plants removed as necessary.

QUESTION #5: For RTU 401: Can the fence be removed for the work?

RESPONSE #5: Please see note 2 (lower left corner) on the Plan Sheet for this Lift Station. Since the existing fence is to be removed and a new one installed, yes the fence can be removed for the Work.

QUESTION #6: For RTU 401, RTU 146, and RTU 122: Are there any restrictions for bypassing to the manhole in the center of the road?

RESPONSE #6: No, but a maintenance of traffic plan will be required for each Lift Station.

QUESTION #7: For RTU 146: The hedging surrounding the station must be removed to rehab, is this okay? Must the hedging be replaced? There is a palm tree against the telemetry stand. Can it be removed?

RESPONSE #7: The Bid documents and Plan Sheet have been revised to remove all vegetation and the palm tree, and to have a new vinyl coated chain link fence, weed barrier and shell, along with a concrete driveway furnished and installed.

QUESTION #8: For RTU 122: The hedging surrounding the station must be removed to rehab, what replacement requirements are required as the station is already in tight confinement.

RESPONSE #8: Hedging may be removed as required and as approved by the County Inspector. The County shall re-install.

END OF ADDENDUM #2

Bids will be received at Manatee County Purchasing, 1112 Manatee Avenue West, Bradenton, Florida 34205 until **Monday, October 20, 2014 at 3:00 PM.**

Sincerely,


Melissa M. Wendel, CPPO for
Purchasing Official

BID FORM

(Submit in Triplicate)

2014 REHABILITATION OF SATELLITE LIFT STATIONS- GROUP 2

Bid "A" Based on Completion Time of 180 Calendar Days

ITEM NO.	DESCRIPTION	EST. QTY.	U/M	UNIT PRICE	EXTENDED PRICE
	Coral Shores E4- RTU 122				
1	Wetwell Cleaning	SF	463	\$	\$
2	4" DR-11 HDPE Wetwell Piping	LF	56	\$	\$
3	4" HDPE Flange Adapters w/ Backup Rings	EA	4	\$	\$
4	4" HDPE Fittings	LB	8	\$	\$
5	BPIU.14 Pump Base Ells	EA	2	\$	\$
6	Pump Base Ell Mounting Plate	EA	2	\$	\$
7	S.S. Pipe Bracing, 6 ft dia.	EA	3	\$	\$
8	Raise Ex. Wet Well Rim	VF	0.7	\$	\$
9	Replace Ex. Wetwell Top Slab	EA	1	\$	\$
10	4" PVC Vent, Sch 80	EA	1	\$	\$
11	Aluminum Hatch Cover, 36" x 48", Single door (Wetwell)	EA	1	\$	\$
12	2" S.S. Pump Guide Rail System	LF	44	\$	\$
13	Intentionally Left Blank				
14	Wetwell Liner, spray-on	SF	434	\$	\$
15	Intentionally Left Blank				
16	Intentionally Left Blank				
17	4" Flanged Gate Valve	EA	3	\$	\$
18	4" Flanged Swing Check Valve	EA	2	\$	\$
19	4" D.I. Flanged Pipe	LF	8	\$	\$
20	Ductile Iron Fittings	LB	210	\$	\$
21	4" D.I. Flanged Adapters	EA	1	\$	\$
22	4" Male Aluminum Quick Coupler Adapter	EA	1	\$	\$
23	S.S. Adjustable Valve Supports, flange attachment	EA	2	\$	\$

Bidder Name: _____

Authorized Signature: _____

BID FORM

(Submit in Triplicate)

2014 REHABILITATION OF SATELLITE LIFT STATIONS- GROUP 2

Bid "A" Based on Completion Time of 180 Calendar Days

ITEM NO.	DESCRIPTION	EST. QTY.	U/M	UNIT PRICE	EXTENDED PRICE
24	Intentionally Left Blank				
25	Intentionally Left Blank				
26	Complete Removal of Valve Vault	LS	1	\$	\$
27	Concrete Slab, Valve Assembly	LS	1	\$	\$
28	4" Gate Valve, MJ	EA	1	\$	\$
29	4" PVC Pipe (C900) (Cross/tee to plug valve)	LF	10	\$	\$
30	10" Influent Line Plug	EA	1	\$	\$
31	By-Pass Pumping< 500gpm	LS	1	\$	\$
32	Intentionally Left Blank				
33	Intentionally Left Blank				
34	Intentionally Left Blank				
35	Remove & Replace Electric Meter Can	EA	1	\$	\$
36	Remove & Replace Fused Safety Switch (disconnect)	EA	1	\$	\$
37	Remove & Replace Control Panel	EA	1	\$	\$
38	Remove & Replace 2" Sch 80 PVC Conduit	LF	30	\$	\$
39	Intentionally Left Blank				
40	Remove & Replace Electrical Mounting Structure	EA	1	\$	\$
41	Intentionally Left Blank				
42	Intentionally Left Blank				
43	Intentionally Left Blank				
44	Intentionally Left Blank				
45	Intentionally Left Blank				
46	Intentionally Left Blank				
47	Intentionally Left Blank				
48	MOBILIZATION	LS	1	\$	\$
49	MISCELLANEOUS WORK AND CLEAN UP	LS	1	\$	\$
50	RECORD DRAWINGS	LS	1	\$	\$
	SUBTOTAL (Coral Shores E4- RTU 122 ONLY)				\$

Bidder Name: _____

Authorized Signature: _____

BID FORM

(Submit in Triplicate)

2014 REHABILITATION OF SATELLITE LIFT STATIONS- GROUP 2

Bid "A" Based on Completion Time of 180 Calendar Days

ITEM NO.	DESCRIPTION	EST. QTY.	U/M	UNIT PRICE	EXTENDED PRICE
	58th Ave. W.-RTU 131				
1	Wetwell Cleaning	SF	164	\$	\$
2	Intentionally Left Blank				
3	Intentionally Left Blank				
4	Intentionally Left Blank				
5	Intentionally Left Blank				
6	Intentionally Left Blank				
7	Intentionally Left Blank				
8	Intentionally Left Blank				
9	Intentionally Left Blank				
10	Intentionally Left Blank				
11	Intentionally Left Blank				
12	Intentionally Left Blank				
13	Intentionally Left Blank				
14	Intentionally Left Blank				
15	Intentionally Left Blank				
16	Intentionally Left Blank				
17	Intentionally Left Blank				
18	Intentionally Left Blank				
19	Intentionally Left Blank				
20	Intentionally Left Blank				
21	Intentionally Left Blank				
22	Intentionally Left Blank				
23	Intentionally Left Blank				
24	Intentionally Left Blank				
25	Intentionally Left Blank				
26	Intentionally Left Blank				
27	Intentionally Left Blank				
28	Intentionally Left Blank				
29	Intentionally Left Blank				
30	Intentionally Left Blank				
31	Intentionally Left Blank				
32	Intentionally Left Blank				
33	Intentionally Left Blank				
34	Intentionally Left Blank				
35	Intentionally Left Blank				

Bidder Name: _____

Authorized Signature: _____

BID FORM

(Submit in Triplicate)

2014 REHABILITATION OF SATELLITE LIFT STATIONS- GROUP 2

Bid "A" Based on Completion Time of 180 Calendar Days

ITEM NO.	DESCRIPTION	EST. QTY.	U/M	UNIT PRICE	EXTENDED PRICE
36	Intentionally Left Blank				
37	Intentionally Left Blank				
38	Intentionally Left Blank				
39	Intentionally Left Blank				
40	Intentionally Left Blank				
41	Intentionally Left Blank				
42	Intentionally Left Blank				
43	Intentionally Left Blank				
44	Intentionally Left Blank				
45	Intentionally Left Blank				
46	Ex. Lift Station- Complete Abandonment	LS	1	\$	\$
47	Intentionally Left Blank				
48	MOBILIZATION	LS	1	\$	\$
49	MISCELLANEOUS WORK AND CLEAN UP	LS	1	\$	\$
50	RECORD DRAWINGS	LS	1	\$	\$
	SUBTOTAL (58th Ave W.- RTU 131 ONLY)				\$
	WEST GLENN - RTU 146				
1	Wetwell Cleaning	SF	392	\$	\$
2	4" DR-11 HDPE Wetwell Piping	LF	56	\$	\$
3	4" HDPE Flange Adapters w/ Backup Rings	EA	4	\$	\$
4	4" HDPE Fittings	LB	8	\$	\$
5	BPIU.14 Pump Base Ells	EA	2	\$	\$
6	Pump Base Ell Mounting Plate	EA	2	\$	\$
7	S.S. Pipe Bracing, 6 ft dia.	EA	3	\$	\$
8	Intentionally Left Blank				
9	Intentionally Left Blank				
10	Intentionally Left Blank				
11	Intentionally Left Blank				

Bidder Name: _____

Authorized Signature: _____

BID FORM

(Submit in Triplicate)

2014 REHABILITATION OF SATELLITE LIFT STATIONS- GROUP 2

Bid "A" Based on Completion Time of 180 Calendar Days

ITEM NO.	DESCRIPTION	EST. QTY.	U/M	UNIT PRICE	EXTENDED PRICE
12	2" S.S. Pump Guide Rail System	LF	36	\$	\$
13	Intentionally Left Blank				
14	Wetwell Liner, spray-on	SF	363	\$	\$
15	Intentionally Left Blank				
16	Grout Fill Ex. Drain, abandon	EA	1	\$	\$
17	4" Flanged Gate Valve	EA	3	\$	\$
18	4" Flanged Swing Check Valve	EA	2	\$	\$
19	4" D.I. Flanged Pipe	LF	8	\$	\$
20	Ductile Iron Fittings	LB	210	\$	\$
21	4" D.I. Flanged Adapters	EA	1	\$	\$
22	4" Male Aluminum Quick Coupler Adapter	EA	1	\$	\$
23	S.S. Adjustable Valve Supports, flange attachment	EA	2	\$	\$
24	Abandon Ex. Valve Vault	LS	1	\$	\$
25	Intentionally Left Blank				
26	Intentionally Left Blank				
27	Concrete Slab, Valve Assembly	LS	1	\$	\$
28	4" Gate Valve, MJ	EA	1	\$	\$
29	4" PVC Pipe (C900) (Cross/tee to plug valve)	LF	10	\$	\$
30	8" Influent Line Plug	EA	1	\$	\$
31	By-Pass Pumping< 500gpm	LS	1	\$	\$
32	Water Service	LF	10	\$	\$
33	Install New Backflow, Meter, & hose Bibb Assembly	LS	1	\$	\$
34	Intentionally Left Blank				
35	Intentionally Left Blank				
36	Intentionally Left Blank				
37	Intentionally Left Blank				

Bidder Name: _____

Authorized Signature: _____

BID FORM

(Submit in Triplicate)

2014 REHABILITATION OF SATELLITE LIFT STATIONS- GROUP 2

Bid "A" Based on Completion Time of 180 Calendar Days

ITEM NO.	DESCRIPTION	EST. QTY.	U/M	UNIT PRICE	EXTENDED PRICE
38	Intentionally Left Blank				
39	Intentionally Left Blank				
40	Remove & Replace Electrical Mounting Structure	EA	1	\$	\$
41	Intentionally Left Blank				
42	Washed Shell with Weed Barrier	SY	55	\$	\$
43	6' High Galvanized Fence, per 10' long section	EA	9	\$	\$
44	6' High Galvanized Fence Gate, 6' Long Swing Type	EA	2	\$	\$
45	6' High Galvanized Corner/Gate Post	EA	6	\$	\$
46	Intentionally Left Blank				
47	Driveway Restoration, Concrete (6" min. thick.)	SY	15	\$	\$
48	MOBILIZATION	LS	1	\$	\$
49	MISCELLANEOUS WORK AND CLEAN UP	LS	1	\$	\$
50	RECORD DRAWINGS	LS	1	\$	\$
SUBTOTAL (West Glenn -RTU 146 ONLY)					\$
PINEWOOD VILLAGE - RTU 401					
1	Wetwell Cleaning	SF	291	\$	\$
2	4" DR-11 HDPE Wetwell Piping	LF	43	\$	\$
3	4" HDPE Flange Adapters w/ Backup Rings	EA	4	\$	\$
4	4" HDPE Fittings	LB	8	\$	\$
5	BPIU.14 Pump Base Ells	EA	2	\$	\$
6	Pump Base Ell Mounting Plate	EA	2	\$	\$
7	S.S. Pipe Bracing, 5 ft dia.	EA	2	\$	\$
8	Raise Ex. Wet Well Rim (to replace existing brick riser in WW)	VF	1.0	\$	\$
9	Replace Ex. Wetwell Top Slab	EA	1	\$	\$
10	4" PVC Vent, Sch 80	EA	1	\$	\$

Bidder Name: _____

Authorized Signature: _____

BID FORM

(Submit in Triplicate)

2014 REHABILITATION OF SATELLITE LIFT STATIONS- GROUP 2

Bid "A" Based on Completion Time of 180 Calendar Days

ITEM NO.	DESCRIPTION	EST. QTY.	U/M	UNIT PRICE	EXTENDED PRICE
11	Aluminum Hatch Cover, 36" x 48", Single door (Wetwell)	EA	1	\$	\$
12	2" S.S. Pump Guide Rail System	LF	32	\$	\$
13	Intentionally Left Blank				
14	Wetwell Liner, spray-on	SF	271	\$	\$
15	Intentionally Left Blank				
16	Grout Fill Ex. Drain, abandon	EA	1	\$	\$
17	4" Flanged Gate Valve	EA	3	\$	\$
18	4" Flanged Swing Check Valve	EA	2	\$	\$
19	4" D.I. Flanged Pipe	LF	8	\$	\$
20	Ductile Iron Fittings	LB	210	\$	\$
21	4" D.I. Flanged Adapters	EA	1	\$	\$
22	4" Male Aluminum Quick Coupler Adapter	EA	1	\$	\$
23	S.S. Adjustable Valve Supports, flange attachment	EA	2	\$	\$
24	Abandon Ex. Valve Vault	LS	1	\$	\$
25	Intentionally Left Blank				
26	Intentionally Left Blank				
27	Concrete Slab, Valve Assembly	LS	1	\$	\$
28	4" Gate Valve, MJ	EA	1	\$	\$
29	4" PVC Pipe (C900) (Cross/tee to plug valve)	LF	10	\$	\$
30	6" Influent Line Plug	EA	1	\$	\$
31	By-Pass Pumping< 500gpm	LS	1	\$	\$
32	Intentionally Left Blank				
33	Intentionally Left Blank				
34	Intentionally Left Blank				
35	Intentionally Left Blank				
36	Intentionally Left Blank				

Bidder Name: _____

Authorized Signature: _____

BID FORM

(Submit in Triplicate)

2014 REHABILITATION OF SATELLITE LIFT STATIONS- GROUP 2

Bid "A" Based on Completion Time of 180 Calendar Days

ITEM NO.	DESCRIPTION	EST. QTY.	U/M	UNIT PRICE	EXTENDED PRICE
37	Intentionally Left Blank				
38	Intentionally Left Blank				
39	Intentionally Left Blank				
40	Intentionally Left Blank				
41	Intentionally Left Blank				
42	Washed Shell with Weed Barrier	SY	25	\$	\$
43	6' High Galvanized Fence, per 10' long section	EA	8	\$	\$
44	6' High Galvanized Fence Gate, 8' Long Swing Type	EA	1	\$	\$
45	6' High Galvanized Corner/Gate Post	EA	5	\$	\$
46	Intentionally Left Blank				
47	Intentionally Left Blank				
48	MOBILIZATION	LS	1	\$	\$
49	MISCELLANEOUS WORK AND CLEAN UP	LS	1	\$	\$
50	RECORD DRAWINGS	LS	1	\$	\$
	SUBTOTAL (Pinewood Village -RTU 401 ONLY)				\$
WOODS OF WHITFIELD- RTU 435					
1	Wetwell Cleaning	SF	234	\$	\$
2	4" DR-11 HDPE Wetwell Piping	LF	40	\$	\$
3	4" HDPE Flange Adapters w/ Backup Rings	EA	4	\$	\$
4	4" HDPE Fittings	LB	8	\$	\$
5	BPIU.14 Pump Base Ells	EA	2	\$	\$
6	Pump Base Ell Mounting Plate	EA	2	\$	\$
7	S.S. Pipe Bracing, 4 ft dia.	EA	3	\$	\$
8	Raise Ex. Wet Well Rim	VF	0.7	\$	\$
9	Replace Ex. Wetwell Top Slab	EA	1	\$	\$
10	4" PVC Vent, Sch 80	EA	1	\$	\$

Bidder Name: _____

Authorized Signature: _____

BID FORM

(Submit in Triplicate)

2014 REHABILITATION OF SATELLITE LIFT STATIONS- GROUP 2

Bid "A" Based on Completion Time of 180 Calendar Days

ITEM NO.	DESCRIPTION	EST. QTY.	U/M	UNIT PRICE	EXTENDED PRICE
11	Aluminum Hatch Cover, 36" x 48", Single door (Wetwell)	EA	1	\$	\$
12	2" S.S. Pump Guide Rail System	LF	34	\$	\$
13	Intentionally Left Blank				
14	Wetwell Liner, spray-on	SF	221	\$	\$
15	Intentionally Left Blank				
16	Grout Fill Ex. Drain, abandon	EA	1	\$	\$
17	4" Flanged Gate Valve	EA	3	\$	\$
18	4" Flanged Swing Check Valve	EA	2	\$	\$
19	4" D.I. Flanged Pipe	LF	8	\$	\$
20	Ductile Iron Fittings	LB	300	\$	\$
21	4" D.I. Flanged Adapters	EA	1	\$	\$
22	4" Male Aluminum Quick Coupler Adapter	EA	1	\$	\$
23	S.S. Adjustable Valve Supports, flange attachment	EA	2	\$	\$
24	Abandon Ex. Meter Vault	LS	1	\$	\$
25	Intentionally Left Blank				
26	Intentionally Left Blank				
27	Concrete Slab, Valve Assembly	LS	1	\$	\$
28	4" Gate Valve, MJ	EA	1	\$	\$
29	4" PVC Pipe (C900) (Cross/tee to plug valve)	LF	10	\$	\$
30	8" Influent Line Plug	EA	1	\$	\$
31	By-Pass Pumping< 500gpm	LS	1	\$	\$
32	Water Service	LF	10	\$	\$
33	Intentionally Left Blank				
34	Relocate Ex. Backflow, Meter, & Hose Bibb Assembly	LS	1	\$	\$
35	Intentionally Left Blank				
36	Intentionally Left Blank				

Bidder Name: _____

Authorized Signature: _____

BID FORM

(Submit in Triplicate)

2014 REHABILITATION OF SATELLITE LIFT STATIONS- GROUP 2

Bid "A" Based on Completion Time of 180 Calendar Days

ITEM NO.	DESCRIPTION	EST. QTY.	U/M	UNIT PRICE	EXTENDED PRICE
37	Intentionally Left Blank				
38	Intentionally Left Blank				
39	Intentionally Left Blank				
40	Intentionally Left Blank				
41	Intentionally Left Blank				
42	Washed Shell with Weed Barrier	SY	16	\$	\$
43	6' High Galvanized Fence, per 10' long section	EA	6	\$	\$
44	6' High Galvanized Fence Gate, 6' Long Swing Type	EA	2	\$	\$
45	6' High Galvanized Corner/Gate Post	EA	4	\$	\$
46	Intentionally Left Blank				
47	Intentionally Left Blank				
48	MOBILIZATION	LS	1	\$	\$
49	MISCELLANEOUS WORK AND CLEAN UP	LS	1	\$	\$
50	RECORD DRAWINGS	LS	1	\$	\$
SUBTOTAL (Woods of Whitfield-RTU 435 ONLY)					\$
MEDOR SUBDIVISION - RTU 471					
1	Wetwell Cleaning	SF	304	\$	\$
2	4" DR-11 HDPE Wetwell Piping	LF	38	\$	\$
3	4" HDPE Flange Adapters w/ Backup Rings	EA	4	\$	\$
4	4" HDPE Fittings	LB	8	\$	\$
5	BPIU.14 Pump Base Ells	EA	2	\$	\$
6	Pump Base Ell Mounting Plate	EA	2	\$	\$
7	S.S. Pipe Bracing, 6 ft dia.	EA	2	\$	\$
8	Raise Ex. Wet Well Rim	VF	0.7	\$	\$
9	Intentionally Left Blank				

Bidder Name: _____

Authorized Signature: _____

BID FORM

(Submit in Triplicate)

2014 REHABILITATION OF SATELLITE LIFT STATIONS- GROUP 2

Bid "A" Based on Completion Time of 180 Calendar Days

ITEM NO.	DESCRIPTION	EST. QTY.	U/M	UNIT PRICE	EXTENDED PRICE
10	4" PVC Vent, Sch 80	EA	1	\$	\$
11	Intentionally Left Blank				
12	2" S.S. Pump Guide Rail System	LF	27	\$	\$
13	Resilient (link) Seals w/ Carrier Pipe & Liner Repair	EA	5	\$	\$
14	Wetwell Liner, spray-on	SF	275	\$	\$
15	Remove & Replace Ex. PVC Drain P-trap (regROUT) & Liner Repair	EA	1	\$	\$
16	Intentionally Left Blank				
17	4" Flanged Gate Valve	EA	3	\$	\$
18	4" Flanged Swing Check Valve	EA	2	\$	\$
19	Intentionally Left Blank				
20	Ductile Iron Fittings	LB	170	\$	\$
21	Intentionally Left Blank				
22	4" Male Aluminum Quick Coupler Adapter	EA	1	\$	\$
23	S.S. Adjustable Valve Supports, flange attachment	EA	3	\$	\$
24	Intentionally Left Blank				
25	Raise Ex. Valve Vault Rim	VF	0.7	\$	\$
26	Intentionally Left Blank				
27	Intentionally Left Blank				
28	4" Gate Valve, MJ	EA	1	\$	\$
29	Intentionally Left Blank				
30	8" Influent Line Plug	EA	1	\$	\$
31	By-Pass Pumping< 500gpm	LS	1	\$	\$
32	Water Service	LF	10	\$	\$
33	Install New Backflow, Meter, & Hose bibb Assembly	LS	1	\$	\$
34	Intentionally Left Blank				
35	Intentionally Left Blank				
36	Intentionally Left Blank				
37	Intentionally Left Blank				

Bidder Name: _____

Authorized Signature: _____

BID FORM

(Submit in Triplicate)

2014 REHABILITATION OF SATELLITE LIFT STATIONS- GROUP 2

Bid "A" Based on Completion Time of 180 Calendar Days

ITEM NO.	DESCRIPTION	EST. QTY.	U/M	UNIT PRICE	EXTENDED PRICE
38	Intentionally Left Blank				
39	Intentionally Left Blank				
40	Intentionally Left Blank				
41	Intentionally Left Blank				
42	Washed Shell with Weed Barrier	SY	13	\$	\$
43	Intentionally Left Blank				
44	Intentionally Left Blank				
45	Intentionally Left Blank				
46	Intentionally Left Blank				
47	Intentionally Left Blank				
48	MOBILIZATION	LS	1	\$	\$
49	MISCELLANEOUS WORK AND CLEAN UP	LS	1	\$	\$
50	RECORD DRAWINGS	LS	1	\$	\$
	SUBTOTAL (Medor Subdivision -RTU 471 ONLY)				\$
	TOTAL BASE BID "A" - Based on Completion Time of <u>180</u> Calendar Days				\$ _____
51	CONTRACT CONTINGENCY WORK (USED ONLY WITH COUNTY APPROVAL)		10% OF TOTAL BASE BID		\$ _____
	TOTAL OFFER FOR BID "A" with Contract Contingency - Based on Completion Time of <u>180</u> Calendar Days				\$ _____

Bidder Name: _____

Authorized Signature: _____

BID FORM

(Submit in Triplicate)

2014 REHABILITATION OF SATELLITE LIFT STATIONS- GROUP 2

Bid "B" Based on Completion Time of 240 Calendar Days

ITEM NO.	DESCRIPTION	EST. QTY.	U/M	UNIT PRICE	EXTENDED PRICE
Coral Shores E4- RTU 122					
1	Wetwell Cleaning	SF	463	\$	\$
2	4" DR-11 HDPE Wetwell Piping	LF	56	\$	\$
3	4" HDPE Flange Adapters w/ Backup Rings	EA	4	\$	\$
4	4" HDPE Fittings	LB	8	\$	\$
5	BPIU.14 Pump Base Ells	EA	2	\$	\$
6	Pump Base Ell Mounting Plate	EA	2	\$	\$
7	S.S. Pipe Bracing, 6 ft dia.	EA	3	\$	\$
8	Raise Ex. Wet Well Rim	VF	0.7	\$	\$
9	Replace Ex. Wetwell Top Slab	EA	1	\$	\$
10	4" PVC Vent, Sch 80	EA	1	\$	\$
11	Aluminum Hatch Cover, 36" x 48", Single door (Wetwell)	EA	1	\$	\$
12	2" S.S. Pump Guide Rail System	LF	44	\$	\$
13	Intentionally Left Blank				
14	Wetwell Liner, spray-on	SF	434	\$	\$
15	Intentionally Left Blank				
16	Intentionally Left Blank				
17	4" Flanged Gate Valve	EA	3	\$	\$
18	4" Flanged Swing Check Valve	EA	2	\$	\$
19	4" D.I. Flanged Pipe	LF	8	\$	\$
20	Ductile Iron Fittings	LB	210	\$	\$
21	4" D.I. Flanged Adapters	EA	1	\$	\$
22	4" Male Aluminum Quick Coupler Adapter	EA	1	\$	\$
23	S.S. Adjustable Valve Supports, flange attachment	EA	2	\$	\$

Bidder Name: _____

Authorized Signature: _____

BID FORM

(Submit in Triplicate)

2014 REHABILITATION OF SATELLITE LIFT STATIONS- GROUP 2

Bid "B" Based on Completion Time of 240 Calendar Days

ITEM NO.	DESCRIPTION	EST. QTY.	U/M	UNIT PRICE	EXTENDED PRICE
24	Intentionally Left Blank				
25	Intentionally Left Blank				
26	Complete Removal of Valve Vault	LS	1	\$	\$
27	Concrete Slab, Valve Assembly	LS	1	\$	\$
28	4" Gate Valve, MJ	EA	1	\$	\$
29	4" PVC Pipe (C900) (Cross/tee to plug valve)	LF	10	\$	\$
30	10" Influent Line Plug	EA	1	\$	\$
31	By-Pass Pumping< 500gpm	LS	1	\$	\$
32	Intentionally Left Blank				
33	Intentionally Left Blank				
34	Intentionally Left Blank				
35	Remove & Replace Electric Meter Can	EA	1	\$	\$
36	Remove & Replace Fused Safety Switch (disconnect)	EA	1	\$	\$
37	Remove & Replace Control Panel	EA	1	\$	\$
38	Remove & Replace 2" Sch 80 PVC Conduit	LF	30	\$	\$
39	Intentionally Left Blank				
40	Remove & Replace Electrical Mounting Structure	EA	1	\$	\$
41	Intentionally Left Blank				
42	Intentionally Left Blank				
43	Intentionally Left Blank				
44	Intentionally Left Blank				
45	Intentionally Left Blank				
46	Intentionally Left Blank				
47	Intentionally Left Blank				
48	MOBILIZATION	LS	1	\$	\$
49	MISCELLANEOUS WORK AND CLEAN UP	LS	1	\$	\$
50	RECORD DRAWINGS	LS	1	\$	\$
	SUBTOTAL (Coral Shores E4- RTU 122 ONLY)				\$
58th Ave. W.-RTU 131					

Bidder Name: _____

Authorized Signature: _____

BID FORM

(Submit in Triplicate)

2014 REHABILITATION OF SATELLITE LIFT STATIONS- GROUP 2

Bid "B" Based on Completion Time of 240 Calendar Days

ITEM NO.	DESCRIPTION	EST. QTY.	U/M	UNIT PRICE	EXTENDED PRICE
1	Wetwell Cleaning	SF	164	\$	\$
2	Intentionally Left Blank				
3	Intentionally Left Blank				
4	Intentionally Left Blank				
5	Intentionally Left Blank				
6	Intentionally Left Blank				
7	Intentionally Left Blank				
8	Intentionally Left Blank				
9	Intentionally Left Blank				
10	Intentionally Left Blank				
11	Intentionally Left Blank				
12	Intentionally Left Blank				
13	Intentionally Left Blank				
14	Intentionally Left Blank				
15	Intentionally Left Blank				
16	Intentionally Left Blank				
17	Intentionally Left Blank				
18	Intentionally Left Blank				
19	Intentionally Left Blank				
20	Intentionally Left Blank				
21	Intentionally Left Blank				
22	Intentionally Left Blank				
23	Intentionally Left Blank				
24	Intentionally Left Blank				
25	Intentionally Left Blank				
26	Intentionally Left Blank				
27	Intentionally Left Blank				
28	Intentionally Left Blank				
29	Intentionally Left Blank				
30	Intentionally Left Blank				
31	Intentionally Left Blank				
32	Intentionally Left Blank				
33	Intentionally Left Blank				
34	Intentionally Left Blank				
35	Intentionally Left Blank				

Bidder Name: _____

Authorized Signature: _____

BID FORM

(Submit in Triplicate)

2014 REHABILITATION OF SATELLITE LIFT STATIONS- GROUP 2

Bid "B" Based on Completion Time of 240 Calendar Days

ITEM NO.	DESCRIPTION	EST. QTY.	U/M	UNIT PRICE	EXTENDED PRICE
36	Intentionally Left Blank				
37	Intentionally Left Blank				
38	Intentionally Left Blank				
39	Intentionally Left Blank				
40	Intentionally Left Blank				
41	Intentionally Left Blank				
42	Intentionally Left Blank				
43	Intentionally Left Blank				
44	Intentionally Left Blank				
45	Intentionally Left Blank				
46	Ex. Lift Station- Complete Abandonment	LS	1	\$	\$
47	Intentionally Left Blank				
48	MOBILIZATION	LS	1	\$	\$
49	MISCELLANEOUS WORK AND CLEAN UP	LS	1	\$	\$
50	RECORD DRAWINGS	LS	1	\$	\$
	SUBTOTAL (58th Ave W.- RTU 131 ONLY)				\$
	WEST GLENN - RTU 146				
1	Wetwell Cleaning	SF	392	\$	\$
2	4" DR-11 HDPE Wetwell Piping	LF	56	\$	\$
3	4" HDPE Flange Adapters w/ Backup Rings	EA	4	\$	\$
4	4" HDPE Fittings	LB	8	\$	\$
5	BPIU.14 Pump Base Ells	EA	2	\$	\$
6	Pump Base Ell Mounting Plate	EA	2	\$	\$
7	S.S. Pipe Bracing, 6 ft dia.	EA	3	\$	\$
8	Intentionally Left Blank				
9	Intentionally Left Blank				
10	Intentionally Left Blank				
11	Intentionally Left Blank				

Bidder Name: _____

Authorized Signature: _____

BID FORM

(Submit in Triplicate)

2014 REHABILITATION OF SATELLITE LIFT STATIONS- GROUP 2

Bid "B" Based on Completion Time of 240 Calendar Days

ITEM NO.	DESCRIPTION	EST. QTY.	U/M	UNIT PRICE	EXTENDED PRICE
12	2" S.S. Pump Guide Rail System	LF	36	\$	\$
13	Intentionally Left Blank				
14	Wetwell Liner, spray-on	SF	363	\$	\$
15	Intentionally Left Blank				
16	Grout Fill Ex. Drain, abandon	EA	1	\$	\$
17	4" Flanged Gate Valve	EA	3	\$	\$
18	4" Flanged Swing Check Valve	EA	2	\$	\$
19	4" D.I. Flanged Pipe	LF	8	\$	\$
20	Ductile Iron Fittings	LB	210	\$	\$
21	4" D.I. Flanged Adapters	EA	1	\$	\$
22	4" Male Aluminum Quick Coupler Adapter	EA	1	\$	\$
23	S.S. Adjustable Valve Supports, flange attachment	EA	2	\$	\$
24	Abandon Ex. Valve Vault	LS	1	\$	\$
25	Intentionally Left Blank				
26	Intentionally Left Blank				
27	Concrete Slab, Valve Assembly	LS	1	\$	\$
28	4" Gate Valve, MJ	EA	1	\$	\$
29	4" PVC Pipe (C900) (Cross/tee to plug valve)	LF	10	\$	\$
30	8" Influent Line Plug	EA	1	\$	\$
31	By-Pass Pumping< 500gpm	LS	1	\$	\$
32	Water Service	LF	10	\$	\$
33	Install New Backflow, Meter, & hose Bibb Assembly	LS	1	\$	\$
34	Intentionally Left Blank				
35	Intentionally Left Blank				
36	Intentionally Left Blank				
37	Intentionally Left Blank				

Bidder Name: _____

Authorized Signature: _____

BID FORM

(Submit in Triplicate)

2014 REHABILITATION OF SATELLITE LIFT STATIONS- GROUP 2

Bid "B" Based on Completion Time of 240 Calendar Days

ITEM NO.	DESCRIPTION	EST. QTY.	U/M	UNIT PRICE	EXTENDED PRICE
38	Intentionally Left Blank				
39	Intentionally Left Blank				
40	Remove & Replace Electrical Mounting Structure	EA	1	\$	\$
41	Intentionally Left Blank				
42	Washed Shell with Weed Barrier	SY	55	\$	\$
43	6' High Galvanized Fence, per 10' long section	EA	9	\$	\$
44	6' High Galvanized Fence Gate, 6' Long Swing Type	EA	2	\$	\$
45	6' High Galvanized Corner/Gate Post	EA	6	\$	\$
46	Intentionally Left Blank				
47	Driveway Restoration, Concrete (6" min. thick.)	SY	15	\$	\$
48	MOBILIZATION	LS	1	\$	\$
49	MISCELLANEOUS WORK AND CLEAN UP	LS	1	\$	\$
50	RECORD DRAWINGS	LS	1	\$	\$
SUBTOTAL (West Glenn -RTU 146 ONLY)					\$
PINEWOOD VILLAGE - RTU 401					
1	Wetwell Cleaning	SF	291	\$	\$
2	4" DR-11 HDPE Wetwell Piping	LF	43	\$	\$
3	4" HDPE Flange Adapters w/ Backup Rings	EA	4	\$	\$
4	4" HDPE Fittings	LB	8	\$	\$
5	BPIU.14 Pump Base Ells	EA	2	\$	\$
6	Pump Base Ell Mounting Plate	EA	2	\$	\$
7	S.S. Pipe Bracing, 5 ft dia.	EA	2	\$	\$
8	Raise Ex. Wet Well Rim (to replace existing brick riser in WW)	VF	1.0	\$	\$
9	Replace Ex. Wetwell Top Slab	EA	1	\$	\$
10	4" PVC Vent, Sch 80	EA	1	\$	\$

Bidder Name: _____

Authorized Signature: _____

BID FORM

(Submit in Triplicate)

2014 REHABILITATION OF SATELLITE LIFT STATIONS- GROUP 2

Bid "B" Based on Completion Time of 240 Calendar Days

ITEM NO.	DESCRIPTION	EST. QTY.	U/M	UNIT PRICE	EXTENDED PRICE
11	Aluminum Hatch Cover, 36" x 48", Single door (Wetwell)	EA	1	\$	\$
12	2" S.S. Pump Guide Rail System	LF	32	\$	\$
13	Intentionally Left Blank				
14	Wetwell Liner, spray-on	SF	271	\$	\$
15	Intentionally Left Blank				
16	Grout Fill Ex. Drain, abandon	EA	1	\$	\$
17	4" Flanged Gate Valve	EA	3	\$	\$
18	4" Flanged Swing Check Valve	EA	2	\$	\$
19	4" D.I. Flanged Pipe	LF	8	\$	\$
20	Ductile Iron Fittings	LB	210	\$	\$
21	4" D.I. Flanged Adapters	EA	1	\$	\$
22	4" Male Aluminum Quick Coupler Adapter	EA	1	\$	\$
23	S.S. Adjustable Valve Supports, flange attachment	EA	2	\$	\$
24	Abandon Ex. Valve Vault	LS	1	\$	\$
25	Intentionally Left Blank				
26	Intentionally Left Blank				
27	Concrete Slab, Valve Assembly	LS	1	\$	\$
28	4" Gate Valve, MJ	EA	1	\$	\$
29	4" PVC Pipe (C900) (Cross/tee to plug valve)	LF	10	\$	\$
30	6" Influent Line Plug	EA	1	\$	\$
31	By-Pass Pumping< 500gpm	LS	1	\$	\$
32	Intentionally Left Blank				
33	Intentionally Left Blank				
34	Intentionally Left Blank				
35	Intentionally Left Blank				
36	Intentionally Left Blank				

Bidder Name: _____

Authorized Signature: _____

BID FORM

(Submit in Triplicate)

2014 REHABILITATION OF SATELLITE LIFT STATIONS- GROUP 2

Bid "B" Based on Completion Time of 240 Calendar Days

ITEM NO.	DESCRIPTION	EST. QTY.	U/M	UNIT PRICE	EXTENDED PRICE
37	Intentionally Left Blank				
38	Intentionally Left Blank				
39	Intentionally Left Blank				
40	Intentionally Left Blank				
41	Intentionally Left Blank				
42	Washed Shell with Weed Barrier	SY	25	\$	\$
43	6' High Galvanized Fence, per 10' long section	EA	8	\$	\$
44	6' High Galvanized Fence Gate, 8' Long Swing Type	EA	1	\$	\$
45	6' High Galvanized Corner/Gate Post	EA	5	\$	\$
46	Intentionally Left Blank				
47	Intentionally Left Blank				
48	MOBILIZATION	LS	1	\$	\$
49	MISCELLANEOUS WORK AND CLEAN UP	LS	1	\$	\$
50	RECORD DRAWINGS	LS	1	\$	\$
	SUBTOTAL (Pinewood Village -RTU 401 ONLY)				\$
WOODS OF WHITFIELD- RTU 435					
1	Wetwell Cleaning	SF	234	\$	\$
2	4" DR-11 HDPE Wetwell Piping	LF	40	\$	\$
3	4" HDPE Flange Adapters w/ Backup Rings	EA	4	\$	\$
4	4" HDPE Fittings	LB	8	\$	\$
5	BPIU.14 Pump Base Ells	EA	2	\$	\$
6	Pump Base Ell Mounting Plate	EA	2	\$	\$
7	S.S. Pipe Bracing, 4 ft dia.	EA	3	\$	\$
8	Raise Ex. Wet Well Rim	VF	0.7	\$	\$
9	Replace Ex. Wetwell Top Slab	EA	1	\$	\$
10	4" PVC Vent, Sch 80	EA	1	\$	\$

Bidder Name: _____

Authorized Signature: _____

BID FORM

(Submit in Triplicate)

2014 REHABILITATION OF SATELLITE LIFT STATIONS- GROUP 2

Bid "B" Based on Completion Time of 240 Calendar Days

ITEM NO.	DESCRIPTION	EST. QTY.	U/M	UNIT PRICE	EXTENDED PRICE
11	Aluminum Hatch Cover, 36" x 48", Single door (Wetwell)	EA	1	\$	\$
12	2" S.S. Pump Guide Rail System	LF	34	\$	\$
13	Intentionally Left Blank				
14	Wetwell Liner, spray-on	SF	221	\$	\$
15	Intentionally Left Blank				
16	Grout Fill Ex. Drain, abandon	EA	1	\$	\$
17	4" Flanged Gate Valve	EA	3	\$	\$
18	4" Flanged Swing Check Valve	EA	2	\$	\$
19	4" D.I. Flanged Pipe	LF	8	\$	\$
20	Ductile Iron Fittings	LB	300	\$	\$
21	4" D.I. Flanged Adapters	EA	1	\$	\$
22	4" Male Aluminum Quick Coupler Adapter	EA	1	\$	\$
23	S.S. Adjustable Valve Supports, flange attachment	EA	2	\$	\$
24	Abandon Ex. Meter Vault	LS	1	\$	\$
25	Intentionally Left Blank				
26	Intentionally Left Blank				
27	Concrete Slab, Valve Assembly	LS	1	\$	\$
28	4" Gate Valve, MJ	EA	1	\$	\$
29	4" PVC Pipe (C900) (Cross/tee to plug valve)	LF	10	\$	\$
30	8" Influent Line Plug	EA	1	\$	\$
31	By-Pass Pumping < 500gpm	LS	1	\$	\$
32	Water Service	LF	10	\$	\$
33	Intentionally Left Blank				
34	Relocate Ex. Backflow, Meter, & Hose Bibb Assembly	LS	1	\$	\$

Bidder Name: _____

Authorized Signature: _____

BID FORM

(Submit in Triplicate)

2014 REHABILITATION OF SATELLITE LIFT STATIONS- GROUP 2

Bid "B" Based on Completion Time of 240 Calendar Days

ITEM NO.	DESCRIPTION	EST. QTY.	U/M	UNIT PRICE	EXTENDED PRICE
35	Intentionally Left Blank				
36	Intentionally Left Blank				
37	Intentionally Left Blank				
38	Intentionally Left Blank				
39	Intentionally Left Blank				
40	Intentionally Left Blank				
41	Intentionally Left Blank				
42	Washed Shell with Weed Barrier	SY	16	\$	\$
43	6' High Galvanized Fence, per 10' long section	EA	6	\$	\$
44	6' High Galvanized Fence Gate, 6' Long Swing Type	EA	2	\$	\$
45	6' High Galvanized Corner/Gate Post	EA	4	\$	\$
46	Intentionally Left Blank				
47	Intentionally Left Blank				
48	MOBILIZATION	LS	1	\$	\$
49	MISCELLANEOUS WORK AND CLEAN UP	LS	1	\$	\$
50	RECORD DRAWINGS	LS	1	\$	\$
SUBTOTAL (Woods of Whitfield-RTU 435 ONLY)					\$
MEDOR SUBDIVISION - RTU 471					
1	Wetwell Cleaning	SF	304	\$	\$
2	4" DR-11 HDPE Wetwell Piping	LF	38	\$	\$
3	4" HDPE Flange Adapters w/ Backup Rings	EA	4	\$	\$
4	4" HDPE Fittings	LB	8	\$	\$
5	BPIU.14 Pump Base Ells	EA	2	\$	\$
6	Pump Base Ell Mounting Plate	EA	2	\$	\$
7	S.S. Pipe Bracing, 6 ft dia.	EA	2	\$	\$
8	Raise Ex. Wet Well Rim	VF	0.7	\$	\$
9	Intentionally Left Blank				

Bidder Name: _____

Authorized Signature: _____

BID FORM

(Submit in Triplicate)

2014 REHABILITATION OF SATELLITE LIFT STATIONS- GROUP 2

Bid "B" Based on Completion Time of 240 Calendar Days

ITEM NO.	DESCRIPTION	EST. QTY.	U/M	UNIT PRICE	EXTENDED PRICE
10	4" PVC Vent, Sch 80	EA	1	\$	\$
11	Intentionally Left Blank				
12	2" S.S. Pump Guide Rail System	LF	27	\$	\$
13	Resilient (link) Seals w/ Carrier Pipe & Liner Repair	EA	5	\$	\$
14	Wetwell Liner, spray-on	SF	275	\$	\$
15	Remove & Replace Ex. PVC Drain P-trap (regROUT) & Liner Repair	EA	1	\$	\$
16	Intentionally Left Blank				
17	4" Flanged Gate Valve	EA	3	\$	\$
18	4" Flanged Swing Check Valve	EA	2	\$	\$
19	Intentionally Left Blank				
20	Ductile Iron Fittings	LB	170	\$	\$
21	Intentionally Left Blank				
22	4" Male Aluminum Quick Coupler Adapter	EA	1	\$	\$
23	S.S. Adjustable Valve Supports, flange attachment	EA	3	\$	\$
24	Intentionally Left Blank				
25	Raise Ex. Valve Vault Rim	VF	0.7	\$	\$
26	Intentionally Left Blank				
27	Intentionally Left Blank				
28	4" Gate Valve, MJ	EA	1	\$	\$
29	Intentionally Left Blank				
30	8" Influent Line Plug	EA	1	\$	\$
31	By-Pass Pumping< 500gpm	LS	1	\$	\$
32	Water Service	LF	10	\$	\$
33	Install New Backflow, Meter, & Hose bibb Assembly	LS	1	\$	\$
34	Intentionally Left Blank				
35	Intentionally Left Blank				
36	Intentionally Left Blank				

Bidder Name: _____

Authorized Signature: _____

BID FORM

(Submit in Triplicate)

2014 REHABILITATION OF SATELLITE LIFT STATIONS- GROUP 2

Bid "B" Based on Completion Time of 240 Calendar Days

ITEM NO.	DESCRIPTION	EST. QTY.	U/M	UNIT PRICE	EXTENDED PRICE
37	Intentionally Left Blank				
38	Intentionally Left Blank				
39	Intentionally Left Blank				
40	Intentionally Left Blank				
41	Intentionally Left Blank				
42	Washed Shell with Weed Barrier	SY	13	\$	\$
43	Intentionally Left Blank				
44	Intentionally Left Blank				
45	Intentionally Left Blank				
46	Intentionally Left Blank				
47	Intentionally Left Blank				
48	MOBILIZATION	LS	1	\$	\$
49	MISCELLANEOUS WORK AND CLEAN UP	LS	1	\$	\$
50	RECORD DRAWINGS	LS	1	\$	\$
	SUBTOTAL (Medor Subdivision -RTU 471 ONLY)				\$
	TOTAL BASE BID "B" - Based on Completion Time of <u>240</u> Calendar Days				\$ _____
51	CONTRACT CONTINGENCY WORK (USED ONLY WITH COUNTY APPROVAL)			10% OF TOTAL BASE BID	\$ _____
	TOTAL OFFER FOR BID "A" with Contract Contingency - Based on Completion Time of <u>240</u> Calendar Days				\$ _____

Bidder Name: _____

Authorized Signature: _____

BID ITEM NO. 47: DRIVEWAY

Measurement shall be per square yards of installed driveway.

Payment will be for the actual square yards of driveway installed and accepted.

Payment for all work included in these Bid Items will be made at the applicable contract unit bid price per square yard of shell, asphaltic concrete, or concrete driveway restoration as listed on the Bid Form. Disturbed driveways shall be replaced or restored in accordance with the latest Manatee County Transportation Department Highway Standards.

The unit bid price shall include, but is not limited to, all labor, materials and equipment for cutting the edges of existing driveways/pavement/curbing, compacting subgrade, furnishing and installing the shell, asphaltic concrete or concrete and all incidentals necessary to complete these bid items ready for approval and acceptance by the County.

BID ITEM NO. 48: MOBILIZATION

Measurement and payment for this Bid Item shall include full compensation for the required 100 percent (100%) Performance Bond, 100 Percent (100%) Payment Bond, all required insurance for the project and the Contractor's mobilization and demobilization costs as shown in the Bid Form. Mobilization includes, but it not limited to: preparation and movement of personnel, contractor's equipment required for product installation, supplies and incidentals such as safety and sanitary supplies/ facilities.

Payment for mobilization shall not exceed 10 percent (10%) of the total Contract cost, but shall exclude the material cost of the emergency pump(s), emergency generator(s), and automatic transfer switch(es) (ATS), unless the Contractor can prove to the County that his actual mobilization cost exceeds 10 percent (10%).

Partial payments for this Bid Item will be made in accordance with the following schedule:

Percent of Original Contract Amount:	Percent Allowable Payment of Mobilization/Demobilization Bid Item Price:
5	25
10	35
25	45
50	50
75	75
100	100

These payments will be subject to the standard retainage provided in the Contract. Payment of the retainage will be made after completion of the work and demobilization.

BID ITEM NO. 49: MISCELLANEOUS WORK & CLEANUP

Payment for all work included under this Bid Item shall be made at the Contract lump sum price bid listed in the Bid Form for any other miscellaneous work not specifically included for payment under other Bid Items obviously necessary to complete the Contract. Partial payments will be based on the breakdown of the Bid Item in accordance with the Schedule of Values submitted by the Contractor and approved by the County. Payment shall also

include, but not limited to, full compensation for project photographs, project signs, traffic control, rubbish and spoil removal, repair, replacement or relocation of all signs, walls, private irrigation systems and related items and any and all other items required to complete the project in accordance with Contract Documents.

BID ITEM NO. 50: RECORD DRAWINGS

Payment for all work included under this Bid Item shall be made at the Contract lump sum price bid listed in the Bid Form and shall represent full compensation for all labor, materials and equipment required to generate and provide record drawings approved by the County. Record drawings shall be in strict accordance with Section 14 of the Manatee County Public Work Utility Standards. Record drawings shall be required when the top slabs of the existing structures are modified/raised/relocated and/or the alignment/elevation of more than 10 feet of the existing force main has been changed. The Vertical Datum is to be NAVD 1988 and the survey notes shall include the relationship to NGVD 1929 and the method of conversion.

BID ITEM NO. 51: CONTRACT CONTINGENCY

Payment for all work under this Bid Item shall be made only at the County's discretion. This Bid Item shall not exceed 10% of the Bidders Total Base Bid. The Bidder shall calculate and enter a dollar amount for this Bid Item.

PART 2 PRODUCTS (NOT USED)

PART 3 EXECUTION (NOT USED)

END OF SECTION