



Financial Management Department  
Purchasing Division  
1112 Manatee Ave W Suite 803  
Bradenton, FL 34205  
Phone: (941) 749-3074  
www.mymanatee.org

email

January 22, 2015

TO: All Interested Bidders

SUBJECT: Invitation for Bid #15-0015DC  
MSO Fish Hatchery Electrical System

**ADDENDUM #2**

**Bidders are hereby notified that this Addendum shall be acknowledged on the Bid Form and made a part of the above named bidding and contract documents.**

1. Question: Why does the drawing show new underground service from utility pole transformer to new meter can?

Response: The Utility service will have to be pulled from the transformer if a new service is being pulled in. Remember the power cannot but turned off for a period greater than 20-30 minutes as specified on the plans.

2. Question: Discuss losing the NEMA 6 gear to be relocated with motor disconnects within site (Code).

Response:

- NEMA 6 is only specified for a single panel (B).
- NEMA 3R is good for the rest of the equipment unless in a spray wash area. We don't want anything to be spray washed unless it is NEMA 6. Disconnects can be NEMA 3R as long as they are within sight.

If you have submitted a bid prior to receiving this addendum you may request in writing that your original, sealed bid be returned to your firm. All sealed bids received will be opened on the date stated.

Bids will be received at Manatee County Purchasing, 1112 Manatee Avenue West, Suite 803, Bradenton, Florida 34205 until **January 23, 2015 at 3:00 P.M.**

Sincerely,