



Financial Management Department
Purchasing Division
1112 Manatee Avenue West, Ste 803
Bradenton, FL 34205

June 22, 2015

TO: All Interested Bidders

SUBJECT: Invitation for Bid# 15-1519-DS
Manatee Agricultural Reuse Supply Management (MARS)
Improvements

ADDENDUM #6

Bidders are hereby notified that this Addendum shall be acknowledged on page Bid Form-1 of the Bid Form and made a part of the above named bidding and contract documents. Bids submitted without acknowledgement of the Addendum will be considered incomplete.

The following items are issued to add to, modify, and clarify the bid and contract documents. These items shall have the same force and effect as the original bidding and contract documents, and cost involved shall be included in the bid prices. Bids to be submitted on the specific bid date, shall conform to the additions and revisions listed herein.

The deadline for clarification of questions was **May 14, 2015 at 3:00 pm**. This deadline had been established to maintain fair treatment of all potential bidders. Questions received after this date and time shall not be considered.

Question 1 With reference to the bypass pumping as indicated in the two responses from addendum #5, can the Owner provide the current/anticipated flows at both the Rye Road Booster PS and the SWWRF Site? Additionally, are there any other sites that will require the GC to maintain current operations by installation of a temporary bypass pumping system?

Response 1 Rye Road Booster Pump Station -The flow in the MARS pipeline outside of the Rye Road pump station can vary based on system demands and flow transferring. A temporary bypass pipe that matches the existing pipe diameter will provide adequate capacity. Pumping is not anticipated as necessary to accomplish the bypass.

SEWRF, SWWRF, NWRF plant water booster stations – A temporary bypass pipe that matches the existing pipe diameter will provide adequate capacity. Pumping is not anticipated as necessary to accomplish the bypasses.

**Response 1
(Continued)**

Remote Locations - It is anticipated that adequate coordination with the County and remote users with regards to disruption of service will preclude the need to bypass at these locations.

This clarification does not preclude the Contractor from identifying and installing bypass systems as they see necessary to complete the work.

The deadline for submitting sealed Bids at the Manatee County Purchasing Division, 1112 Manatee Avenue West, Suite 803, Bradenton, FL 34205 is **June 26, 2015 at 3:00 PM.**

No further extensions or questions will be addressed.

END OF ADDENDUM # 6

Sincerely,



Melissa M. Wendel, CPPO *for*
Purchasing Official
/ds