



July 9, 2015

TO: All Interested Quoters

SUBJECT: ADDENDUM #1 – RFQ #15-1982BLS
Resurface Concrete Tennis Courts (#5-8 and #9-12)
Request for Quotation Due Date: July 15, 2015 at 3:00pm

Quoters are hereby notified that this addendum shall be acknowledged within their quote and shall be made a part of the above issued Request for Quotation. This information is issued to add to, modify, and/or clarify the Request for Quotation documents. These items shall have the same force and effect as the original Request for Quotation. Quotes are to be submitted on the specified date and shall conform to the additions and revisions listed herein.

Question: Will “or equivalent” manufacturer / products be accepted?

Answer: Manatee County has selected SportMaster Sport Surfaces. An equivalent product shall not be accepted.

Question: What are the County’s expectations regarding the large expansion cracks?

Answer: The County requires the large expansion cracks to be cleaned, packed, and the cracks to be ground smooth using a concrete diamond grinder and resurfaced. The County is aware that spider cracks may appear immediately following surface preparation and application repairs. All delivery, storage, handling, execution of repairs, surface preparation and application shall be in accordance with manufacturer’s instructions.

Question: What are the County’s expectations regarding the existing large spider cracks?

Answer: The County requires the large spider cracks to be flattened using a concrete diamond grinder and resurfaced. The County is aware that small spider cracks may appear immediately following surface preparation and application repairs. All delivery, storage, handling, execution of repairs, surface preparation and application shall be in accordance with manufacturer’s instructions.

Question: What are the County's expectations regarding areas of missing concrete?

Answer: The County requires the areas of missing concrete to be cleaned out and patched. The County is aware that small spider cracks may appear immediately following surface preparation and application repairs. All delivery, storage, handling, execution of repairs, surface preparation and application shall be in accordance with manufacturer's instructions.

Question: Will Manatee County choose a "normal" surface color?

Answer: Manatee County shall select "ice blue" and "green". Color identification numbers shall be finalized with the awarded quoter.

Revise: **Part 3 – Execution – 3.1D**

All phases of work shall be monitored and approved by a SportMaster Representative and / or the Manatee County Construction Coordinator. All work shall be completed in accordance with manufacturer's specifications, guidelines, and recommendations. Awarded quoter shall schedule all construction work with the Manatee County Construction Coordinator. Awarded quoter shall not be compensated for any work completed if a SportMaster Representative and / or the Manatee County Construction Coordinator is not present. Awarded quoter shall not be compensated for any work completed if work is not executed in accordance with manufacturer's specifications, guidelines, and recommendations.



Bonnie Sietman
Purchasing, Senior Buyer

7/10/2015

Date

/bls