



Financial Management Department  
Purchasing Division  
1112 Manatee Ave W Suite 803  
Bradenton, FL 34205-7804  
Phone: (941) 745-3730  
www.mymanatee.org

January 6, 2016

TO: All Interested Quoters

SUBJECT: **ADDENDUM #1- RFO #16-0262CB - Maintenance Services for Water Chemistry to Chillers, Cooling Tower Systems, and Water Softeners**

**This information is issued to modify, and/or clarify the request for quotation document.**

**Item #1 - Minimum Technical Specifications,**

Modify the first sentence under DESCRIPTION OF THE WORK (page 10): "The vendor shall perform a complete monthly inspection of the chiller loops at each of the different facilities listed."

Q1: Will I be allowed to reach out to the specific site contact for system information, particularly Chiller tonnage and system volumes?

A1: Yes, however the system volumes may not be known.

Q2: Related to the water softeners, are you looking for hardness testing only or equipment servicing as well?

A2: We are mainly looking for hardness testing. We may reach out to the awarded vendor, if they are qualified to make these repairs, to have this repaired on a Time and Material basis if repairs are required.

Charles Bentley, Buyer  
Purchasing Division

1-6-2016  
Date