



Financial Management Department  
Purchasing Division  
1112 Manatee Avenue West, Ste 803  
Bradenton, FL 34205  
Phone: (941) 749-3044  
george.earnest@mymanatee.org  
www.mymanatee.org

October 12, 2016

**IFB 16-2912GE: Bradenton Area Convention Center Generator  
ADDENDUM 2**

The following addendum is issued to add to, modify, and/or clarify the above named solicitation documents. The items contained within this Addendum shall have the same force and effect as if contained within the first issued solicitation document and any cost involved shall be factored into the response. Bidders shall acknowledge receipt of this and any other addenda issued pursuant to this Invitation for Bids (IFB) in their bid submittal.

Question 1: Confirm the required fuel tank size and run time.

**Response 1: The run time is 48 hours and the fuel tank shall be sized to provide the 48 hour run time.**

Question 2: Who will remove the diesel fuel in the existing tank?

**Response 2: The County will be responsible to transfer the existing fuel from the old tank into the new tank. If this process interferes with the project the County will remove the fuel and use it elsewhere.**

Question 3: What will be done with the existing tank?

**Response 3: The County intends to remove the tank and use it elsewhere.**

Question 4: Will the County provide the Final Construction, 2<sup>nd</sup> Elevation Certification?

**Response 4: Yes, the County will provide this with two weeks' notice from the Contractor to schedule our service providers.**

**Note: A Tier 4 Generator meeting local jurisdiction wind loading is allowed. The generator is not required to meet Miami-Dade wind loading.**

Sincerely,

George Earnest CPPB  
Buyer, Purchasing