



Financial Management Department  
Purchasing Division  
1112 Manatee Ave W Suite 803  
Bradenton, FL 34205  
Phone: (941) 749-3074  
[www.mymanatee.org](http://www.mymanatee.org)

Email

November 1, 2016

TO: All Interested Bidders

SUBJECT: Invitation for Bid (IFB) #16-2802DC  
MLS Tara 20 Rehabilitation

ADDENDUM #2

**Bidders are hereby notified that this Addendum shall be acknowledged on the Bid Form and made a part of the above named bidding and contract documents.**

1. Bid Opening is extended to **3:00 P.M., November 10, 2016**, same location.
2. The sluice gate does not have to be specific to a manufacturer; but, comparable to the Detail on plans Sheet 5 of 5 with the minimum requirements:
  - a. Manually operated.
  - b. Manufactured of material suitable for a wastewater wet well - 316 stainless steel, EPDM rubber seals, etc.
  - c. Stop the flow of wastewater from the flow splitter box into adjacent wet well.
  - d. Meet AWWA 501 requirements.

If you have submitted a bid prior to receiving this addendum you may request in writing that your original, sealed bid be returned to your firm. All sealed bids received will be opened on the date stated.

Bids will be received at Manatee County Purchasing, 1112 Manatee Avenue West, Suite 803, Bradenton, Florida 34205 until **3:00 P.M., November 10, 2016**.

Sincerely,

*Don* Melissa M. Wendel, CPPO  
Purchasing Official

/dcr