



# Florida Department of Environmental Protection

Southwest District Office  
13051 North Telecom Parkway  
Temple Terrace, Florida 33637-0926

Rick Scott  
Governor

Carlos Lopez-Cantera  
Lt. Governor

Jonathan P. Steverson  
Secretary

## Notification of Acceptance of Use of a General Permit

**PERMITTEE:**

Manatee County Public Works Department  
Sia Mollanazar, P.E.  
Deputy Director of Engineering  
1022 26<sup>th</sup> Avenue East  
Bradenton, FL 34208  
[sia.mollanazar@mymanatee.org](mailto:sia.mollanazar@mymanatee.org)

**Permit Number:** 133068-1177-DSGP/02

**Issue Date:** August 25, 2016

**Expiration Date:** August 24, 2021

**County:** Manatee

**Project Name:** 63rd Street E Water Main  
from 61st St E to SR 70

**Water Supplier:** Manatee County Public  
Works Department

**PWS ID:** 641-1132

Dear Mr. Mollanazar:

On August 23, 2016, the Florida Department of Environmental Protection received a "Notice of Intent to Use the General Permit for Construction of Water Main Extensions for PWSs" [DEP Form No. 62-555.900(7)], under the provisions of Rule 62-4.530 and Chapter 62-555, Florida Administrative Code (F.A.C.). The proposed project includes the construction of new 12-inch and 8-inch diameter water main along 63<sup>rd</sup> Street E.

Based upon the submitted Notice and accompanying documentation, this correspondence is being sent to advise that the Department does not object to the use of such general permit at this time. Please be advised that the permittee is required to abide by Rule 62-555.405, F.A.C., all applicable rules in Chapters 62-4, 62-550, 62-555, F.A.C., and the General Conditions for All General Drinking Water Permits (found in 62-4.540, F.A.C.).

The permittee shall comply with all sampling requirements specific to this project. These requirements are attached for review and implementation.

Pursuant to Rule 62-555.345, F.A.C., the permittee shall submit a certification of construction completion [DEP Form No. 62-555.900(9)] to the Department and obtain approval, or clearance, from the Department before placing any water main extension constructed under this general permit into operation for any purpose other than disinfection or testing for leaks.

Permittee:  
Manatee County Public Works Department  
Page 2

DEP File No.:  
133068-1177-DSGP/02

Within 30 days after the sale or legal transfer of ownership of the permitted project that has not been cleared for service in total by the Department, both the permittee and the proposed permittee shall sign and submit an application for transfer of the permit using Form 62-555.900(8), F.A.C., with the appropriate fee. The permitted construction is not authorized past the 30-day period unless the permit has been transferred.

This permit will expire five years from the date of issuance. If the project has been started and not completed by that time, a new permit must be obtained before the expiration date in order to continue work on the project, per Rule 62-4.030, F.A.C.

STATE OF FLORIDA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION



---

For Pamala Vazquez  
Program Administrator  
Permitting & Waste Cleanup Program  
Southwest District

Enclosures: Clearance Requirements/Utilities Separation Requirements

cc: Anthony Benitez, P.E., Manatee Co Public Works Dept., [anthony.benitez@mymanatee.org](mailto:anthony.benitez@mymanatee.org)  
Mike Gore, Manatee Co Public Works Dept., [mike.gore@mymanatee.org](mailto:mike.gore@mymanatee.org)  
Kenneth Labarr, Manatee Co Public Works Dept., [kenneth.labarr@mymanatee.org](mailto:kenneth.labarr@mymanatee.org)  
Jim Stockwell, P.E., Manatee Co Public Works Dept., [jim.stockwell@mymanatee.org](mailto:jim.stockwell@mymanatee.org)

**A Civil Penalty May Be Incurred**  
**if this project is placed into operation before obtaining a clearance from this office.**

Requirements for clearance upon completion of projects are as follows:

**1) Clearance Form**

Submission of a fully completed Department of Environmental Protection (DEP) Form 62-555.900(9) *Certification of Construction Completion and Request for Clearance to Place Permitted PWS Components into Operation.*

**2) Record Drawings, if deviations were made**

Submission of the portion of record drawings showing deviations from the DEP construction permit, including preliminary design report or drawings and specifications, if there are any deviations from said permit (Note that it is necessary to submit a copy of only the portion of record drawings showing deviations and not a complete set of record drawings.).










**3) Bacteriological Results**

Copies of satisfactory bacteriological analysis (a.k.a. Main Clearance), taken within sixty (60) days of completion of construction, from locations within the distribution system or water main extension to be cleared, in accordance with Rules 62-555.315(6), 62-555.340, and 62-555.330, F.A.C. and American Water Works Association (AWWA) Standard C 651-92, as follows:

- Connection to an existing system
- The end point of the proposed addition
- Any water lines branching off a main extension
- Every 1,200 feet on straight runs of pipe

Each location shall be sampled on two consecutive days, at least 6 hours apart, with sample points and chlorine residual readings clearly indicated on the report. A sketch or description of all bacteriological sampling locations must also be provided.

**LOCATION OF PUBLIC WATER SYSTEM MAINS IN ACCORDANCE WITH F.A.C. RULE 62-555.314**

Other Pipe	Horizontal Separation	Crossings (1)	Joint Spacing @ Crossings (Full Joint Centered) Alternate 3 ft. minimum
Storm Sewer, Stormwater Force Main, Reclaimed Water (2)	 <p>Water Main 3 ft. minimum</p>	 <p>Water Main 12 inches is the minimum, except for storm sewer, then 6 inches is the minimum and 12 inches is preferred</p>	 <p>Water Main Alternate 3 ft. minimum</p>
Vacuum Sanitary Sewer	 <p>Water Main 10 ft. preferred 3 ft. minimum</p>	 <p>Water Main 12 inches preferred 6 inches minimum</p>	 <p>Water Main Alternate 3 ft. minimum</p>
Gravity or Pressure Sanitary Sewer, Sanitary Sewer Force Main, Reclaimed Water (4)	 <p>Water Main 10 ft. preferred 6 ft. minimum (3)</p>	 <p>Water Main 12 inches is the minimum, except for gravity sewer, then 6 inches is the minimum and 12 inches is preferred</p>	 <p>Water Main Alternate 6 ft. minimum</p>
On-Site Sewage Treatment & Infiltration System	10 ft. minimum	---	---

(1) Water main should cross above other pipe. When water main must be below other pipe, the minimum separation is 12 inches.  
 (2) Reclaimed water regulated under Part III of Chapter 62-610, F.A.C.  
 (3) 3 ft. for gravity sanitary sewer where the bottom of the water main is laid at least 6 inches above the top of the gravity sanitary sewer.  
 (4) Reclaimed water not regulated under Part III of Chapter 62-610, F.A.C.