



Financial Management Department
Purchasing Division
1112 Manatee Ave W Suite 803
Bradenton, FL 34205
Phone: (941) 749-3074
www.mymanatee.org

Email

October 2, 2017

TO: All Interested Bidders

SUBJECT: Invitation for Bid (IFB) #17-1641DC
Phase III Gas Collection Expansion Lena Road Landfill
ADDENDUM 4

Bidders are hereby notified that this Addendum shall be acknowledged and made a part of the above-named bidding and contract documents.

The following items are issued to add to, modify, and/or clarify the bid and contract documents. These items shall have the same force and effect as the original bidding and contract documents, and cost involved shall be included in the bid prices. Bids to be submitted on the specified bid date, shall conform to the additions and revisions listed herein.

The following questions have been presented by potential bidders:

1. QUESTION: ref. Addendum 3, item 7: Will excavated material from the trench excavation be allowed for pipe bedding and backfill?

RESPONSE: Yes, clean excavated material that meets the IFB fill specification may be reused as backfill for the trench.

2. QUESTION: ref. Addendum 3, item 8: Can piping installed along the top deck of the landfill be installed at a minimum of 3 percent slope? We are worried that piping installed at 5 percent minimum on the top deck will cause trench depths to be very deep?

RESPONSE: The required slope on the header piping is 5% minimum as specified and independent of depth. The bids should be prepared accordingly.

Bids will be received at Manatee County Procurement, 1112 Manatee Avenue West, Suite 803, Bradenton, Florida 34205 until **October 4, 2017 at 3:00 P.M.**

Sincerely,

Chris Daley, CPPB, CPPO
Buyer Manager
/dcr