



1112 Manatee Ave. West
Bradenton, FL 34205
purchasing@mymanatee.org

Solicitation Addendum

Addendum No.: 1

Solicitation No.: IFB 18-R067493OV

Project No.: 0008128

Solicitation Title: Palma Sola Yacht Basin Retaining Wall Repair

Addendum Date: November 28, 2017

Procurement Contact: Olga Valcich, (941) 749-3055 – Email: olga.valcich@mymanatee.org

IFB 18-R067493OV, IS AMENDED AS SET FORTH HEREIN. RESPONSES TO QUESTIONS POSED BY PROSPECTIVE BIDDERS ARE PROVIDED BELOW. THIS ADDENDUM IS HEREBY INCORPORATED IN AND MADE A PART OF IFB 18R067493OV.

The Due Date and Time for submission of Bids in response to this Invitation for Bid (IFB) is **December 13, 2017 at 3:00 P.M. ET.** Bids must be delivered to the following location: Manatee County Administration Building, 1112 Manatee Ave. W., Suite 803, Bradenton, FL 34205 prior to the Due Date and Time.

QUESTIONS AND RESPONSES:

Q1. What is the 10 vt of #57 stone for? It is not founded on the plans but is line item 8 on the bid sheet.

R1. Bid Item 8 for Select Bedding Material (#57 Stone) with an estimated quantity of 10 cubic yards, was added to the project to provide the successful contractor a quantity of material to facilitate the placement of fill along the retaining wall in the event of wet conditions, particularly at the locations of the closure pours. Placement of material shall be directed or approved by the Engineer and / or Project Representative.

NOTE: Items that are ~~struck through~~ are deleted. Items that are underlined have been added. All other terms and conditions remain as stated in the <solicitation type>.

End of Addendum

INSTRUCTIONS:

Receipt of this addendum must be acknowledged as instructed in the solicitation document. Failure to acknowledge receipt of this Addendum may result in the response being deemed non-responsive.

AUTHORIZED FOR RELEASE: _____

