



1112 Manatee Ave. West  
Bradenton, FL 34205  
[purchasing@mymanatee.org](mailto:purchasing@mymanatee.org)

## Solicitation Addendum

Addendum No.: 1

Solicitation No.: 18-R067493-1OV

Project No.: 0008128

Solicitation Title: Palma Sola Yacht Basin Retaining Wall Repair (REBID)

Addendum Date: January 12, 2018

Procurement Contact: Olga Valcich, 941-749-3055

**IFB 18-R067493-1OV, Palma Sola Yacht Basin Retaining Wall Repair (REBID) IS AMENDED AS SET FORTH HEREIN. RESPONSES TO QUESTIONS POSED BY PROSPECTIVE BIDDERS ARE PROVIDED BELOW. THIS ADDENDUM IS HEREBY INCORPORATED IN AND MADE A PART OF IFB 18-R067493-1OV. THE DUE DATE AND TIME FOR SUBMISSION OF BIDS IN RESPONSE TO THIS INVITATION FOR BID (IFB) IS JANUARY 24, 2018 3:00 P.M. ET.**

### QUESTIONS AND RESPONSES:

**Q1. Is there a way to adjust the scope of work or to increase the engineered budget to make this project more feasible with the assumed construction method?**

R1. In review of the construction methods and cost estimate, particularly with respect to the concrete closure pours to tie the new sheet pile wall to the existing wall, the method anticipated is to form and pour the concrete utilizing the tremie method to displace the water while preventing intermixing, cement washout and separation of the concrete. No adhesive anchoring is required for this closure pour. In addition, the engineering estimate for the construction has been reviewed and compared with the most recent FDOT bid item averages and was determined to be adequate for the proposed construction. NOTE: This response is not to guide the bidder in their means and methods of construction.

**End of Addendum**

### INSTRUCTIONS:

Receipt of this addendum must be acknowledged as instructed in the solicitation document. Failure to acknowledge receipt of this Addendum may result in the response being deemed non-responsive.

AUTHORIZED FOR RELEASE: 

Addendum No. 1

ITB/18-R067493-1OV

Palma Sola Yacht Basin Retaining Wall Repair