

1112 Manatee Ave. West Bradenton, FL 34205 purchasing@mymanatee.org

**Solicitation Addendum** 

Addendum No.:1Solicitation No.:18-R069035GEProject No.:18-R069035GESolicitation Title:Bus Shelter Solar Lighting MaintenanceAddendum Date:July 26, 2018Procurement Contact:George Earnest CPPB, Buyer, George.earnest@mymanatee.org

RFO 18-R069035GE IS AMENDED AS SET FORTH HEREIN. RESPONSES TO QUESTIONS POSED BY PROSPECTIVE PROPOSERS ARE PROVIDED BELOW. THIS ADDENDUM IS HEREBY INCORPORATED IN AND MADE A PART OF RFO NO. 18-R069035GE.

Add:

# ATTACHMENT E, GENERAL AND TECHNICAL SPECIFICATIONS PERTAINING TO SOLAR LIGHTING, PASSENGER BUS SHELTERS

Attachment E, General and Technical Specifications Pertaining to Solar Lighting, Passenger Bus Shelters, has been added per this Addendum No. 1 and hereby incorporated into the RFO.

## Change to:

## Section A, Article A.01 Offeror Due Date

The Due Date and Time for submission of Offers in response to this Request for Offers (RFO) <u>is</u> <u>August 3, 2018</u> 3:00 P.M. ET. Offers must be delivered to the following location: Manatee County Administration Building, 1112 Manatee Ave. W., Suite 803, Bradenton, FL 34205 or via email to the Designated Procurement Contact via email at <u>George.earnest@mymanatee.org</u> prior to the Due Date and Time.

#### **QUESTIONS AND RESPONSES:**

- Q1. Does Manatee request any minimum light output specifications to be met after maintenance? Industry standards use measurements for Peak, Average, and Minimum light output in a given area for security lighting? For example, 25fc at peak, 2.5 fc average and 0.1 fc in an area of 40 square feet measured at bench height.
- R1. Yes, refer to Attachment E, Section E.3, incorporated herein, for the lighting output specifications.
- Q2. What is the operation time for the safety light? Standard operation is from dusk till dawn, with bright lighting during operational times (dusk to 12 midnight) and reduced safety lighting during off peak hours (midnight to 5 AM)? What must the duty-cycle be programmed to in order to meet the quarterly maintenance requirements?
- **R2.** There is a dimming function when no occupants are in the shelter and then the power up accomplished using a Passive Infrared (PIR) Circuit. The lighting pre-set specification is in Attachment E, Section E.5.

### Q3. How many days of autonomy is required for the solar system?

**R.3** Per Attachment E, Section E.6, the current specification is a minimum, two days of reserve power in the event insufficient solar power is generated due to the lack of sun/inclement weather

### Q4. Is there advertising lighting in the shelters?

R.4 No

Q5. What time requirements are needed for the advertising lighting if present?

R.5 Not applicable.

- Q6. Does Manatee request vendors to provide photometric plot drawings to give confirmation of above measurements?
- **R6.** No, photometer plots are not required. The Preventive Maintenance program is intended to confirm functionality, via the Vendor's Summary Report as per Exhibit 1, Section 1.06.

## Q7. Will Manatee County require all replacement systems and parts be UL Listed?

R7. Yes

- Q8. Does Manatee request vendors to provide detailed ALR and autonomy calculations based on the worst solar isolation period of the year (December) for Manatee. Still adhering to the 1.25 Minimum ALR and 2 day minimum?
- **R8.** No. The project scope is for Preventive Maintenance inspections and to define non-functional elements for solar lighting at specific passenger shelter locations.
- Q9. SOL lighting systems is no longer in business to supply replacements for failed parts for their shelter systems. Will the County allow the use of used or scavenged parts or in all cases shall new lighting system parts, or complete systems, be installed if current systems fail to meet performance specifications?
- **R9.** New replacement parts are required for all failed components and/or complete systems.

quarterly checking the systems operation and state of health 24/7 making it more economical for Manatee.

- **R10.** Yes, the self-test charge/load feature is required for replacement systems.
- Q11. Warranty on replacement systems typically there is a comprehensive warranty in place for the solar system, with a prorated battery warranty (due to varying placement and site conditions). For example: Each system shall have a minimum warranty of five (5) years. Photovoltaic panels shall have a minimum warranty of 20 years. Batteries shall have a prorated 5year warranty (100% replacement for three years, 50% replacement for the 4th year, 25% replacement for the fifth year). Will Manatee require a warranty such as this on replacement batteries panels and electronics systems?
- **R11.** Yes. Refer to Attachment E, Section E.2.
- Q12. Other than the listed SOL and Urban Solar systems currently in use by Manatee, are there any other solar systems from other shelter manufacturers (i.e. Brasco) in the field requiring maintenance/retrofit?
- **R12.** Currently there are two types of shelters in service in Manatee County, Tolar and Brasco. Most Tolar shelters have SOL systems installed but the newer Tolar shelters have Urban Solar. All Brasco shelters currently have the Urban Solar systems.

NOTE: Items that are struck through are deleted. Items that are <u>underlined</u> have been added or changed. All other terms and conditions remain as stated in the RFO.

End of Addendum

#### **INSTRUCTIONS:**

Receipt of this addendum must be acknowledged as instructed in the solicitation document. Failure to acknowledge receipt of this Addendum may result in the response being deemed non-responsive.

AUTHORIZED FOR RELEASE: TOOOR

# ATTACHMENT E

# GENERAL AND TECHNICAL SPECIFICATIONS PERTAINING TO SOLAR LIGHTING, PASSENGER BUS SHELTERS

## E.1 SOLAR LIGHTING GENERAL INFORMATION

MCAT has performed extensive research to determine minimum solar powered lighting specifications for solar powered shelter lighting. Bidders shall provide a bid for the Urban Solar ® Model RMS 30/60 or an approved equal meeting the following specifications as the minimum allowable benchmarks for performance of the lighting unit. If not bidding an Urban Solar model RMS 30/60 lighting package, the Bidder shall be prepared to provide a sample of their product for evaluation by MCAT prior to award of the contract and/or delivery of the shelter components.

## E.2 SOLAR LIGHTING WARRANTY MINIMUMS

- A. Battery 5 years (prorated)
- B. LED's -20 years
- C. Controller 5 years
- D. Solar Panel 20 years
- E. Light Fixture 10 years

## E.3 SOLAR LIGHTING REQUIREMENTS

- A. The minimum reading of foot candles (fc) at the ground level in the larger passenger shelter shall be no less than 5fc in the middle of the shelter and no lower than 15fc at a height of 4' from the ground (at the same location).
- B. The light should be easily integrated into the interior of all MCAT passenger shelters and mounted at a height of approximately 8'.
- C. Solar lighting shall be centered in the shelter and have even light distribution.
- D. All wiring should be concealed.
- E. A 110v hard wire solution shall be offered.
- F. All exposed metal parts shall be powder coated to match the shelter.

## E.4 LIGHTING SYSTEM PERFORMANCE REQUIRMENTS

A. The LED lighting fixture shall incorporate the latest LED technologies to provide uniform light with multi-directional mounting of LED's.

- B. In the event one LED were to fail, the remaining LED's are to remain in operation.
- C. The circuit substrate containing the LED's shall be made of flexible materials to allow the substrate to conform to different angles to achieve the minimum required fc readings as listed above. The secondary substrate shall be made of a flexible aluminum with a heat transfer epoxy between it and the flexible circuit containing the LED's.
- D. The light fixture should at minimum contain 24, 1W, 100Lumen LED's. The LED's should be 5000k (+-10%) for natural daylight color representation. Any LED out of this range will not be acceptable to MCAT.
- E. The light fixture shall have adequate heat sinking to maximize LED life at 100% non-condensing humidity. The working temperature range for MCAT's lighting system is estimated at between 10° and 130°.
- F. A dimming function must be installed to change the intensity (and energy usage) of the system to 15% of full illumination when no shelter occupants are detected and shall power up to 100% at the first detection of a shelter occupant using a Passive Infrared (PIR) circuit. The sensitivity of the PIR circuit shall be adjustable to allow for different shelter location ambiance, i.e. passing cars, blinking lights, etc.

# E.5 LIGHTING SYSTEM TECHNICAL SPECIFICATIONS

- A. The water tight light fixture at minimum should be constructed of .090 inch thick aluminum, and ¼ inch clear polycarbonate lens that can be removed for cleaning. The light fixture shall be vandalism resistant to avoid paraphernalia to be stored in the unit.
- B. The Solar Panel shall be a multi-crystal photovoltaic (PV) module that can rotate to optimize the collection of solar light rays, and shall have a solar cell conversion efficiency of 16% minimum. It shall be designed to be mounted on the roof of the shelter specified herein.
- C. The charger/controller shall at minimum perform regulation voltage disconnect to prevent overcharging at a setting of 14.1v.
- D. A low voltage disconnect setting of 11.7v is required to prevent battery from deep cycle discharge.
- E. Lighting preset to operational shut-down at 6 hours after dusk and resume operation at 2 hours pre-dawn; settings must be adjustable to different shelter scenarios.

F. Green and red charge/load lights are required and must be easily visible in a dark environment.

# E.6 BATTERY REQUIREMENTS

- A. A 12v sealed lead acid, maintenance free, non-spillable, and air shippable battery shall be supplied as the DC power source with a weather resistant inline fuse holder and wire harness.
- B. The battery shall be sized to meet the systems operational requirements and provide for 2 days of reserve power in the event insufficient solar power is generated due to the lack of sun in times of inclement weather. The battery must be installed within the lighting fixture to eliminate vandalism or theft of the battery.