



1112 Manatee Ave. West  
Bradenton, FL 34205  
[purchasing@mymanatee.org](mailto:purchasing@mymanatee.org)

## Solicitation Addendum

---

Addendum No.:	3
Solicitation No.:	19-R071409CD
Project No.:	
Solicitation Title:	Rental of Mobile Dewatering Plant
Addendum Date:	November 8, 2019
Procurement Contact:	Chris Daley, CPPO, CPPB, Procurement Manager

**IFB NO. 19-R071409CD is amended as set forth herein. Responses to questions posed by prospective bidders are provided below. This addendum is hereby incorporated in and made a part of IFB NO. 19-R071409CD.**

### QUESTIONS AND RESPONSES:

**Q1- Item D under Technical requirements states that the contractor will supply a submersible pump and pull the alum sludge from the pond. Please clarify that this is not the spec requirement per the pre-bid meeting.**

R1- The Dewatering Plant operator can pull direct from the plant discharge, or from the pond. The submersible pump would be required if pulling from the pond.

**Q2- If the centrate/filtrate discharge line is not of a sufficient size to handle the discharge who is responsible for providing additional capacity?**

R2- Should the discharge to the lift station need to be upsized, the County would be responsible.

NOTE: Items that are ~~struck through~~ are deleted. Items that are underlined have been added or changed. All other terms and conditions remain as stated in the IFB.

**End of Addendum**

### INSTRUCTIONS:

Receipt of this addendum must be acknowledged as instructed in the solicitation document. Failure to acknowledge receipt of this Addendum may result in the response being deemed non-responsive.

AUTHORIZED FOR RELEASE