



1112 Manatee Ave. West  
Bradenton, FL 34205  
[purchasing@mymanatee.org](mailto:purchasing@mymanatee.org)

## Solicitation Addendum

---

Addendum No.: 1  
Solicitation No.: 20-TA003281AJ  
Solicitation Title: SEWRF Biosolid Dryer Regenerative Thermal Oxidizer (RTO)  
Unit Rehabilitation  
Addendum Date: May 20, 2020  
Procurement Contact: Abigail Jenkins

**IFB No. 20-TA003281AJ is amended as set forth herein. Responses to questions posed by prospective bidders are provided below. This addendum is hereby incorporated in and made a part of IFB No. 20-TA003281AJ.**

### QUESTIONS AND RESPONSES:

**Q1. IFB page #41, Section B, Bid Item 2, line #6 it mentions supply and installation of a barrier consisting of ¼” 304 SS to isolate the media from the insulation. We will bid the project according to specifications, but we would like to submit a line item to replace the barrier with a 330 SS thin gauge that will accommodate the temperature and would be installed in a manner that would “float” to adjust for the temperature changes. This procedure will allow the frequent washouts without compromising the insulation. The County’s feedback is appreciated.**

R1. Because the barrier insulation is essential for protection from the required washouts on the unit every year, the 304 SS was a recommendation from Andritz. The County’s ultimate goal is to protect the chamber and insulation with the best possible solution; as such, the County will consider alternate solutions to protect and extend the life of the RTO Units.

**Q2. The phone number provided for the contact at Florida Power and Light, Don Sayer (941) 708-2900 is not a working phone number. Do you have another number for this contact?**

R2. Florida Power & Light Major Account Contact Information:

- David R Heiser, FPL Customer Advisor, [David.heiser@fpl.com](mailto:David.heiser@fpl.com), 941-316-6220 (o), 941-350-4873 (c).

- Larisa Gadson, FP&L Account Specialist, [larisa.gadson@fpl.com](mailto:larisa.gadson@fpl.com), 800-995-5761, option 7 (o), 561-640-2421 (alternative number).
- Brett Coomer, Back-up Customer Advisor, [brett.coomer@fpl.com](mailto:brett.coomer@fpl.com), 941-316-6257 (o), 386-576-3186 (c).

NOTE: Items that are ~~struck through~~ are deleted. Items that are underlined have been added or changed. All other terms and conditions remain as stated in the IFB.

**END OF ADDENDUM**

**INSTRUCTIONS:**

Receipt of this addendum must be acknowledged as instructed in the solicitation document. Failure to acknowledge receipt of this Addendum may result in the response being deemed non-responsive.

AUTHORIZED FOR RELEASE