



MANATEE COUNTY

February 16, 2011

All Interested Bidders:

SUBJECT: Invitation for Bid #10-3699-OV
26th Avenue Fuel Island Rehabilitation
Location: Grounds of the Public Works Facility, East Bradenton, FL 34208

ADDENDUM #1

Bidders are hereby notified that this Addendum shall be acknowledged on page 00300-1 of the Bid Form and made a part of the above named bidding and contract documents. Bids submitted without acknowledgement of the Addendum will be considered incomplete.

The following items are issued to add to, modify, and clarify the bid and contract documents. These items shall have the same force and effect as the original bidding and contract documents, and cost involved shall be included in the bid prices. Bids to be submitted on the specified bid date, shall conform to the additions and revisions listed herein.

Additional questions shall not be accepted at this time as the stated deadline of **February 10, 2011** has lapsed. This deadline has been established to maintain fair treatment of all potential bidders, while maintaining the expedited nature of the Economic Stimulus that the contracting of this work may achieve.

As a result of the question received at the Pre-Bid Conference held on February 4, 2011 and questions received through February 10, 2011, Addendum No. 1 is made a part of the Bidding Documents.

Attachment:

- Memorandum from Salvatore Bordonaro, Jr., Project Manager, Project Management Division, Public Works responding to questions received at the Pre-Bid Conference and questions received through February 10, 2011. (1 Total Page)
- **Bidders Note:** A total of eight (8) photos of the existing supporting members above the canopy's decking are attached for your reference.

Financial Management Department – Purchasing Division
1112 Manatee Avenue West, Suite 803, Bradenton, FL 34205
Phone: 941-708-7527 – Fax: 941-708-7544

February 16, 2011
Invitation for Bid #10-3699-OV
26th Avenue Fuel Island Rehabilitation
Location: Grounds of the Public Works Facility
East Bradenton, FL 34208
Page 2

If you have submitted a bid prior to receiving this addendum, you may request in writing that your original, sealed bid be returned to your firm. All sealed bids received will be opened on the date stated.

END OF ADDENDUM #1

Bids will be received at the **Manatee County Purchasing Division, 1112 Manatee Avenue West, Suite 803, Bradenton, FL 34205** until **2:00 P.M. on February 25, 2011**

Sincerely,



R. C. "Rob" Cuthbert, C.P.M., CPPO
Purchasing Division Manager

Ov

Attachments:

Memorandum (1 total page)

Photos – Eight (8) via PDF of the
Existing Supporting Members above the
Canopy's Decking

MEMORANDUM



Public Works Department
Project Management
1022 26th Avenue East
Bradenton, FL 34208

Phone: 941.708-7450
Fax: 941.708-7579
www.mymanatee.org

MANATEE COUNTY FLORIDA

To: Olga Valcich
From: Salvatore Bordonaro Jr.
Date: February 15, 2011
Subject: Response to Pre-Bid Conference Held February 4, 2011
IFB #10-3699-OV 26th Avenue Fuel Island Rehabilitation

1. Question: What is the condition of the supporting structure above the canopy?

Answer: Page 27, SECTION 01150, MEASUREMENT AND PAYMENT, BID ITEM NO.8 PAINTING: add the following paragraph:

“The canopy’s structural steel support members above the decking, and the fascia’s diagonal bracket bracing shall be cleaned and painted per the specifications.”

Note: Attached to this Addendum are photos of the existing supporting members above the canopy’s decking for your reference.

2. Question: Who is responsible for the fuel island’s temporary lighting?

Answer: Manatee County will provide the temporary lighting.

3. Question: What is the Fire Marshal’s contact information?

Answer: The Southern Manatee Fire & Rescue District contact information is as follows;

**Ken Reed, Inspector/EMT
Southern Manatee Fire & Rescue District
Bureau of Fire Prevention, Inspection and Investigation
PO Box 20216
2451 Trailmate Drive
Bradenton, FL 34204-0216
Phone: 941-751-7675
FAX: 941-751-7694**

4. Question: What is the fuel island’s replacement value?

Answer: The fuel island’s replacement value is \$150,000.00.















